

... Fire Protection by Computer Design

EASTERN FIRE PROTECTION
170 KITTY HAWK AVE
AUBURN, ME 04210
207-784-1507

Job Name : BRIGG'S STREET APARTMENTS
Drawing : 1 OF 1
Location : PORTLAND, MAINE
Remote Area : 1
Contract : AU-5364-15
Data File : AU-5364-15 B.S.A. BASEMENT WORKSHOP CALC. CPVC.WXF

HYDRAULIC CALCULATIONS
for

Project name: BRIGG'S STREET APARTMENTS
Location: PORTLAND, MAINE
Drawing no: 1 OF 1
Date: 5/16/16

Design

Remote area number: 1
Remote area location: BASEMENT WORKSHOP
Occupancy classification: OHI
Density: .15 - Gpm/SqFt
Area of application: 378 - SqFt
Coverage per sprinkler: 125 - SqFt
Type of sprinklers calculated: RELIABLE F1FR56 WHITE RECESSED PENDENT
No. of sprinklers calculated: 4
In-rack demand: - GPM
Hose streams: 0 - GPM
Total water required (including hose streams): 78.136 - GPM @ 52.035 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 7/7/2015
Location: PORTLAND, MAINE
Source: PORTLAND WATER DISTRICT

Name of contractor: EASTERN FIRE PROTECTION
Address: 170 KITTY HAWK AVE / / AUBURN, ME 04210
Phone number: 207-784-1507
Name of designer: ERIC MELANSON
Authority having jurisdiction: STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)

Water Supply Curve C


EASTERN FIRE PROTECTION
BRIGG'S STREET APARTMENTS

City Water Supply:

C1 - Static Pressure : 67
C2 - Residual Pressure: 35
C2 - Residual Flow : 887

Demand:

D1 - Elevation : 4.690
D2 - System Flow : 78.136
D2 - System Pressure : 52.035
Hose (Demand) :
D3 - System Demand : 78.136
Safety Margin : 14.607



Fittings Used Summary

EASTERN FIRE PROTECTION
BRIGGS STREET APARTMENTS

Fitting Legend Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G NFPA 13 Gate Valve	0	0	0	0	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
L NFPA 13 Long Turn Elbow	0.5	1	2	2	3	4	5	5	5	6	8	9	13	16	18	24	27	30	34	40
N* CPVC 90'Ell Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O* CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

- Diameter Units Inches
- Length Units Feet
- Flow Units US Gallons per Minute
- Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA 2007

EASTERN FIRE PROTECTION
BRIGG'S STREET APARTMENTS

Page 4
Date 5/16/16

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	67.0	35	887.0	66.643	78.14	52.035

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
HEAD1	0.0	5.6	11.21	18.75	
HEAD2	0.0	5.6	11.21	18.75	
1	106.83	5.51	11.57	18.75	K=K @ LIN2
2	106.83	5.51	12.24	19.28	K=K @ LIN2
3	107.749		13.07		
4	106.83	5.51	12.59	19.56	K=K @ LIN2
5	106.83	5.51	13.9	20.55	K=K @ LIN2
6	107.749		14.86		
21	107.749		24.01		
22	107.749		28.21		
TOR	105.0		34.04		
BFP	101.0		39.01		
BASE	98.0		46.3		
TEST	96.0		52.04		

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE PROTECTION
BRIGG'S STREET APARTMENTS

Page 5
Date 5/16/16

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
HEAD1 to LIN1	0 0	5.60	18.75 18.75	1 1.049	O	5.0 0.0 0.0	1.001 5.000 6.001	120 0.1156	11.210 0.0 0.694			Vel = 6.96
LIN1			0.0 18.75						11.904			K Factor = 5.43
HEAD2 to LIN2	0 0	5.60	18.75 18.75	1 1.101	O	5.0 0.0 0.0	1.001 5.000 6.001	150 0.0605	11.210 0.0 0.363			Vel = 6.32
LIN2			0.0 18.75						11.573			K Factor = 5.51
1 to 2	106.830 106.830	5.51	18.75 18.75	1 1.101		0.0 0.0 0.0	11.000 0.0 11.000	150 0.0604	11.573 0.0 0.664			K = K @ LIN2 Vel = 6.32
2 to 3	106.830 107.749	5.51	19.28 38.03	1 1.101	O	5.0 0.0 0.0	0.500 5.000 5.500	150 0.2235	12.237 -0.398 1.229			K = K @ LIN2 Vel = 12.82
3 to 6	107.749 107.749		0.0 38.03	1 1.101		0.0 0.0 0.0	8.000 0.0 8.000	150 0.2234	13.068 0.0 1.787			Vel = 12.82
6			0.0 38.03						14.855			K Factor = 9.87
4 to 5	106.830 106.830	5.51	19.56 19.56	1 1.101	N	7.0 0.0 0.0	13.000 7.000 20.000	150 0.0653	12.592 0.0 1.306			K = K @ LIN2 Vel = 6.59
5 to 6	106.830 107.749	5.51	20.54 40.1	1 1.101	O	5.0 0.0 0.0	0.500 5.000 5.500	150 0.2464	13.898 -0.398 1.355			K = K @ LIN2 Vel = 13.51
6 to 21	107.749 107.749		38.04 78.14	1.25 1.394		0.0 0.0 0.0	34.120 0.0 34.120	150 0.2683	14.855 0.0 9.154			Vel = 16.43
21 to 22	107.749 107.749		0.0 78.14	1.5 1.598	2N	18.0 0.0 0.0	12.460 18.000 30.460	150 0.1380	24.009 0.0 4.202			Vel = 12.50
22 to TOR	107.749 105		0.0 78.14	1.5 1.61	3E	12.0 0.0 0.0	11.080 12.000 23.080	120 0.2010	28.211 1.191 4.638			Vel = 12.31
TOR to BFP	105 101		0.0 78.14	2 2.067	Fsp	0.0 0.0 0.0	4.000 0.0 4.000	120 0.0598	34.040 4.732 0.239			** Fixed Loss = 3 Vel = 7.47
BFP to BASE	101 98		0.0 78.14	2 2.067	Zaa	0.0 0.0 0.0	3.000 0.0 3.000	120 0.0597	39.011 7.111 0.179			** Fixed Loss = 5.812 Vel = 7.47
BASE to TEST	98 96		0.0 78.14	2 1.72	2L T G	3.705 6.174 0.617	40.000 10.497 50.497	150 0.0964	46.301 0.866 4.868			Vel = 10.79
TEST			0.0 78.14						52.035			K Factor = 10.83