Portland Fire Department

1/2/2019

CERTIFIED MAIL

RE: 194 DANFORTH ST

PORTLAND, ME 04102

057 K006001

Page 1 of 2

NOTICE OF VIOLATION AND ORDER TO CORRECT

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 5/29/2017 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 2/1/2019 9:30:00AM.

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan Fire Prevention Bureau City of Portland

NON-COMPLIANCE VIOLATION LIST			
NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-31.2.2.1	1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	All apartment doors must be fire rated and have a rating tag attached to each door.	5/1/2017
NFPA 101-8.6	Vertical openings shall be enclosed or protected in accordance with Section 8.6.	Install a 1 hr fire seperation in above and below the dumbwaiter opening at the second floor landing in the rear stairs.	6/5/2017
NFPA 70	Refer to NFPA 70, National Electrical Code, for information on missing breakers in an electrical panel.	2 open spaces in the electrical panel inside Apartment 4 just inside the entry door.	6/12/2017
NFPA 101-8.3.3.3	Fire doors must be self- or auto-closing.		6/28/2017
NFPA 101-31.3.4.5; City Code 10-3(i)	Photoelectric, hardwired with battery backup smoke alarms must be provided in every sleeping room, outside every sleeping area, and on every level, including the basement.	IMMEDIATELY install temporary alarms where required. Fully compliant, permanent alarms must be installed by the date given. Install hardwired smoke detectors in apartments 2 and 3 in the living room (Immediately outside the bedroom is not possible do to the kitchen location)	6/28/2017