CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager		Inspector	Inspection Date 3/14/2007	
49 SUMMER STREET LLC		Suzanne Hunt		
Locatation	CBL	Status	Inspection Type	
49 SUMMER ST	058 A033001	Re-Inspect 5 Days	Complaint-Non Compliance	

					•	•
	Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1)	6-109/5.0 Violation: Notes:	Unoccupied residential structures building must be secured from va				
2)	6-108.6 Violation: Notes:	Interior Required equipment and utilities no water, not heat				
3)	22-3 (a) Violation: Notes:	Exterior Rodent Harborage misc trash in yard				
4)	22-3.3(a) Violation: Notes:	Interior Premises to be kept free from roo basement must be cleared of de	_		Basement	
5)	6-108.6 Violation: Notes:	Required equipment and utilities reported broken pipe must be rep	paired			

Comments: