

Marge Schmuckal - application #2013-01789 - 30 Salem Street

From: Marge Schmuckal
To: gregory.davis54@yahoo.com
Date: 8/15/2013 10:23 AM
Subject: application #2013-01789 - 30 Salem Street

Hi Gregory,

I am in receipt of your permit to put a dormer on the rear of 30 Salem Street. Presently I can not review your application for Zoning because your plans are not scaleable. Our requirements for building plans submittals must have a bar scale on the plans in order to calibrate our scaling program. I can not scale as given on the plans. I also did not receive a plot plan showing setbacks. So I am assuming that the current building is legally nonconforming for setbacks. If the building does meet setbacks, then I won't have to go thru a lot of calculations to determine compliance. A required plot plan submittal would have helped me determine that at the get-go.

Please supply the above information so that I can do my review. Your permit is on hold until I receive that information. If you have any questions, please call me at 874-8695.

Marge