

NOTES:

ELECTRICAL CONTRACTOR TO SCHEDULE ON-SITE REVIEW OF PROJECT PRIOR TO ROUGH-IN.

CENTER SWITCHES AT 42" AFF UNLESS OTHERWISE NOTED.

CENTER OUTLETS AT 12" AFF UNLESS OTHERWISE NOTED.

OUTLETS TO BE INSTALLED PER PLANS, ADD OUTLETS AS REQ'D BY CODE.

SMOKE DETECTORS/CO TO CODE.

PROVIDE POWER IN ATTIC NEAR RADON VENT STACK FOR POTENTIAL EXHAUST FAN.

NO MORE THAN 4 SWITCHES GANGED IN ONE BOX. IF MORE THAN 4 SWITCHES ARE REQUIRED, STACK 2 BOXES ABOVE ONE ANOTHER WITH EQUAL NUMBER OF SWITCHES IN EACH BOX. USE DUMMY SWITCH IF NECESSARY.

BATH FAN/LIGHTS TO BE PANASONIC WHISPER LIGHT UNITS, FANS TO BE ON TIMER SWITCHES.


THIRD FLOOR HEAT: HEAT PUMP SYSTEM, TBD

SECOND FLOOR HEAT: EXISTING

COMMUNICATION: TBD



SECOND FLOOR ELECTRICAL PLAN







REV

REV