

58-B-20

Return to
Insp (N. Adams)
for file

Walter C Haycock
10 Madeline Dr.
Brunswick Me. 04011

March 16, 2011

Code Enforcement
Inspections Division
City Of Portland, Me.

RE: 3 Sommer Set St.
Portland, Me.

To Whom it may concern:

I Walter Haycock, License # MS60004066. Do state, that to the best of my knowledge, the wiring I installed at the above address, as per the PERMITS issued to me, is up to date, and meets the present standards of the: Local, State, and National Electrical Codes. I further state, that the existing wiring, appears to be in good shape, and I understand that I am responsible for that as well.

Just for the record, I do carry insurance: MMG Insurance Company. P.O. Box 15011
Lewiston, Me. 04243-9561 Policy # SC 0118691
Agent # 564 18
Foy Insurance- Westbrook
506 Main St. Suite 14
Westbrook, Me. 04092
207-854-3634
Contact: Mike Boisvert

During the first walk-through with Brian LaFlamm, (The Electrical Inspector,) I explained to him, that I WAS using the existing circuits AS per the electrical plans, given to me. Most important, I pointed out the existing Breaker Panel, and Electrical Room, which was a disaster. I noted the changes he insisted: Add a second ground bar to remove doubled up Neutrals, Remove non-compatible breakers, neaten up as best I could, make sure bonding was complete. Of which I complied. I received 3 punch lists with numerous items. And I corrected them.

Sincerely
Walter Haycock
207-837-8873