PROJECT: NEW YARD
SUBJECT: OPERATIONS BUILDING
ITEM: floor slab Sections, Details

GAGNON ENGINEERING INC.
Structural Consultants

DATE: 07/11/14
BY: RG
SHEET: 8 OF 9
PROJECT NO. 402

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/28/14

SECTION FS1
SCALE: 1"=1'-0"

FLOOR SLAB AT TRAVEL-LIFT TRACK
(see plan for locations)

NOTES:

4000 psi, 4" SLUMP CONCRETE, GRADE 60 REBAR
SAMPLE & TEST CONCRETE PER CONTRACT SPECs.
Lap-splice Bars 36 diameter UNO.

SUB-SLAB PREP & INSULATION NOT SHOWN,
HEATING TUBES NOT SHOWN

SECTION FS2
SCALE: 1"=1'-0"

FLOOR SLAB CONSTRUCTION JONT typ UNO
(see plan for locations)

STATE OF MAINE
ROGER R. GAGNON
No. 3409
LICENSED
PROFESSIONAL ENGINEER