

Design Calculations

For:

Precast Utility Building

UniTel Regulator Building

16065

Portland, ME

Submitted on:

6/20/2016 REV-00


REV-01

United Concrete Products, Inc.


173 Church Street

Yalesville, CT 06492

(800) 234.3119




FLOOR MAIN REINF SECTION




FLOOR RIB REINF SECTION

STATE OF MAINE
 Jeffrey R. Walton, Jr.
 No. 12871
 LICENSED PROFESSIONAL ENGINEER
 AUG 29 2016

PROVIDE 1) #4 ADDN'L
EA SIDE OF SKYLIGHT




ROOF MAIN REINF SECTION




ROOF RIB REINF SECTION


STATE OF MAINE
 Jeffrey R. Walton, Jr.
 No. 12871
 LICENSED PROFESSIONAL ENGINEER
 AUG 29 2016



RIGHT ELEVATION




LEFT ELEVATION



INTERIOR ELEVATION





AUG 29 2016

General Information

Applicable Codes:

- 1.) ACI 318-11 Building Code Requirements for Structural Concrete (318-11) and commentary (318R-11)
- 2.) AISC Manual of Steel Construction, 14th Editions (ASD & LRFD)
- 3.) MNL 120-10 PCI Design Handbook, 7th Edition
- 4.) International Building Code 2012 with Amendments
- 5.) SEI/ASCE 7-10 Minimum Design Loads for Building and other Structures
- 6.) 2010 Maine Uniform Building and Energy Code

Material Specifications:

1.) Precast Concrete.....	$f'_{ci} = 2500$ psi
	$f'_{c,28} = 5000$ psi
	$w = 150$ pcf
(Normal weight concrete)	
2.) Prestressed/Post-Tensioned Concrete	$f'_{ci} = 2500$ psi
	$f'_{c,28} = 5000$ psi
3.) Mild reinforcement (ASTM A615).....	$f_y = 60$ ksi
4.) Prestressed Reinforcement (ASTM A417 7-wire low lax).....	$f_y = 270$ ksi
5.) Steel Plates and Angles (ASTM A36).....	$f_y = 36$ ksi
6.) Hollow steel sections (ASTM A500).....	$f_y = 46$ ksi
7.) Bolts (ASTM A325).....	$\phi f_v (N) = 36$ ksi
	$\phi f_v (X) = 45$ ksi
8.) Threaded rod (ASTM A305).....	$\phi f_v = 18$ ksi
9.) Headed anchor studs (ASTM A108).....	$f_y = 50$ ksi
10.) Welded wire fabric (ASTM A185 plain WWR).....	$f_y = 80$ ksi
11.) Allowabl soil bearing capacity.....	$F_{brg} = 3000$ psf



Wind Loading

User Input:

Wind importance factor = 1.00 (not used in ASCE 7-10)
Occupancy Risk Category = IV
Exposure Category = C
Basic wind speed, V_{ult} = 150 mph V_{asd} = 116 mph
Topographic Factor, K_{zt} = 1.0 (Section 26.8-1)
Wind Directionality Factor, K_d = 0.85 (Table 26.6-1)
Gust Effect Factor, G = 0.85 (Section 26.9.1)
Windward Ext Press Coeff, C_{pw} = 0.8 (Figure 27.4-1)
Leeward Ext Press Coeff, C_{pl} = -0.5
Internal Pressure Coefficient, GC_{pi} = -0.18 (Figure 26.11-1)

Calculated values:

Velocity Pressure Coefficient at "z", K_z = 0.85
Velocity Pressure at "z", q_z = 41.6 psf
Windward design Pressure, p_w = 35.8 psf
Leeward design Pressure, p_l = -25.2 psf
MWFRS pressure = 61.0 psf

Wind overturning moments:

	V_u (k)	M_u (k-ft)
X-axis =	34.55	195.77
Y-axis =	19.35	109.63

Seismic Loading (per Simplified Alternative Structural Design Criteria)

User Input:

Seismic design category = C
Seismic importance factor = 4.50
Seismic risk category = IV
Short period response, S_s = 0.241
1 second period response, S_1 = 0.078
Seismic site class = D (D to be used if soil not known)
 F_a = Per USGS design maps
 F_v = Per USGS design maps
 R = 4 (4 for ordinary reinforced PC Brg walls)

Calculated values:

S_{MS} = 0.385 S_{DS} = 0.257
 S_{M1} = 0.187 S_{D1} = 0.125
Seismic mass, W = 166.7 kips
X&Y-axis Base Shear, V_u = 48.2 kips
Seismic overturning moment: 273.2 k-ft

Seismic controls X-axis design
Seismic controls Y-axis design



Geometry & Live Loads

Building width = 28.00 ft
 Building length = 50.00 ft
 Building height = 11.33 ft
 Wall height = 9.67 ft
 Roof overhang = 2.00 in

Roof Live Load = 20 psf
 Roof Snow Load = 80 psf
 Roof Super. DL = 5 psf
 Floor Live Load = 150 psf
 Floor Super. DL = 0 psf
 Wall Lateral Load = 61.0 psf

Roof thickness_(ave) = 6.54 in
 Wall thickness = 5 in
 Floor thickness_(ave) = 5.925714 in

Blockouts in roof = 48.00 sq-ft

Blockouts in walls:

Wall (1) = 92.96 sq-ft
 Wall (2) = 4.00 sq-ft
 Wall (3) = 92.96 sq-ft
 Wall (4) = 9.59 sq-ft


Ultimate Component Wind Loads per wind worksheet:

$P_{ult(+)} = 41.60$ psf

$P_{ult(-)} = -51.20$ psf

Bldg on Foundation: 1 (1 = on foundation | 0 = brg on soil)


Blockouts in Floor = 0.00 sq-ft



Building Weight

* Conservatively ignore equipment for overturning

Roof =	119.77 kips	
Wall (1) =	24.40 kips	
Wall (2) =	16.16 kips	
Wall (3) =	24.40 kips	
Wall (4) =	15.81 kips	
Floor =	103.70 kips	
Addn'l DL =	13.13 kips	(Interior Wall)
Total =	317.38 kips	



Sliding (Using side with maximum exposure)

Coefficient of friction, C_f =	0.3	(assumed)
Sliding resistance =	95.2 kips	(0.3*building wt.)
Sliding force =	34.55 kips	(maximum wall area times wind force)
F.S. =	2.76	


Overturning

F.S. against overturn about the x-axis:

M_{OT} =	273.2 kip-ft
M_{RES} =	7597 kip-ft
F.S. =	27.8


F.S. against overturn about the y-axis:

M_{OT} =	273 kip-ft
M_{RES} =	4259 kip-ft
F.S. =	15.6



Soil Bearing Stress (about y-axis which controls)

Building rests on foundation N/A



Lateral wall loading and forces

Walls 2 & 4 (Non-Load Bearing)

(Roof connections)

Shear force at top of wall, $V_u =$	8.03 kips
capacity of roof connections each, $\phi V_n =$	3.0 kips (per calc sheet)
# of connections required =	2.68 (min of 2)

(Wall properties)

Wall length =	28.00 ft	
Area =	1680.0 sq-in	
Axial Load =	15.225 kips	(ultimate weight of wall only)
$S_{wall} =$	94080 in ³	($bh^2/6$)

(Wall forces)

$M_u =$	77.7 k-ft	
$T_u =$	1.12 kips	(maximum compressive force at end)
$T_u =$	-0.03 kips	(maximum tension force at end, "+" = net compression)
$\phi T_n =$	21.6 kips	(Tension capacity w/ 2)#4 ea end of wall)

(Shear in concrete at base of wall)

* assume #4's @ 12" o.c. & $\mu = 1.4$ for integrally cast $\lambda = 1$

$$\phi V_n = \phi A_{vf} F_y \mu = 352.8 \text{ kips}$$

$$V_u = 4.61 \text{ kips} \quad \leftarrow \text{-----ok!}$$

(Wind Loading out of plane on wall)


(Re: attached LECWALL output)

w/

$P_{DL} =$	0.45 kips
$P_{lat} =$	1.12 kips
$P_{W(+)} =$	41.6 psf
$P_{W(-)} =$	-51.2 psf



Note: center vertical reinforcement
in wall ~ horizontal reinforcement
should be on inside face.



Walls 1 & 3 (Load Bearing)

(Roof connections)

Shear force at top of each wall, $V_u =$ 2.41 kips
capacity of roof connections each, $\phi V_n =$ 3.00 kips (per calc sheet)
of connections required = 2 (min of 2)

(Wall properties)

Wall length = 10.00 ft
Area = 600 sq-in
Axial Load = 3.976 klf (ultimate load of wall, roof and roof live load)
 $S_{wall} =$ 12000 in³ ($bh^2/6$)

(Wall forces)

$M_u =$ 23.3 k-ft
 $T_u =$ 9.37 kips (maximum compressive force at end)
 $T_u =$ 6.85 kips (maximum tension force at end, "+" = net compression)
 $\phi T_n =$ 21.6 kips (Tension capacity w/ 2)#4 ea end of wall)

(Shear in concrete at base of wall)

* assume #4's @ 12" o.c.

$\phi V_n = \phi A_v F_y \mu =$ 126.0 kips/ft
 $V_u =$ 0.63 kips <-----ok!

(Wind Loading out of plane on wall plus gravity)

(Re: attached LECWALL output)

w/	(typ/ft)	(Entire Wall)
$P_{DL} =$	1.80 kips	90.10 kips
$P_{LL} =$	1.13 kips	56.67 kips
$P_{Lat} =$	9.37 kips	
$P_{W(+)} =$	41.6 psf	2080.0 psf
$P_{W(-)} =$	-51.2 psf	-2560.0 psf



Beam Above Door or Wall Opening

(Geometry and loads)

length = 76.3 in
h = 29.9 in
d = 27.9 in
b = 5.00 in

door width = 76.25 in
door height = 86.125 in
Load bearing wall? = 1 (0 = no, 1 = yes)

$W_u = 3.437$ klf (includes roof live load)
 $M_u = 17.348$ k-ft $M_u = W_u l^2/8$
 $V_u = 6.93$ kips $V_u = W_u (l-d)/2$

(Flexure)

Assuming 2) #4 standard above door:

$a = A_s F_y / 0.85 f'_c b = 1.13$ in
 $\phi M_n = \phi A_s F_y (d - a/2) = 590$ k-in
 49.2 k-ft <-----ok!
 $\rho = 0.0029$

$A_s = 0.40$ sq-in

(Shear)

$\phi V_n = \phi 2 f'_c c^{1/2} b_w d / 1000 = 14.78$ kips
 $\phi V_n / 2 = 7.39$ kips <-----ok! No shear reinf req'd

Roof Design

See alternate roof design for sloped roof





[ASCE 7 Windspeed](#)
[ASCE 7 Ground Snow Load](#)
[Related Resources](#)
[Sponsors](#)
[About ATC](#)
[Contact](#)


Search Results

Query Date: Mon Jun 20 2016
Latitude: 43.6615
Longitude: -70.2553

**ASCE 7-10 Windspeeds
 (3-sec peak gust in mph*):**

Risk Category I: 107
Risk Category II: 118
Risk Category III-IV: 127
MRI 10-Year:** 76
MRI 25-Year:** 86
MRI 50-Year:** 91
MRI 100-Year:** 97

ASCE 7-05 Windspeed:
 99 (3-sec peak gust in mph)
ASCE 7-93 Windspeed:
 83 (fastest mile in mph)



*Miles per hour
 **Mean Recurrence Interval

Users should consult with local building officials
 to determine if there are community-specific wind speed
 requirements that govern.



[Print your results](#)

WINDSPEED WEBSITE DISCLAIMER

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the windspeed report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the windspeed report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the windspeed load report.

USGS Design Maps Summary Report

User-Specified Input


Report Title 9262 Unitol Regulator Building
 Mon June 20, 2016 15:15:32 UTC

Building Code Reference Document ASCE 7-10 Standard
 (which utilizes USGS hazard data available in 2008)

Site Coordinates 43.6615°N, 70.2553°W

Site Soil Classification Site Class D – “Stiff Soil”



Risk Category IV (e.g. essential facilities)



USGS-Provided Output

$S_S = 0.241 \text{ g}$	$S_{MS} = 0.385 \text{ g}$	$S_{DS} = 0.257 \text{ g}$
$S_1 = 0.078 \text{ g}$	$S_{M1} = 0.187 \text{ g}$	$S_{D1} = 0.125 \text{ g}$

For information on how the S_S and S_1 values above have been calculated from probabilistic (risk-targeted) and deterministic ground motions in the direction of maximum horizontal response, please return to the application and select the “2009 NEHRP” building code reference document.



For PGA_M , T_L , C_{RS} , and C_{R1} values, please view the detailed report.

Although this information is a product of the U.S. Geological Survey, we provide no warranty, expressed or implied, as to the accuracy of the data contained therein. This tool is not a substitute for technical subject-matter knowledge.

Components and Cladding SEI/ASCE 7-10 (Part 1) Wind Loading Wind Loading Design Sheet ≤ 60' by: Justin B. Currier January 5, 2015

Project:	9262 Unittl Regulator Building
PMC Job#:	16065
Dsg Date:	20-Jun-2016

Basic wind speed (mph):	150 <-- V _{ult} (Risk Category IV)
BV Pressure, P_v (psf):	57.6
Exposure Category:	C <-- per section 26.7
Importance Factor, I:	1.00 Not used in ASCE 7-10
Building Height, K_h (ft):	11.3 <-- per contract documents
Wind Directionality, K_d:	0.85 <-- per section 26.6
Topographic Factor, K_{zt}:	1.00 <-- per section 26.8
Int. Press. Coeff, GC_{pi}:	0.18 (+) <-- per section 26.11
	-0.18 (-)

Area (sq-ft)	Element GC _p vs Area (Fig 30.4-1)			Windward Zones 4 & 5
	4	5	5	
1	-1.10	-1.40	-1.40	1.00
10	-1.10	-1.40	-1.40	1.00
20	-1.05	-1.30	-1.30	0.97
50	-0.98	-1.15	-1.15	0.89
100	-0.93	-1.05	-1.05	0.82
200	-0.88	-0.95	-0.95	0.77
500	-0.80	-0.80	-0.80	0.70
1000	-0.80	-0.80	-0.80	0.70

Ht. (ft)	GC _p	-2.5	-2.4	-2.30	-2.20	-2.10	-2.00	-1.40	-1.30	-1.15	-1.10	-1.05	-0.98	-0.95	-0.93	-0.88	-0.50	0.80	0.77	0.82	0.89	0.97	1.00
15		-111.5	-107.4	-103.2	-99.0	-94.9	-90.7	-65.8	-61.6	-55.3	-53.3	-51.2	-48.3	-47.0	-46.2	-44.1	-28.3	25.8	24.6	41.6	44.5	47.9	49.1
20		-118.1	-113.7	-109.3	-104.9	-100.5	-96.1	-69.6	-65.2	-58.6	-56.4	-54.2	-51.1	-49.8	-48.9	-46.7	-30.0	27.3	26.0	44.1	47.1	50.7	52.0
25		-123.3	-118.7	-114.1	-109.5	-104.9	-100.3	-72.7	-68.1	-61.2	-58.9	-56.6	-53.4	-52.0	-51.1	-48.8	-31.3	28.5	27.2	46.0	49.2	52.9	54.3
30		-128.6	-123.8	-119.0	-114.2	-109.4	-104.6	-75.8	-71.0	-63.8	-61.4	-59.0	-55.7	-54.2	-53.3	-50.9	-32.6	29.7	28.3	48.0	51.3	55.2	56.6
40		-136.5	-131.4	-126.3	-121.2	-116.1	-111.0	-80.5	-75.4	-67.7	-65.2	-62.6	-59.1	-57.5	-56.5	-54.0	-34.6	31.6	30.0	50.9	54.5	58.6	60.1
50		-143.0	-137.7	-132.3	-127.0	-121.7	-116.3	-84.3	-79.0	-71.0	-68.3	-65.6	-61.9	-60.3	-59.2	-56.6	-36.3	33.1	31.5	53.4	57.1	61.4	63.0
60		-148.3	-142.7	-137.2	-131.7	-126.1	-120.6	-87.4	-81.9	-73.6	-70.8	-68.0	-64.2	-62.5	-61.4	-58.6	-37.6	34.3	32.6	55.3	59.2	63.6	65.3
70		-153.5	-147.8	-142.1	-136.3	-130.6	-124.9	-90.5	-84.8	-76.2	-73.3	-70.5	-66.4	-64.7	-63.6	-60.7	-39.0	35.5	33.8	57.3	61.3	65.9	67.6
80		-158.8	-152.8	-146.9	-141.0	-135.1	-129.1	-93.6	-87.7	-78.8	-75.8	-72.9	-68.7	-66.9	-65.8	-62.8	-40.3	36.7	35.0	59.2	63.4	68.1	69.9
90		-162.7	-156.6	-150.6	-144.5	-138.4	-132.3	-95.9	-89.9	-80.7	-77.7	-74.7	-70.4	-68.6	-67.4	-64.4	-41.3	37.6	35.8	60.7	65.0	69.8	71.6
100		-165.3	-159.2	-153.0	-146.8	-140.7	-134.5	-97.5	-91.3	-82.0	-79.0	-75.9	-71.6	-69.7	-68.5	-65.4	-41.9	38.2	36.4	61.7	66.0	70.9	72.8
120		-171.9	-165.5	-159.1	-152.6	-146.2	-139.8	-101.3	-94.9	-85.3	-82.1	-78.9	-74.4	-72.5	-71.2	-68.0	-43.6	39.8	37.8	64.1	68.6	73.8	75.7
140		-178.4	-171.8	-165.1	-158.5	-151.8	-145.2	-105.2	-98.5	-88.6	-85.2	-81.9	-77.2	-75.2	-73.9	-70.6	-45.3	41.3	39.3	66.6	71.2	76.6	78.6
160		-182.4	-175.6	-168.8	-162.0	-155.2	-148.4	-107.5	-100.7	-90.5	-87.1	-83.7	-78.9	-76.9	-75.5	-72.1	-46.3	42.2	40.2	68.1	72.8	78.3	80.3
180		-187.6	-180.6	-173.6	-166.6	-159.6	-152.6	-110.6	-103.6	-93.1	-89.6	-86.1	-81.2	-79.1	-77.7	-74.2	-47.6	43.4	41.3	70.0	74.9	80.5	82.6
200		-191.6	-184.4	-177.3	-170.1	-163.0	-155.8	-112.9	-105.8	-95.1	-91.5	-87.9	-82.9	-80.8	-79.3	-75.8	-48.6	44.3	42.2	71.5	76.5	82.2	84.3
250		-200.8	-193.3	-185.8	-178.3	-170.8	-163.3	-118.4	-110.9	-99.6	-95.9	-92.1	-86.9	-84.6	-83.1	-79.4	-50.9	46.4	44.2	74.9	80.2	86.1	88.4
300		-208.6	-200.8	-193.1	-185.3	-177.5	-169.7	-123.0	-115.2	-103.5	-99.6	-95.8	-90.3	-88.0	-86.4	-82.5	-52.9	48.3	45.9	77.8	83.3	89.5	91.9
350		-215.2	-207.2	-199.1	-191.1	-183.1	-175.0	-126.9	-118.8	-106.8	-102.8	-98.8	-93.1	-90.7	-89.1	-85.1	-54.6	49.8	47.4	80.3	85.9	92.3	94.7
400		-221.7	-213.5	-205.2	-196.9	-188.7	-180.4	-130.7	-122.5	-110.0	-105.9	-101.8	-96.0	-93.5	-91.8	-87.7	-56.3	51.3	48.8	82.7	88.5	95.2	97.6
450		-227.0	-218.5	-210.1	-201.6	-193.1	-184.6	-133.8	-125.4	-112.7	-108.4	-104.2	-98.3	-95.7	-94.0	-89.8	-57.6	52.5	50.0	84.7	90.6	97.4	99.9
500		-232.2	-223.6	-214.9	-206.2	-197.6	-188.9	-136.9	-128.3	-115.3	-110.9	-106.6	-100.5	-97.9	-96.2	-91.9	-58.9	53.7	51.1	86.7	92.7	99.7	102.3

Table based upon pressure as defined in Section 6.5.10 with $q_z = 0.00256 K_z K_{zt} K_d V^2 I$ (psf) and 6.5.12.4.2 with $p = q(GC_p) - q_i(GC_{pi})$ (psf)

Project:	UPL BLOB	Job #	N/A
Subject:	STD FND PINN CONN	Sheet #	1 of 1
Calc by:	JEC	Chk by:	
		Date:	4/30/10

17375 Crookes Farm Road — Rixeyville, Virginia 22737 — T: 540.212.3900 — W: <http://www.pmceng.us>

STANDARD FOUNDATION PIN CONN

* NOTE CONN USED FOR SHEAR ONLY - NO TENSION

→ RED FND THREADED

$$\phi V_n = 0.75(0.31 \text{ in}^2)(0.88)(36 \text{ ksi})$$

$$\phi V_n = 7.36 \text{ k}$$

2"


1/2" THRU HOLE
IN SLAB BASE

3/4"

5/8" 1/2" ALL THREAD
SET & GROUTED W/
NO-SHrink FORT

7/8"

3/4" 1/2" HOLE DRILLED
IN FIELD AFTER SETTING



$$\phi V_n = 0.75(.44)(.88)(36)$$

$$\phi V_n = 10.45 \text{ kips}$$

When Epoxy is used in both holes to provide tension capacity:
 $\phi T_n = 14.9 \text{ kips}$ (AISC Table 7-2, A307)



AUG 29 2016

Project: EASTHAM	Job # 15091
Subject: CAWN	Sheet # 1 of 1
Calc by: JBC	Chk by:
	Date: 11/5/15

17375 Crookes Farm Road — Rixeyville, Virginia 22737 — T: 540.212.3900 — W: <http://www.pmceng.us>

ROOF TO WALL CAWN

* USED FOR LATERAL CAWN TO ROOF ↗
 * TO BRACE TOP OF WALL ←

** CAPACITY COMPUTED/VERIFY BASED ON CORNER CAWN WHICH IS WEAKEST

ROOF R (PER SPUD OUTPUT)

ϕV_n EITHER DIRECTION
 = 8.3k

WELD $\phi R_n = 0.75(0.6)(70ks)(\frac{3}{16})(3")$
 $\phi R_n = 12.53k$

WALL EMBEDD (PER SPUD OUTPUT)

← $\phi T_n = 4.3k$

↗ $\phi V_n = 3.0k$

FLXURE




$\phi M_n = 0.9(36ksi)(A)(\frac{3}{8})^2/4 = 4.5k$

$\phi M_n = \phi P_n (d)$ SOLVE FOR ϕP_n


$\phi P_n = 4.5k / 2.25' = 2.03k$ max

SHEAR

$\phi V_n = 0.9(0.6)(36ksi)(\frac{3}{8})(4')$
 $V_n = 29.2k$



SHEAR WELD



CONTROLS CAPACITY IN SHEAR




AUG 29 2016

CONTROLS OUT OF PLANE
 SHEAR CAPACITY

0
3
6
9
12
15
18
21
24
27
30
33
36
39
42
45
48
51
54
57
60
63
66
69
72
75
78
81
84
87
90
93
96
99
102
105
108

----- **DESIGN DATA** -----

Design : PCI Design Handbook, 6th Ed.
 Criteria
 H.A.S. : Type = 1/2 X 2
 Properties $d_s = 0.500$ in $d_h = 1.000$ in
 $l_e = 1.688$ in $A_s = 0.196$ in²
 $f_y = 50.0$ ksi $f_u = 60.0$ ksi
 Plate Thk = 0.375 in
 No. of : X-rows = 3 Y-rows = 3
 Studs Total = 9
 Edge dist. : $d_{e1} = 10.000$ in $d_{e3} = 10.000$ in
 Stud Spac'g $X_1 = 1.000$ in $Y_1 = 1.000$ in
 $X_2 = 1.000$ in $Y_2 = 1.000$ in
 $d_{e2} = 100.000$ in $d_{e4} = 100.000$ in
 Fig. 6.5.4.2, PCI Hdbk (6th Ed) Case = 1
 Y-rows included in group pullout = 1
 Load $e_{nx} = 0.00$ in $e_{ny} = 0.00$ in
 Eccentr'y $e_{vx} = 0.00$ in
 Concrete Member Thickness = 6.00 in
 Material : $f'_c = 5.00$ ksi $\lambda = 1.00$
 Properties Concrete = Normal Wt.
 ϕ factors : Tension: $\phi_s = 0.75$ $\phi_c = 0.70$
 Shear : $\phi_s = 0.65$ $\phi_c = 0.70$
 Pullout / Pryout : $\phi_p = 0.70$



Tension/Shear Modifiers : No Cracking at service load level (Fig 6.5.5.2)
 NO Supplementary Reinf. for Tension or Shear Loads (§ 6.2.1.3)

----- **OUTPUT** -----

A) Tension capacity for group of 3 studs; $\phi_s = 0.75$; $\phi_c = 0.70$

Steel Stud Strength : $\phi N_s = 0.75 * 35.34 = 26.5$ k (Eq 6.5.2.1)
 Concrete Breakout Strength (1) : $\phi N_{cb} = 0.70 * 7.68 = 5.4$ k (Eq 6.5.4.1)
 Concrete Pullout Strength (2) : $\phi N_{pnq} = 0.70 * 98.96 = 69.3$ k (Eq 6.5.4.5*)
 Concrete Side Face Blowout (3) : ϕN_{sb} (Not Calculated) (Eq 6.5.4.6)

Group tensile strength based on:

- (1) Projected Surface Area, $A_N = 45.43$ in² (Fig 6.5.4.1)
 Modifiers : $C_{bs} = 169.142$ (Eq 6.5.4.2) $C_{crb} = 1.000$ (p 6-14)
 $\psi_{ed} = 1.000$ (Eq 6.5.4.3) $\psi_{ec} = 1.000$ (Eq 6.5.4.4)
- (2) Modifier : $C_{crp} = 1.000$ (p 6-17)
- (*) No equation is given for pullout of a group. We use $n_g * N_{pn}$
 where n_g is the number of studs in the group.
- (3) All edge distances $> 0.4 * h_{ef}$ (§ 6.5.4.3)

B) Shear capacity for group of 9 studs; $\phi_s = 0.65$; $\phi_c = 0.70$

Steel Stud Strength : $\phi V_s = 0.65 * 106.03 = 68.9$ k (Eq 6.5.2.1)
 Concrete Front Edge Breakout (1) : $\phi V_{c3} = 0.70 * 11.80 = 8.3$ k (Eq 6.5.5.1)
 Concrete Side Edge Breakout (2) : ϕV_{c1} (Not Calculated) (Eq 6.5.5.12)
 Concrete Pryout Strength (3) : $\phi V_{cp} = 0.70 * 22.45 = 15.7$ k (Eq 6.5.7.1)

Group shear strength based on:

- (1) One fastener in concrete $V_{co3} = 31.8$ k (Eq 6.5.5.2)
 Note: This is a Corner condition
 Modifiers : $C_{n3} = 0.530$ (Eq 6.5.5.5) $C_{rc2} = 1.000$ (Fig 6.5.5.11)
 $C_{e3} = 1.000$ (Eq 6.5.5.6) $C_{c3} = 0.700$ (Eq 6.5.5.11)
- (2) Both SED $> 0.2 * BED$ (Eq 6.5.5.11)
- (3) Modifier : $\psi_y = 1.000$ (§ 6.5.7)




C) Tension and shear for stud groups

Tension : $\phi N_n = 5.4$ k, group of 3
Shear : $\phi V_n = 8.3$ k, group of 9



----- **DESIGN DATA** -----

Design : PCI Design Handbook, 6th Ed.
 Criteria
 H.A.S. : Type = 1/2 X 2
 Properties $d_s = 0.500$ in $d_h = 1.000$ in
 $l_e = 1.688$ in $A_s = 0.196$ in²
 $f_y = 50.0$ ksi $f_u = 60.0$ ksi
 Plate Thk = 0.375 in
 No. of : X-rows = 3 Y-rows = 3
 Studs Total = 9
 Edge dist. : $d_{e1} = 2.000$ in $d_{e3} = 3.000$ in
 Stud Spac'g $X_1 = 1.000$ in $Y_1 = 1.000$ in
 $X_2 = 1.000$ in $Y_2 = 1.000$ in
 $d_{e2} = 100.000$ in $d_{e4} = 100.000$ in
 Fig. 6.5.4.2, PCI Hdbk (6th Ed) Case = 2
 Y-rows included in group pullout = 1
 Load $e_{nx} = 0.00$ in $e_{ny} = 0.00$ in
 Eccentr'y $e_{vx} = 0.00$ in
 Concrete Member Thickness = 4.00 in
 Material : $f'_c = 5.00$ ksi $\lambda = 1.00$
 Properties Concrete = Normal Wt.
 ϕ factors : Tension: $\phi_s = 0.75$ $\phi_c = 0.70$
 Shear : $\phi_s = 0.65$ $\phi_c = 0.70$
 Pullout / Pryout : $\phi_p = 0.70$



Tension/Shear Modifiers : No Cracking at service load level (Fig 6.5.5.2)
 NO Supplementary Reinf. for Tension or Shear Loads (§ 6.2.1.3)


----- **OUTPUT** -----

A) Tension capacity for group of 3 studs; $\phi_s = 0.75$; $\phi_c = 0.70$
 Steel Stud Strength : $\phi N_s = 0.75 * 35.34 = 26.5$ k (Eq 6.5.2.1)
 Concrete Breakout Strength (1) : $\phi N_{cb} = 0.70 * 6.16 = 4.3$ k (Eq 6.5.4.1)
 Concrete Pullout Strength (2) : $\phi N_{pn} = 0.70 * 98.96 = 69.3$ k (Eq 6.5.4.5*)
 Concrete Side Face Blowout (3) : ϕN_{sb} (Not Calculated) (Eq 6.5.4.6)

Group tensile strength based on:
 (1) Projected Surface Area, $A_N = 40.16$ in² (Fig 6.5.4.1)
 Modifiers : $C_{bs} = 169.142$ (Eq 6.5.4.2) $C_{crb} = 1.000$ (p 6-14)
 $\psi_{ed} = 0.906$ (Eq 6.5.4.3) $\psi_{ec} = 1.000$ (Eq 6.5.4.4)
 (2) Modifier : $C_{crp} = 1.000$ (p 6-17)
 (*) No equation is given for pullout of a group. We use $n_g * N_{pn}$
 where n_g is the number of studs in the group.
 (3) All edge distances $> 0.4 * h_{ef}$ (§ 6.5.4.3)


B) Shear capacity for group of 9 studs; $\phi_s = 0.65$; $\phi_c = 0.70$
 Steel Stud Strength : $\phi V_s = 0.65 * 106.03 = 68.9$ k (Eq 6.5.2.1)
 Concrete Front Edge Breakout (1) : $\phi V_{c3} = 0.70 * 4.33 = 3.0$ k (Eq 6.5.5.1)
 Concrete Side Edge Breakout (2) : ϕV_{c1} (Not Calculated) (Eq 6.5.5.12)
 Concrete Pryout Strength (3) : $\phi V_{cp} = 0.70 * 22.45 = 15.7$ k (Eq 6.5.7.1)

Group shear strength based on:
 (1) One fastener in concrete $V_{c03} = 9.9$ k (Eq 6.5.5.2)
 Note: This is a Corner condition
 Modifiers : $C_{n3} = 0.671$ (Eq 6.5.5.5) $C_{vcr} = 1.000$ (Fig 6.5.5.2)
 $C_{ev3} = 1.000$ (Eq 6.5.5.6) $C_{c3} = 0.650$ (Eq 6.5.5.11)
 (2) Both SED $> 0.2 * BED$ (Eq 6.5.5.11)
 (3) Modifier : $\psi_\gamma = 1.000$ (§ 6.5.7)



C) Tension and shear for stud groups

Tension : $\phi N_n =$ 4.3 k, group of 3
Shear : $\phi V_n =$ 3.0 k, group of 9



CALCULATION

Archon Weld Calculator Program


d = 4 (in)
b = 3 (in)

Ultimate Stress = 37.8 (ksi)

LOADS:

FY = 18.2 (kips) MX = 54.6 (in-kips) MZ = 38.22 (in-kips)

Actual Weld Size = 3/16 (in)
Min. Weld for Stress = 0.188 (in)




Project: UNITL	Job # 16065
Subject: MISC. DESIGN	Sheet # 1 of
Calc by: JBC	Chk by: Date: 6/20/16

17375 Crookes Farm Road — Rixeyville, Virginia 22737 — T: 540.212.3900 — W: <http://www.pmceng.us>

FLOOR SLAB DESIGN

THIN SLAB SPAN




CHECK TYPICAL 12' WIDE SECTION

$$b = 12", d = 2" A_s = 0.20 in^2 \text{ (}\frac{1}{4} - \frac{OS}{OS}\text{)}$$

PER CONC WORKSHEET OK w/ JUST REBAR

LOAD SPAN



$W =$

$$DL = \left(\frac{5.93}{12}\right) (150) (10') = 741 \text{ pcf}$$

$$U = 150 \text{ pcf (10')} = 1500 \text{ pcf}$$

FROM ACI $M_u, \text{max} = 108 \text{ K}' \text{ @ TOP}$

$M_u, \text{max} = 87 \text{ K}' \text{ @ BOT}$

TOP TEN w/ $\frac{1}{4} - \frac{OS}{OS}$ $A_s = (0.20) (9.5') =$

$d = 6"$

$b = 4(10") = 40" \text{ (i.e. REB WORK)}$

$\phi M_u = 581 \text{ K}' \text{ de} \checkmark$

DOT TEN w/ 2) #7

$A_s = (4) (2) (0.60 in^2) = 4.8 in^2$

$d = 6"$

$b = 120"$

$\phi M_u = 1482 \text{ K}' \text{ de} \checkmark$



* * * FOR TRANSVERSE REINFORCEMENT @ 1/2' PITCH TO MINIMIZE CRACKING



17375 Crookes Farm Road
 Leesville, VA 22737
 T 540 212 3900
<http://www.apmceng.us>

Engineering & Detailing

Simple Flexural Design

$W_{dl} = 0.050$ klf

$W_{liv} = 0.1500$ klf

$W_{snow} = 0.000$ klf

$W_u = 0.300$ klf

length = 2.167 ft

$\phi_{flex} = 0.9$

$\phi_{shear} = 0.75$

$b = 12$ in

$d = 2$ in

$h = 4$ in

$W_{conc} = 120$ pcf

$f'_c = 5000$ psi

$f_y, flex = 60000$ psi

$A_s = 0.200$ in²

$M_u = 0.18$ kip-ft

$R_u = 0.325$ kips

Simple Shear Design

$V_u = 0.275$ kips

$A_s = 0.15$ in²/ft

$f_y, shear = 80000$ psi

PROJECT	Unitil Reg Bldg	JOB NO:	16065
SUBJECT:	Floor Design	SHEET NO.	1 OF 1
CALCULATED BY:	JBC	DATE:	20-Jun-16

(9-1) = 0.07 (10-3)
 (9-2) = 0.3 (200bwd/fy)
 (9-3) = 0.135

530.3 psi
 0.08 3067403 psi
 0.08 64 in⁴
 200 plf

Design OK

$f_r =$
 $E =$
 $I_g =$
 $W_s =$

<----Does not crack

#/ft
 beta1 = 0.800

OK

$V_c = 3394$
 $V_s = 2000$

No V-reinf Req'd

$\phi V_c/2 = 1.27$ kips
 $A_{v,min} = 0.095$ in²/ft
 (not less than) 0.090 in²/ft
 $\phi V_n = 4.0$ kips

Shear OK



AUG 29 2016

IECS
 Unitil Reg Building Floor slab
 Bcan, 3.0.03, (C)2005 SALMONS TECHNOLOGIES, INC.

SHEET OF
 DATE: 6/20/2016
 PAGE: 1 BY: JBC

 INPUT DATA

E= 100 ksi No. of Jts.= 4 No. of Elements= 3

 Element Data

 Joint Data


Element #	I (in ⁴)	Joint #	X (ft)	Joint Restraint
1	100	1	0.00	PINNED
2	100	2	9.33	PINNED
3	100	3	18.67	PINNED
		4	28.00	PINNED

 Load Case Description

Load Case	Description
1	Dead Load
2	Live Load

 Distributed Loads

Load Case	W1 (k/ft)	W2 (k/ft)	X1 (ft)	X2 (ft)
1	0.741	0.741	0.00	28.00
2	1.500	1.500	0.00	28.00



 LOAD COMBINATION 1 1.4DL


Combined Loads = 1.400 * LC 1

Joint Reactions and Displacements

Joint #	X (ft)	Rx (k)	Ry (k)	Mz (k-in)	Y-disp. (in)	Rotat. (rad)
1	0.00	0.00	-3.87	0	0.0000	0.303120
2	9.33	0.00	-10.65	0	0.0000	-0.100714
3	18.67	0.00	-10.65	0	0.0000	0.100714
4	28.00	0.00	-3.87	0	0.0000	-0.303120

Element Forces and Displacements

Ele. #	X (ft)	Axial Force (k)	Shear Force (k)	Moment (k-in)	Y-displ. (in)
1	0.00	0.00	-3.87	-0	0.0000
1	1.87	0.00	-1.93	-65	6.1537
1	3.73	0.00	0.00	-87	9.2295
1	5.60	0.00	1.94	-65	8.1418
1	7.46	0.00	3.87	0	3.9782
1	9.33	0.00	5.81	108	0.0000
2	9.33	0.00	-4.84	108	0.0000
2	11.20	0.00	-2.91	22	-0.3509
2	13.07	0.00	-0.97	-22	0.5649
2	14.00	0.00	0.00	-27	0.7306
2	14.93	0.00	0.97	-22	0.5649
2	16.80	0.00	2.91	22	-0.3509
2	18.67	0.00	4.84	108	0.0000
3	18.67	0.00	-5.81	108	0.0000
3	20.54	0.00	-3.87	0	3.9782
3	22.40	0.00	-1.94	-65	8.1418
3	24.27	0.00	-0.00	-87	9.2295
3	26.13	0.00	1.93	-65	6.1537
3	28.00	0.00	3.87	-0	0.0000



 LOAD COMBINATION 2 1.2D+1.6L

Combined Loads = 1.200 * LC 1 + 1.600 * LC 2

Joint Reactions and Displacements

Joint #	X (ft)	Rx (k)	Ry (k)	Mz (k-in)	Y-disp. (in)	Rotat. (rad)
1	0.00	0.00	-12.27	0	0.0000	0.961077
2	9.33	0.00	-33.78	0	0.0000	-0.319327
3	18.67	0.00	-33.78	0	0.0000	0.319327
4	28.00	0.00	-12.27	0	0.0000	-0.961077

Element Forces and Displacements

Ele. #	X (ft)	Axial Force (k)	Shear Force (k)	Moment (k-in)	Y-displ. (in)
1	0.00	0.00	-12.27	-0	0.0000
1	1.87	0.00	-6.13	-206	19.5111
1	3.73	0.00	0.00	-275	29.2633
1	5.60	0.00	6.14	-206	25.8145
1	7.46	0.00	12.28	0	12.6135
1	9.33	0.00	18.42	344	0.0000
2	9.33	0.00	-15.36	344	0.0000
2	11.20	0.00	-9.22	68	-1.1127
2	13.07	0.00	-3.07	-69	1.7912
2	14.00	0.00	0.00	-86	2.3164
2	14.93	0.00	3.07	-69	1.7912
2	16.80	0.00	9.22	68	-1.1127
2	18.67	0.00	15.36	344	0.0000
3	18.67	0.00	-18.42	344	0.0000
3	20.54	0.00	-12.28	0	12.6135
3	22.40	0.00	-6.14	-206	25.8145
3	24.27	0.00	-0.00	-275	29.2633
3	26.13	0.00	6.13	-206	19.5111
3	28.00	0.00	12.27	-0	0.0000



DESIGN DATA

Left Cant. = 0.00 ft Simple Span = 28.00 ft Right Cant. = 0.00 ft
Beam Length = 28.00 ft Loop @ Left = 0.00 ft Loop @ Right = 0.00 ft
Design Bearing Lengths: @ Left = 0.420 ft @ Right = 0.420 ft

Leg Bottom = 10.000 in Flange width=120.000 in Web width = 40.000 in
Leg Top = 10.000 in Flange thick= 3.000 in Tpg. thick = 0.000 in
Stem height = 9.000 in No. of stems= 4.00 Section Type=DOUBLE TEE

Non-Composite : (Based on above section dimensions) Height = 12.000 in
Area = 720.000 in-2 Sb = 1224.00 in-3 St = 2040.00 in-3
I = 9180.00 in-4 Yb = 7.5000 in Yt = 4.5000 in

Miscellaneous : (Governing code is ACI 318-02)

Beam type =NORMAL WT. Topping type=NORMAL WT. Stress Block= RECTANGULAR
Beam weight = 150.00 pcf Topping wt. = 150.00 pcf
Cu = 2.350 eds = 0 E-06 eshu = 650 E-06
Vol/Surf = 2.264 in Rel. humid = 60.00% Strain Curve=PCI Handbook
Beam f'ci = 3.500 ksi Beam f'c = 5.000 ksi Topping f'c = 3.000 ksi
Eci modifier= 1.000 Ec modifier = 1.000 Camber Mult.= 1.000
Shear Options : Depth used = NON-COMP f'c used = BEAM
Allow. Concrete Stress: At Release =0.700f'ci At Final =12.00sqrt f'c
phi Factors: Tension-controlled Flexure = 0.900 Strand Development = 0.750
 Compression-controlled Flexure = 0.650 Shear & Torsion = 0.750
Load Cases: 1) U = 1.40 DL
 2) U = 1.20 DL + 1.60 LL

Prestressing Strands (Strand Type = LOW RELAXATION)

Eff. Pull = 0.700Xfp Strand diam.= 0.5000 in Estrand =28322.44 ksi
Strand fp =270.00 ksi Area ea.str.= 0.1531 in-2 LtMult = 1.000
Str. lev. = 1 # of Strand = 8.00 LdMult = 1.000
Losses: PCI Comm. Report (RATIONAL) Strand Transformed -> NO

Harping Profile:

Description	X(ft) From Left End	Hstr (in)	Eccent. (in)	Area of P/S (in-2)
Left End of Beam-----	0.00	2.00	5.50	1.2248
Right End of Beam-----	28.00	2.00	5.50	1.2248

Mild Steel


Shear : fyv = 60.00 ksi fyh = 60.00 ksi fyl = 60.00 ksi
Flexure : fy = 60.00 ksi fs = 30.00 ksi
Emild = 29000 ksi LdMult = 1.000

Layer	No. of Bars in Layer	Bar Size	Area of Steel(in-2)	Dist. from Bottom of Section (in)	Distance From Left End Beginning (ft)	Ending (ft)
1	8	6	3.520	2.00	0.00	28.00
2	4	4	0.800	8.50	0.00	28.00
3	--	--	1.930 (*)	8.50	0.00	28.00

NOTE: Mild steel transformed for section props and used in design moment
(*) Assumed fully developed at ends (mesh or hooked bars)

Distributed Loads (non-factored)

Load Type	Magnitude of Load		Distance From Left		Eccen (in)
	Beginning (k/ft)	Ending (k/ft)	Beginning (ft)	Ending (ft)	



P/C Self Weight	0.750	0.750	0.00	12.00	0.000
P/C Self Weight	0.600	0.600	12.00	16.00	0.000
P/C Self Weight	0.750	0.750	16.00	28.00	0.000
Non-comp. Dead Load	0.050	0.050	0.00	28.00	0.000
Composite Dead Load	0.000	0.000	0.00	28.00	0.000
Live Load	0.800	0.800	0.00	28.00	0.000

At Release Only: Suction = 0.000 k/ft Core Material = 0.000 k/ft

NOTE: 10.00% of all distributed and concentrated live loads are sustained.

Openings in Flanges

Location of Opening	- Distance From Left End - Start of Opening (ft)	End of Opening (ft)	Width at Start (in)	Width at End (in)
TOP FLANGE	12.00	16.00	48.000	48.000

Section Properties at Openings

X(ft) From Left End	Height (in)	Area (in-2)	Yb (in)	Sb (in-3)	Hc (in)	Ac (in-2)	Ybc (in)	Sbc (in-3)
12.00	12.00	576.00	6.75	1104.0	12.00	576.00	6.75	1104.0
16.00	12.00	576.00	6.75	1104.0	12.00	576.00	6.75	1104.0


Bearing Plates

Nu = 0.20*Pu Height= 0.00 in Bearing Pad Thickness = 0.250 in
 Eff. Brg. Surface: Width = 0.00 in Length = 0.000 in
 Plate Rebar: Angle = 10.00 deg fy = 60.00 ksi
 Confinement for non-debonded prestressing strand assumed -> NO

***** OUTPUT *****

FINAL STRESSES (psi)

X(ft) From Left End	FP + BM		FP + DL + Sustained LL			FP + DL + All LL		
	Top	Bot	Tpg	Top	Bot	Tpg	Top	Bot
0.00	0	0	---	0	0	---	0	0
1.40	-92	611	---	-79	589	---	-2	464
2.80	-106	847	---	-80	806	---	63	576
4.20	-49	763	---	-12	704	---	192	379
5.60	0	690	---	47	617	---	302	209
7.00	42	630	---	96	543	---	396	65
8.40	75	581	---	136	484	---	472	-51
9.80	101	543	---	166	438	---	530	-141
11.20	118	517	---	188	407	---	572	-205
12.60	234	467	---	336	341	---	901	-341
14.00	238	462	---	341	334	---	912	-341
15.40	234	467	---	336	341	---	901	-341
16.80	118	517	---	188	407	---	572	-205
18.20	101	543	---	166	438	---	530	-141
19.60	75	581	---	136	484	---	472	-51
21.00	42	630	---	96	543	---	396	65
22.40	0	690	---	47	617	---	302	209
23.80	-49	763	---	-12	704	---	192	379
25.20	-106	847	---	-80	806	---	63	576



26.60	-92	611	---	-79	589	---	-2	464
28.00	0	-0	---	0	-0	---	0	-0

NOTE: Allowable precast tensile stress = $12.0 \cdot \sqrt{f'c}$ = -849 psi

ULTIMATE MOMENT: (k-in)

X(ft) From Left End	Required Mu		Provided phi*Mn		
	by Fact'd Loads	by 1.2*Mcr (ACI 18.8.2)	by Strain- compat.	by Other Limits (see notes)	Flex. phi Factor (ACI 9.3.2)
0.00	0			0 (3)	0.75
1.40	494 {2}			914 (3)	0.75
2.80	936 {2}			3476 (1)	0.75
4.20	1325 {2}			3831 (1)	0.75
5.60	1662 {2}			4052 (1)	0.75
7.00	1945 {2}		4931		0.90
8.40	2176 {2}		4931		0.90
9.80	2355 {2}		4931		0.90
11.20	2480 {2}		4932		0.90
12.60	2554 {2}		4526		0.90
14.00	2578 {2}	2359	4526		0.90
15.40	2554 {2}		4526		0.90
16.80	2480 {2}		4932		0.90
18.20	2355 {2}		4931		0.90
19.60	2176 {2}		4931		0.90
21.00	1945 {2}		4931		0.90
22.40	1662 {2}			4052 (1)	0.75
23.80	1325 {2}			3831 (1)	0.75
25.20	936 {2}			3476 (1)	0.75
26.60	494 {2}			914 (3)	0.75
28.00	0			0 (3)	0.75


{n}: Load Case {n} controls.

(1): Development length controlled by strand.

(3): Development length controlled by both strand and rebar.

VERTICAL SHEAR REINFORCING

X(ft) From Left End	D in.	Vu kips	Tu k-in	Vci kips	Vcw kips	-- Required Reinforcing --		
						for Avci in-2/ft	for Avcw in-2/ft	for Avmin in-2/ft
0.21	10.00	29.88	0.0	269	102	0.000	0.000	0.000
0.50	10.00	29.88	0.0	157	107	0.000	0.000	0.000
1.40	10.00	27.86	0.0	100	121	0.000	0.000	0.000
2.80	10.00	24.73	0.0	68	132	0.000	0.000	0.000
4.20	10.00	21.59	0.0	49	132	0.000	0.000	0.000
5.60	10.00	18.45	0.0	48	133	0.000	0.000	0.000
7.00	10.00	15.32	0.0	48	133	0.000	0.000	0.000
8.40	10.00	12.18	0.0	48	133	0.000	0.000	0.000
9.80	10.00	9.05	0.0	48	133	0.000	0.000	0.000
11.20	10.00	5.91	0.0	48	133	0.000	0.000	0.000
12.60	10.00	2.88	0.0	48	142	0.000	0.000	0.000
14.00	10.00	0.00	0.0	48	142	0.000	0.000	0.000
15.40	10.00	-2.88	0.0	48	142	0.000	0.000	0.000
16.80	10.00	-5.91	0.0	48	133	0.000	0.000	0.000
18.20	10.00	-9.05	0.0	48	133	0.000	0.000	0.000
19.60	10.00	-12.18	0.0	48	133	0.000	0.000	0.000



21.00	10.00	-15.32	0.0	48	133	0.000	0.000	0.000
22.40	10.00	-18.45	0.0	48	133	0.000	0.000	0.000
23.80	10.00	-21.59	0.0	49	132	0.000	0.000	0.000
25.20	10.00	-24.73	0.0	68	132	0.000	0.000	0.000
26.60	10.00	-27.86	0.0	100	121	0.000	0.000	0.000
27.50	10.00	-29.88	0.0	157	107	0.000	0.000	0.000
27.79	10.00	-29.88	0.0	269	102	0.000	0.000	0.000

: Minimum based on ACI Eq. 11-13. (prestress < 40% tensile strength)
 (2) : Minimum based on ACI Eq. 11-14. (prestress > 40% tensile strength)
 NOTE: Avmin not required for $\phi \cdot V_c > V_u > \phi \cdot V_c / 2$ (ACI 11.5.5.1(c)).
 NOTE: Req'd. reinf. is based on a total web width = 40.000 in.
 NOTE: No significant torsion was found (ACI 11.6.1).
 NOTE: Design assumes web reinforcing is carried as close to compression and tension surfaces as possible per ACI 12.13.1.

SUMMARY OF MINIMUM VERTICAL AND LONGITUDINAL WEB REINFORCEMENT REQUIREMENTS

NOTE: The specified section type does not have a bottom ledge.
 For Vertical Reinf, select from columns (1), (2), (3) or (4) : (in-2/ft)
 For Longitudinal Reinf, select from columns (A) or (B) : (in-2)

X(ft)	From	Ph	(1)	(2)	(3)	(4)	(A)	(B)
Left	End	in	Ash	Av/2+At	Av/2+Ash	Av/2+Awv	Al/2	Awl
0.21	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
0.50	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
1.40	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
2.80	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
4.20	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
5.60	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
7.00	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
8.40	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
9.80	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
11.20	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
12.60	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
14.00	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
15.40	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
16.80	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
18.20	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
19.60	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
21.00	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
22.40	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
23.80	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
25.20	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
26.60	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
27.50	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000
27.79	0.0	<3>	0.000	<3>	0.000	0.000	0.000	0.000



AUG 29 2016

Awv=Awl= 0.000(left), 0.000(right)=Vertical and longitudinal web reinf. for bending due to torsional equil. reactions (ledge face,in-2), based on:
 Tu = 0.0 k-in at Left End, = 0.0 k-in at Right End
 ds = 18.000 in Hs = 9.600 in

Ash=Hanger reinforcement (ledge face only).

NOTE: The above values for steel are for one face only. Columns (2) & (A) should be applied to both faces. All other columns need only be applied to the ledge face.

<3>NOTE: Section does not have a ledge, or is defined as a General Section.

PREDICTED DEFLECTIONS

Based on : Rational approach and PCI Committee Recommendations for losses.

$f'_{ci} = 3.500$ ksi, $f'_c = 5.000$ ksi and ACI-209

$E_{ci} = 3587$ ksi, $E_c = 4287$ ksi, Camber Mult.= 1.000

Modified : $C_u = 1.812$ $e_{shu} = 476 E-06$

NOTE: Negative values indicate camber.


	Midspan Position (in)
Release : PS(-0.50)+BM DL(0.31)	-0.20
Creep Before Erection	-0.12
Erection: PS+BM DL (@ 4 weeks)	-0.32
Change Due to Non-Comp.DL	0.02
: PS+BM DL+Non-Comp.DL	-0.30
Change Due to Comp.DL+SustLL	0.03
: PS+All DL+Sust.LL	-0.27
Long Term Creep	-0.06
Final : PS+All DL+Sust.LL	-0.33
: PS+All DL+LL	-0.08



Project: UNTEL	Job # 16065
Subject: DIAPHRAGM DESIGN	Sheet # 1 of 1
Calc by: JBC	Chk by: Date: 6/20/16

17375 Crookes Farm Road — Rixeyville, Virginia 22737 — T: 540.212.3900 — W: <http://www.pmceng.us>

DIAPHRAGM DESIGN




LATERAL LOAD

$$w_u = 48.2^k / 50' = 0.964 \text{ k/ft (SEISMIC)}$$

$$M_u = 0.964 \text{ k/ft} (50')^2 / 8 = 301 \text{ k-ft}$$

$$T_u = 301 \text{ k-ft} / 20' = 15.06^k$$

$$\phi T_n = 0.9 (0.1531 \text{ in}^2 \times 270 \text{ ksi}) = 37.2^k > T_u \text{ ok}$$



0
3
6
9
12
15
18
21
24
27
30
33
36
39
42
45
48
51
54
57
60
63
66
69
72
75
78
81
84
87
90
93
96
99
102
105
108

0 3 6 9 12 15 18 21 24 27 30 33 36 39 42 45 48 51 54 57 60 63 66 69 72 75 78 81 84 87 90 93



Interior Lighting Compliance Certificate

Project Information

Energy Code: 2015 IECC
 Project Title: Unitil Regulator Building
 Project Type: New Construction

Construction Site: Portland, ME Owner/Agent: Designer/Contractor:

Additional Efficiency Package

On-site Renewable Energy

Allowed Interior Lighting Power

A Area Category	B Floor Area (ft ²)	C Allowed Watts / ft ²	D Allowed Watts (B X C)
1-Common Space Types:Workshop	1400	1.59	2226
Total Allowed Watts =			2226

Proposed Interior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
1-Common Space Types:Workshop				
HID 1: Exterior: High-Pressure Sodium: Standard:	2	10	36	360
Total Proposed Watts =				360

Interior Lighting PASSES: Design 84% better than code

Interior Lighting Compliance Statement

Compliance Statement: The proposed interior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed interior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.0.2.0 and to comply with the mandatory requirements listed in the Inspection Checklist.

Jaclyn Reed/Designer

Name - Title

Signature

7/5/16

Date





COMcheck Software Version 4.0.2.0

Exterior Lighting Compliance Certificate

Project Information

Energy Code: 2015 IECC
 Project Title: Unitil Regulator Building
 Project Type: New Construction
 Exterior Lighting Zone: 3 (Other)

Construction Site:
 Portland, ME

Owner/Agent:

Designer/Contractor:

Allowed Exterior Lighting Power

A Area/Surface Category	B Quantity	C Allowed Watts / Unit	D Tradable Wattage	E Allowed Watts (B X C)
Main entry	3 ft of door	30	Yes	90
Other door (not main entry)	3 ft of door	20	Yes	60
Other door (not main entry)	6 ft of door	20	Yes	120
Other door (not main entry)	6 ft of door	20	Yes	120
Total Tradable Watts (a) =				390
Total Allowed Watts =				390
Total Allowed Supplemental Watts (b) =				750

(a) Wattage tradeoffs are only allowed between tradable areas/surfaces.

(b) A supplemental allowance equal to 750 watts may be applied toward compliance of both non-tradable and tradable areas/surfaces.

Proposed Exterior Lighting Power

A Fixture ID : Description / Lamp / Wattage Per Lamp / Ballast	B Lamps/ Fixture	C # of Fixtures	D Fixture Watt.	E (C X D)
<u>Main entry (3 ft of door width): Tradable Wattage</u>				
LED 1: Exterior: Other:	1	1	21	21
<u>Other door (not main entry) (3 ft of door width): Tradable Wattage</u>				
LED 1: Exterior: Other:	1	1	21	21
<u>Other door (not main entry) (6 ft of door width): Tradable Wattage</u>				
LED 1: Exterior: Other:	1	1	21	21
LED 1: Exterior: Other:	1	1	21	21
Total Tradable Proposed Watts =				84

Exterior Lighting PASSES: Design 93% better than code

Exterior Lighting Compliance Statement

Compliance Statement: The proposed exterior lighting design represented in this document is consistent with the building plans, specifications, and other calculations submitted with this permit application. The proposed exterior lighting systems have been designed to meet the 2015 IECC requirements in COMcheck Version 4.0.2.0 and to comply with the mandatory requirements listed in the Inspection Checklist.

Jaclyn Reed/Designer

Name - Title

Signature

7/5/16

Date

Project Title: Unitil Regulator Building

Data filename: C:\Users\jaclyn\Documents\1-NH Buildings\9262 Unitil Regulator\3-Engineering & JCP Drawings Page 2 of 8
 TRA (3rd Party)\9262 Unitil ComCheck.cck





COMcheck Software Version 4.0.2.0

Inspection Checklist

Energy Code: 2015 IECC

Requirements: 0.0% were addressed directly in the COMcheck software

Text in the "Comments/Assumptions" column is provided by the user in the COMcheck Requirements screen. For each requirement, the user certifies that a code requirement will be met and how that is documented, or that an exception is being claimed. Where compliance is itemized in a separate table, a reference to that table is provided.

Section # & Req.ID	Plan Review	Complies?	Comments/Assumptions
C103.2 [PR4] ¹	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the interior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include interior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C103.2 [PR8] ¹	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the exterior lighting and electrical systems and equipment and document where exceptions to the standard are claimed. Information provided should include exterior lighting power calculations, wattage of bulbs and ballasts, transformers and control devices.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C406 [PR9] ¹	Plans, specifications, and/or calculations provide all information with which compliance can be determined for the additional energy efficiency package options.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	3 Low Impact (Tier 3)
------------------------	--------------------------	-----------------------

Section # & Req.ID	Footing / Foundation Inspection	Complies?	Comments/Assumptions
C402.2.6 [FO12] ³	Radiant heating systems panels insulated to $\geq R-3.5$ on face opposite space being heated.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Envelope Assemblies table for values.

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	3 Low Impact (Tier 3)
------------------------	--------------------------	-----------------------

Section # & Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
C405.2.1 [EL15] ¹	Lighting controls installed to uniformly reduce the lighting load by at least 50%.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.1 [EL18] ¹	Occupancy sensors installed in required spaces.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.1, C405.2.2, 3 [EL23] ²	Independent lighting controls installed per approved lighting plans and all manual controls readily accessible and visible to occupants.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.2, 1 [EL22] ²	Automatic controls to shut off all building lighting installed in all buildings.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.3 [EL16] ²	Daylight zones provided with individual controls that control the lights independent of general area lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.3, C405.2.3. 1, C405.2.3. 2 [EL20] ¹	Primary sidelighted areas are equipped with required lighting controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.3, C405.2.3. 1, C405.2.3. 3 [EL21] ¹	Enclosed spaces with daylight area under skylights and rooftop monitors are equipped with required lighting controls.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.4 [EL4] ¹	Separate lighting control devices for specific uses installed per approved lighting plans.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.4 [EL8] ¹	Additional interior lighting power allowed for special functions per the approved lighting plans and is automatically controlled and separated from general lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.2.5 [EL25] ^{null}	Automatic lighting controls for exterior lighting installed. Controls will be daylight controlled, set based on business operation time-of-day, or reduce connected lighting > 30%.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.3 [EL6] ¹	Exit signs do not exceed 5 watts per face.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

1 High Impact (Tier 1) 2 Medium Impact (Tier 2) 3 Low Impact (Tier 3)

Section # & Req.ID	Rough-In Electrical Inspection	Complies?	Comments/Assumptions
C405.6, C405.6.1 [EL24] ²	Exterior grounds lighting meets exterior lighting power requirements.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	3 Low Impact (Tier 3)
------------------------	--------------------------	-----------------------

Section # & Req.ID	Final Inspection	Complies?	Comments/Assumptions
C303.3, C408.2.5.2 [F117] ³	Furnished O&M instructions for systems and equipment to the building owner or designated representative.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C405.4.1 [F118] ¹	Interior installed lamp and fixture lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Interior Lighting fixture schedule for values.
C405.5.1 [F119] ¹	Exterior lighting power is consistent with what is shown on the approved lighting plans, demonstrating proposed watts are less than or equal to allowed watts.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	See the Exterior Lighting fixture schedule for values.
C406.5 [F149] ¹	On-site renewable efficiency package. One of the following levels of renewable energy must be satisfied: provide ≥ 1.75 Btu/h, or ≥ 0.50 watts per square foot of conditioned floor area or provide ≥ 3 percent of the energy used within the building for mechanical and service water heating equipment and lighting.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.2.5.1 [F116] ³	Furnished as-built drawings for electric power systems within 90 days of system acceptance.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	
C408.3 [F133] ¹	Lighting systems have been tested to ensure proper calibration, adjustment, programming, and operation.	<input type="checkbox"/> Complies <input type="checkbox"/> Does Not <input type="checkbox"/> Not Observable <input type="checkbox"/> Not Applicable	

Additional Comments/Assumptions:

1 High Impact (Tier 1)	2 Medium Impact (Tier 2)	3 Low Impact (Tier 3)
------------------------	--------------------------	-----------------------

