Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/03/16

Fire Department Check List

1. **Applicant:**

   Joel Kittredge, Maine Dept Of Transportation
   16 State House Station
   Augusta, ME 04333-0015
   207-624-3550

   Matt Doughty, Unitil
   376 Riverside Industrial Parkway
   Portland, ME 04103
   207-541-2579

2. **Architect:**
   Not Applicable

3. **Proposed Use of Structure:**
   Gas Regulator Building and Data Acquisition Building (no IBC classification as neither will be occupied)

4. **Square footage of structures:**
   Regulator Building: 1400 sf (single story)
   Data Acquisition Building: 120 sf (single story)

5. **Elevation of all structures:**
   All structures will be constructed at an elevation at least 2 feet above the 100 year flood line.

6. **Proposed fire protection of all structures:**
   See Section 15

7. **Hydrant locations:**
   See Section 15

8. **Water main size and location:**
   Existing 12" water line in West Commercial/Commercial Street

9. **Access to all structures:**
   The size of the access gates has been increased as requested to 16' wide to accommodate fire equipment.

10. **Code summary:**
    Previously submitted for the site, See Section 15