Reviewed for Code Compliance
Inspector of Buildings
Authorized Signature
Date: 08/03/16

INTERIOR DAC BUILDING ELEVATION

SCALE: 1/2" = 1'-0"

*SUITABLE MATERIAL SHALL BE CLEAN, CONTAIN NO STONES GREATER THAN 4" IN ANY DIMENSION, NO FROZEN LUMPS, AND ONLY MINOR AMOUNTS OF CLAY, COMPACTION SHALL OCCUR AS INDICATED IN THE SPECIFICATIONS.

TYPICAL TRENCH DETAIL

SCALE: NTS

*REFER TO TYPICAL TRENCH DETAIL

TYPICAL ENLARGED TRENCH DETAIL
(NON ENCASED)

SCALE: NTS

ISSUED FOR BID

REV	BY	DATE	DESCRIPTION	DWG NO.	REFERENCE DRAWINGS	SEAL AND SIGNATURE

PRJ MANAGER: MARK D. WOOD		
PRJ ENGINEER: MARK D. WOOD		
PRJ NAME: WEST COMMERCIAL STREET		
PRJ NUMBER: 5183		
PRJ MILESTONE: ISSUED FOR BID		
PRJ PHASE: ISSUED FOR BID		
DESIGNED BY:	MDW	05/20/16
DRAFTED BY:	RPG	05/20/16
CHECKED BY:	SMR	05/20/16
APPROVED BY:	MDW	05/20/16

CLIENT INFORMATION: Unitil, ME GAS OPERATIONS

DESIGN MANAGER: TIM BICKFORD
DESIGN ENGINEER: BOB SCHUMMRICK
AUTH NO: 6039 167616
REVIEWED BY:
CHECKED BY:
APPROVED BY:

SHEET TITLE: ELECTRICAL ONE-LINE DIAGRAM & TRENCH DETAILS

PROJECT NAME: WEST COMMERCIAL STREET REGULATOR STATION

PROJECT LOCATION: PORTLAND, ME 04101

PROCESS PIPELINE SERVICES
1600 Providence Highway
Walpole, MA 02081
781.829.0524
processpipelineservices.com

FILE NAME: 5183_E00.DWG
PLOT DATE: 05/25/2016 2:57 PM
SCALE: N/A

SIZE	SHEET	REV
22X34	E02	F

SHEET 26 OF 35