Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/03/14

FUTURE MEZZANINE COLUMN REACTIONS:

25'-0"/25'-0" SPACING:
$R_V = 135.1^K$
$R_H = 0.0^K$
$R_{UP} = 0.0^K$

34'-0"/16'-0" SPACING:
$R_V = 150.5^K$
$R_H = 0.0^K$
$R_{UP} = 0.0^K$

STATE OF MAINE
STEPHEN JON REIFENBERG
NO. 4763
LICENSED
PROFESSIONAL ENGINEER

9/15/14

NOTES:
1. FINISHED FLOOR ELEVATION: 100'-0"
2. UNLESS NOTED BASE PLATE ELEVATION = 100'-1"

O Dia= 5/8"
⊠ Dia= 3/4"
⊕ Dia= 1"

ERECTION REQUIRES MINOR ADJUSTMENTS

ESSEX STRUCTURAL STEEL CO., INC.
CORTLAND, NEW YORK 13045

REVISIONS
REV. A, 7/7/2014, JCK: SPACING & COLUMN ORIENTATION LINE 7-A,L,M ADDED MEZZ. COL'S, FUTURE COL'S REACTIONS & ELEVATIONS
REV. B, 7/14/2014, JCK: SPACING @ LINE 1 C-I, A-7, J-7. ADDED LINE 6.1
REV. C, 7/22/2014, JCK: ELEVATIONS
REV. D, 8/11/2014, JCK: MEZZ. LOC.

PROJECT: CANAL LANDING
100 WEST COMMERCIAL STREET
PORTLAND, MAINE 04101
CONTRACTOR: IRISHSPAN INDUSTRIES
PROJECT NO.: S-1468

TITLE: ANCHOR BOLT LAYOUT

SHEET: 1

DRAWN BY: WPK | DATE: 6/23/14 | SCALE: D.N.S.