Project: New Yard LLC
Date Prepared: 11-15-13

Inspections Division
Date: 11/19/13

Structural Schedule of Special Inspections
SEISMIC RESISTANCE - STRUCTURAL

VERIFICATION AND INSPECTION IBC Section 1707	Y/N	EXTENT: CONTINUOUS, PERIODIC, SUBMITTAL, OR NONE	COMMENTS	AGENT	AGENT QUALIFICATION	TASK COMPLETED
1. Special inspections for seismic resistance. Special inspection as specified in this section is required for the following:			Seismic Design Category: B			
a. The seismic-force-resisting systems in structures assigned to Seismic Design Category C, D, E or F	N	P	IBC 1707.1 1707.2 Exception 1		PE/SE or EIT	
2. Structural steel: Continuous special inspection for structural welding in accordance with AISC 341.	N	P	IBC 1702.2		AWS-CWI	
3. Structural wood:						
a. Continuous special inspection during field gluing operations of elements of the seismic-force-resisting system.	N	C	IBC 1702.3		PE/SE or EIT	
b. Periodic special inspections for nailing, bolting, anchoring and other fastening of components within the seismic-force-resisting system, including drag struts, braces and hold-downs	N	P	IBC 1702.3		PE/SE or EIT	
4. Cold-formed steel framing: Periodic special inspections during welding operations of elements of the seismic-force-resisting system. Periodic special inspections for screw attachment, bolting, anchoring and other fastening of components within the seismic-force-resisting system, including struts, braces, and hold-downs	N	N				
4. Seismic isolation system. Provide periodic special inspection during the fabrication and installation of isolator units and energy dissipation devices if used as part of the seismic isolation system	N	N	IBC 1707.8			

Project: New Yard LLC
Date Prepared: 11-15-13

Inspections Division
Date: 11/19/13

Quality Assurance Plan – Seismic and Wind

QUALITY ASSURANCE FOR SEISMIC RESISTANCE CHECK LIST [IBC 1705]

Seismic Design Category

☐ **FOR SEISMIC DESIGN CATEGORY C OR HIGHER:**

Structural:

☑ The seismic-force-resisting systems
- ☑ Steel Braced Frames and associated connections/anchorage
- ☑ Steel Moment Frames and associated connections
- ☐ Shear walls: ☐ CMU ☐ Wood ☐ Concrete ☐ Diaphragms: ☐ Floor ☐ Roof
- ☐ Other:

QUALITY ASSURANCE FOR WIND RESISTANCE CHECK LIST [IBC 1706]

Wind Exposure Category

REQUIRED	NOT REQUIRED	NOT APPLICABLE	QUALITY ASSURANCE PLAN REQUIREMENTS (A Quality Assurance Plan is required where indicated below)
☐	☐	☐	In wind exposure Categories A and B, where the 3-second-gust basic wind speed is 120 miles per hour (mph) (52.8 *m/sec)* or greater.
☐	☑	☐	In wind exposure Categories C and D, where the 3-second-gust basic wind speed is 110 mph (49 *m/sec)* or greater.

Prepared by:

Duane Moench 11-15-13
Signature Date

Building Code Official's Acceptance:

Signature Date