

CBL: 059 A0080 **Permit ID:** 2013-02298

Additional Comments:

10/10/2013-MES/Zoning:

I need documented height of the building and also the elevation compared to the 65' above mean sea level. I need the first floor elevation shown on the plans too so I can prepare the floodplain forms. I sent an e-mail to Bob.

10/18/2013-MES/Zoning:

on 10/13/2013 I received information from Steve Bushey concerning the average grade and building height and height above sea level. He also submitted signed flood forms. I need to prepare the two part application and first certificate of elevation.

10/22/2013-CPP/Fire:

need NFPA code analysis and life safety plan.

11/5/2013-CPP/Fire:

The NFPA code analysis should include 101 11.9.2 Tensioned-Membrane Structures