
Fwd: LETTER OF COMPLIANCE

1 message

Leslie Oster <leslie@auroraprovisions.com>
To: John Brennan <brennanj@portlandmaine.gov>

Sat, May 20, 2017 at 8:15 AM

Leslie Oster
General Manager
Aurora Provisions

Begin forwarded message:

From: Paul <metalgod213@live.com>
Date: May 20, 2017 at 6:49:16 AM EDT
To: "leslie@auroraprovisions.com" <leslie@auroraprovisions.com>
Subject: LETTER OF COMPLIANCELEBEL'S SHEET METAL
5/20/17

221 LINCOLN ST.

LEWISTON, ME 04240

TEL: 207-782-2235

RE: LETTER OF COMPLIANCE / AURORA PROVISIONS

To whom it may concern:

Lebel's Sheet Metal acknowledges that to the best of our knowledge has performed all work on the installation of a hood system at Aurora Provisions in Portland Maine was done in accordance with NFPA96 Codes for Kitchen Exhaust. Hood is a Captive-Aire complete with lights, filters and a UL Listed Up-blast fan with hinge kit. All duct-work was 16ga. all welded construction and fire wrapped with Fire-master insulation for a zero clearance to combustibles.

Final approval was done during final inspection by City of Portland and Fire Chief.

Please call with any questions regarding this project: 207-576-1863