

Laurie Leader - 381 Spring St

From: ERIK MERCER <erikmerc@mac.com>
To: Laurie Leader <LRL@portlandmaine.gov>
Date: 1/12/2015 1:55 PM
Subject: 381 Spring St

Laurie,

Here is the information you requested:

Per R305 ceiling height, we meet exception 1 (50% or more of there room has ceiling height of 7 feet) and exception 2 (minimum 6'8" in front of all fixtures).

Thanks for your help.

Erik

ERIK MERCER, L.C.S.W.
381 SPRING STREET
PORTLAND, ME 04102
917-992-8825

49 WEST 24TH STREET, SUITE 1006
NEW YORK, NY 10010
917-992-8825