

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

FUNK WILFRED JOHN & DEBORAH F CHASE JTS

Located at

4 ORCHARD ST

PERMIT ID: 2016-00311

ISSUE DATE: 02/24/2016

CBL: 061 E013001

has permission to **Renovations of the kitchen, first floor bathroom and second floor bathroom.**
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
single-family

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing

Electrical - Residential

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-00311	Date Applied For: 02/11/2016	CBL: 061 E013001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Single Family	Proposed Project Description: Renovations of the kitchen, first floor bathroom and second floor bathroom.			
Dept: Historic Status: Approved w/Conditions Reviewer: Robert Wiener Approval Date: 02/24/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Any additional exterior alterations, including windows and doors, lighting, site alterations, etc. must be reviewed and approved prior to commencement of the work. 2) Proposed alterations to rear vestibule door are approved with this permit; specifications or cut sheet for new door are to be forwarded to HP staff. 3) Any new venting to the exterior for kitchen, bathrooms, or other mechanicals must be reviewed and approved prior to installation.				
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 02/12/2016 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. 2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only. 3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 4) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				