



Portland Fire Department Monthly School Inspection

Name: <u>Waynflete Gym</u>	Address: <u>360 Spring St</u>
Principal: <u>Mark Segar</u>	Emergency contact #: <u>207-615-1972</u>
Date inspected: <u>3-30-09</u>	Inspector: <u>Capt. Dyer</u>
	Time in: <u>1515</u> Time out: <u>1530</u>

Fire Drills Conducted Yes No Date of last drill: 3-26-09

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/>	<input checked="" type="checkbox"/>

Notes:

Emergency lights not working

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date


<u>N/A</u>	<input type="checkbox"/>
<u>N/A</u>	<input type="checkbox"/>
<u>N/A</u>	<input type="checkbox"/>

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <i>Wadyville Jc</i>	Address: <i>64 Emery</i>
Principal: <i>Mark Sawyer</i>	Emergency contact #: 555-4445 <i>615-1972</i>
Date inspected: <i>4-1-09</i>	Inspector: <i>TAVE GREG STEWART</i>
	Time in: <i>1000</i> Time out: <i>1033</i>

Fire Drills Conducted Yes No Date of last drill: *007 08*

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Notes:

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Behind Freezer


3-4-09

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Founders Hall

Name: Wayne Flete School	Address: 360 Spring St
Principal: Mark Segar	Emergency contact #: David Brown
Date inspected: 5/21/09	Inspector: Lt Robert Eaton
	Time in: 10:20 Time out: 11:00

Fire Drills Conducted Yes No Date of last drill: _____

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail	Notes:
✓		
✓		

Fire Alarm System

Panel clear, accessible, operational

✓		
---	--	--

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

✓		
✓		

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

✓		
✓		

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

✓		
✓		
✓		

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

✓		
✓		
✓		
✓		

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

✓		
✓		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <i>wynaflete</i>	Address: <i>64 Emery St.</i>
Principal: <i>Lowell Libby</i>	Emergency contact # :

Date inspected: <i>9-14-09</i>	Inspector: <i>Capt. Dyer</i>
Time in: <i>1520</i>	Time out: <i>1555</i>

Fire Drills Conducted Yes No Date of last drill: *Last Spring - Today first day of School*

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exit signs & Emer lights properly lit	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>3rd floor Emergency Lights not working #106, 107, 108</i>

Fire Alarm System

Panel clear, accessible, operational

Fire Extinguishers

Extinguishers full & tagged annually

Extinguishers accessible

Heating System

Boiler room clear of all combustibles

Boiler room properly rated/protected

Electrical system

Extension cord use vs. permanent

Electrical panels clear & accessible

Electrical circuits clearly identified

Sprinkler System

Sprinkler heads >18" of clearance

Sprinkler Rm & FDC labeled & clear

Spare heads & wrench supplied

Sprinkler system tagged insp. date *6-24-09*

House Keeping

Furnishings & decorations flame rest

Art work displayed < 20% wall area

Housekeeping organized for safety

Additional Safety Concerns: