



Portland Fire Department Monthly School Inspection

Name: <u>Wynafete Gym</u>	Address: <u>360 Spring St.</u>
Principal:	Emergency contact #:

Date inspected: <u>3-30-11</u>	Inspector: <u>Capt. Dyer</u>
Time in: <u>1600</u>	Time out:

Fire Drills Conducted Yes No Date of last drill: Oct. 2010

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Notes:

Fire Alarm System

Panel clear, accessible, operational

<input checked="" type="checkbox"/>	<input type="checkbox"/>
-------------------------------------	--------------------------

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	<input type="checkbox"/>

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <i>Waynflete</i>	Address: <i>360 Spring St. - Merrill/Cook/Hyde</i>
Principal:	Emergency contact #:

Date inspected: <i>12-19-11</i>	Inspector: <i>Capt. Dyer</i>
Time in: <i>1530</i>	Time out:

Fire Drills Conducted Yes No Date of last drill: _____

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	✓		
Exit signs & Emer lights properly lit	✓		

Fire Alarm System		
Panel clear, accessible, operational		

Fire Extinguishers		
Extinguishers full & tagged annually	✓	
Extinguishers accessible	✓	

Heating System		
Boiler room clear of all combustibles	✓	
Boiler room properly rated/protected	✓	

Electrical system		
Extension cord use vs. permanent	✓	
Electrical panels clear & accessible	✓	
Electrical circuits clearly identified	✓	

Sprinkler System		
Sprinkler heads >18" of clearance	✓	
Sprinkler Rm & FDC labeled & clear	✓	
Spare heads & wrench supplied	✓	
Sprinkler system tagged insp. date	✓	<i>9-14-11</i>

House Keeping		
Furnishings & decorations flame rest	✓	
Art work displayed < 20% wall area	✓	
Housekeeping organized for safety	✓	

Additional Safety Concerns: