

F7 TYPICAL CONDUIT SPACING
NO SCALE


- OH — OVERHEAD WIRING
- UG --- UNDERGROUND OR UNDERSLAB WIRING
- ⊙ UTILITY POLE
- ⊞ FUSED DISCONNECT SWITCH
- ⊞ NON-FUSED DISCONNECT SWITCH
- ⊙ MOTOR
- ⊞ GROUNDING SYSTEM
- ⊞ JUNCTION BOX, WALL MOUNTED
- ⊞ JUNCTION BOX, IN-GROUND
- ⊞ ELECTRICAL MANHOLE PER UTILITY COMPANY REQUIREMENTS, COORDINATE LOCATION WITH OTHER UNDERGROUND UTILITIES
- ⊞ PADMOUNT TRANSFORMER
- ⊞ 4'X6' PULL BOX WITH 32" COVER PLATE IN ACCORDANCE WITH UTILITY STANDARDS
- ⊞ PEDESTAL LOCATION, PEDESTAL BY SERVICE PROVIDER, STUB UP (2) 2" CONDUITS WITH CONNECTORS AND BUSHINGS FROM HANDHOLE
- ⊞ HANDHOLE, MINIMUM 18"x36"x24". SIZE PER NEC FOR NUMBER OF CONDUITS INSTALLED
- ⊞ METER & CT CABINET, PEDESTAL MOUNTED

A7 **A9** LEGEND
NO SCALE

N:\Projects\2015\15051 - Waynflete School\00 Drawing Files\15051ES.dwg Jan 13, 2017 - 1:24pm



75 York Street,
Portland, Maine 04101
simonsarchitects.com
207.772.4656




160 Veranda Street
Portland, Maine 04103
T: 207.221.2260
F: 207.221.2266
Web: www.allied-eng.com

Allied Project No: 15051
Cad File: 15051ES.dwg

PROJECT NAME:
WAYNFLETE LOWER SCHOOL
ADDITION & RENOVATIONS

WAYNFLETE SCHOOL
360 SPRING STREET
PORTLAND, MAINE 04102



THIS DRAWING IS THE PROPERTY OF SCOTT SIMONS ARCHITECTS (SSA) AND IS NOT TO BE COPIED OR REPRODUCED IN PART OR WHOLE. © 2015 SCOTT SIMONS ARCHITECTS, LLC

REVISION:

NO.	DATE
1	DATE
2	DATE
3	DATE
4	DATE
5	DATE
6	DATE

DATE OF ISSUE: 12 JANUARY 2017
PROJECT NUMBER: 2013-0050
STATUS: ISSUED FOR BID

ELECTRICAL

ES-101