


N:\Projects\2015\15051 - Waynflete School\00 Drawing Files\15051_EP.dwg Jun 11, 2017 12:43pm

PANEL SCHEDULE ~ MDP										
VOLTAGE: 208/120V				MCB: 1000A			AIC: 42KA			
3-PHASE, 4-WIRE										
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION				
CKT NO	BRKR SIZE	NO OF POLES	A	B	C					
1			A	20.43						PANEL L11
3	225	3	B		18.96					
5			C			20.59				
7			A	18.10						PANEL L21
9	225	3	B		19.05					
11			C			18.73				
13			A	41.34						PANEL L31
15	400	3	B		42.43					
17			C			41.27				
19			A	0.00						SPARE
21	400	3	B		0.00					
23			C			0.00				
25			A	0.00						SPARE
27	225	3	B		0.00					
29			C			0.00				
31			A	0.00						SPARE
33	100	3	B		0.00					
35			C			0.00				
37			A	0.00						SPACE
39	100	3	B		0.00					
41			C			0.00				
SUBTOTAL				79.87	80.44	80.59				
2			A	0.00						ELEVATOR
4	125	3	B		0.00					
6			C			0.00				
8			A	0.00						PANEL L12
10	225	3	B		0.00					
12			C			0.00				
14			A	17.83						PANEL L32
16	225	3	B		18.54					
18			C			15.58				
20			A	0.00						SPARE
22	225	3	B		0.00					
24			C			0.00				
26			A	0.00						SPARE
28	100	3	B		0.00					
30			C			0.00				
32			A	0.00						SPACE
34	225	3	B		0.00					
36			C			0.00				
38	100	2	A	0.00						(E) PP3 VIA ATS
40			B		0.00					
42	100	1	C			0.00				SPACE
SUBTOTAL				17.83	18.54	15.58				

PANEL SCHEDULE ~ L12											
VOLTAGE: 208/120V				MLO: 225A			AIC: 14KA				
3-PHASE, 4-WIRE											
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION					
CKT NO	BRKR SIZE	NO OF POLES	A	B	C						
1			A	0.00						PROVIDE BRANCH CIRCUITS AS REQUIRED TO REFEED EXISTING CIRCUITS TO REMAIN THAT WERE FED FROM REMOVED PANELS PP2 AND PP4. PROVIDE 20A, 1P SPARE CIRCUIT BREAKERS AT UNUSED POLE PLACES	
3			B		0.00						
5			C			0.00					
7			A	0.00							
9			B		0.00						
11			C			0.00					
13			A	0.00							
15			B		0.00						
17			C			0.00					
19			A	0.00							
21			B		0.00						
23			C			0.00					
25			A	0.00							
27			B		0.00						
29			C			0.00					
31			A	0.00							
33			B		0.00						
35			C			0.00					
37			A	0.00							
39			B		0.00						
41			C			0.00					
43			A	0.00							
45			B		0.00						
47			C			0.00					
49			A	0.00							
51			B		0.00						
53			C			0.00					
55			A	0.00							
57			B		0.00						
59			C			0.00					
61			A	0.00							
63			B		0.00						
65			C			0.00					
67			A	0.00							
69			B		0.00						
71			C			0.00					
SUBTOTAL				0.00	0.00	0.00					
2			A	0.00							PROVIDE BRANCH CIRCUITS AS REQUIRED TO REFEED EXISTING CIRCUITS TO REMAIN THAT WERE FED FROM REMOVED PANELS PP2 AND PP4. PROVIDE 20A, 1P SPARE CIRCUIT BREAKERS AT UNUSED POLE PLACES
4			B		0.00						
6			C			0.00					
8			A	0.00							
10			B		0.00						
12			C			0.00					
14			A	0.00							
16			B		0.00						
18			C			0.00					
20			A	0.00							
22			B		0.00						
24			C			0.00					
26			A	0.00							
28			B		0.00						
30			C			0.00					
32			A	0.00							
34			B		0.00						
36			C			0.00					
38			A	0.00							
40			B		0.00						
42			C			0.00					
44			A	0.00							
46			B		0.00						
48			C			0.00					
50			A	0.00							
52			B		0.00						
54			C			0.00					
56			A	0.00							
58			B		0.00						
60			C			0.00					
62			A	0.00							
64			B		0.00						
66			C			0.00					
68			A	0.00							
70			B		0.00						
72			C			0.00					
SUBTOTAL				0.00	0.00	0.00					



75 York Street,
Portland, Maine 04101
simonsarchitects.com
207.772.4656




160 Veranda Street
Portland, Maine 04103
T: 207.221.2260
F: 207.221.2266
Web: www.allied-eng.com

Allied Project No: 15051
Cad File: 15051E.dwg

PROJECT NAME:
**WAYNFLETE
LOWER SCHOOL**
ADDITION & RENOVATIONS

WAYNFLETE SCHOOL
360 SPRING STREET
PORTLAND, MAINE 04102



THIS DRAWING IS THE PROPERTY OF SCOTT SIMONS ARCHITECTS (SSA) AND IS NOT TO BE COPIED OR REPRODUCED IN PART OR WHOLE.
2015 © SCOTT SIMONS ARCHITECTS, LLC

REVISION:

1	DATE
2	DATE
3	DATE
4	DATE
5	DATE
6	DATE

DATE OF ISSUE: 12 JANUARY 2017
PROJECT NUMBER: 2013-0050
STATUS: ISSUED FOR BID

**ELECTRICAL
SCHEDULES**

EP602