

PANEL SCHEDULE ~ L11										
VOLTAGE: 208/120V			MLO: 225A			AIC: 42KA				
3-PHASE, 4-WIRE										
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION				
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C				
1			A	3.84						
3	50	3	B		3.84					
5			C			3.84				
7	30	2	A	2.50						
9			B		2.50					
11	20	1	C			1.44				
13	20	1	A	1.44						
15	20	1	B		1.26					
17	20	1	C			1.26				
19	20	1	A	1.26						
21	20	1	B		1.26					
23	20	1	C			1.44				
25	20	1	A	1.44						
27	20	1	B		1.26					
29	20	1	C			1.44				
31	20	1	A	0.00						
33	20	1	B		0.00					
35	20	1	C			0.00				
37	20	1	A	0.00						
39	20	2	B		1.08					
41			C			1.08				
43	20	2	A	1.08						
45			B		1.08					
47	20	1	C			1.00				
49	20	1	A	1.00						
51	20	1	B		1.00					
53	20	1	C			1.50				
55	20	1	A	0.72						
57	20	1	B		1.50					
59	20	1	C			0.00				
61	20	1	A	0.00						
63	20	1	B		0.00					
65	20	1	C			0.00				
67	20	1	A	0.00						
69	20	1	B		0.00					
71	20	1	C			0.00				
SUBTOTAL				13.28	14.78	13.00				
2	20	2	A	0.15						
4			B		0.15					
6	50	2	C			3.60				
8			A	3.60						
10	20	2	B		1.18					
12			C			1.18				
14	20	1	A	0.22						
16	20	1	B		0.22					
18	20	1	C			0.50				
20	20	1	A	0.90						
22	15	2	B		1.44					
24			C			1.44				
26	20	1	A	0.84						
28	20	1	B		1.08					
30	20	1	C			0.87				
32	20	1	A	1.44						
34	20	1	B		0.00					
36	20	1	C			0.00				
38	20	1	A	0.00						
40	20	1	B		0.00					
42	20	1	C			0.00				
44	20	1	A	0.00						
46	20	1	B		0.00					
48	20	1	C			0.00				
50	20	1	A	0.00						
52	20	1	B		0.00					
54	20	1	C			0.00				
56	20	1	A	0.00						
58	20	1	B		0.00					
60	20	1	C			0.00				
62	20	1	A	0.00						
64	20	1	B		0.00					
66	20	1	C			0.00				
68	20	1	A	0.00						
70	20	1	B		0.00					
72	20	1	C			0.00				
SUBTOTAL				7.15	4.07	7.59				

PANEL SCHEDULE ~ L21										
VOLTAGE: 208/120V			MLO: 225			AIC: 14 KA				
3-PHASE, 4-WIRE										
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION				
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C				
1	20	1	A	1.44						
3	20	1	B		1.26					
5	20	1	C			1.44				
7	20	1	A	1.10						
9	20	1	B		1.26					
11	20	1	C			1.26				
13	20	1	A	1.44						
15	20	1	B		1.26					
17	20	1	C			1.20				
19	20	1	A	1.08						
21	20	1	B		1.26					
23	20	1	C			1.10				
25	20	1	A	1.44						
27	20	1	B		1.44					
29	20	1	C			1.28				
31	20	1	A	1.44						
33	20	1	B		1.44					
35	20	1	C			1.50				
37	20	1	A	1.50						
39	20	1	B		1.44					
41	20	1	C			0.90				
43	20	1	A	1.50						
45	20	1	B		0.50					
47	20	1	C			1.00				
49	20	1	A	1.00						
51	20	1	B		1.00					
53	20	1	C			1.00				
55	20	1	A	0.00						
57	20	1	B		0.00					
59	20	1	C			0.00				
61	20	1	A	0.00						
63	20	1	B		0.00					
65	20	1	C			0.00				
67	20	1	A	0.00						
69	20	1	B		0.00					
71	20	1	C			0.00				
SUBTOTAL				11.94	10.86	10.68				
2	20	2	A	0.65						
4			B		0.65					
6	20	1	C			0.54				
8	20	1	A	0.00						
10			B		3.60					
12	50	2	C			3.60				
14	20	1	A	1.00						
16	20	1	B		1.50					
18	20	1	C			1.50				
20	20	1	A	1.00						
22	20	1	B		1.40					
24	20	1	C			1.40				
26	20	1	A	1.50						
28	20	1	B		0.00					
30	20	1	C			0.00				
32	20	1	A	1.18						
34	20	1	B		1.13					
36	20	1	C			1.01				
38	20	1	A	0.83						
40	20	1	B		0.00					
42	20	1	C			0.00				
44	20	1	A	0.00						
46	20	1	B		0.00					
48	20	1	C			0.00				
50	20	1	A	0.00						
52	20	1	B		0.00					
54	20	1	C			0.00				
56	20	1	A	0.00						
58	20	1	B		0.00					
60	20	1	C			0.00				
62	20	1	A	0.00						
64	20	1	B		0.00					
66	20	1	C			0.00				
68	20	1	A	0.00						
70	20	1	B		0.00					
72	20	1	C			0.00				
SUBTOTAL				6.16	8.28	8.05				

PANEL SCHEDULE ~ L31										
VOLTAGE: 208/120V			MLO: 400A			AIC: 22KA				
3-PHASE, 4-WIRE										
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION				
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C				
1	20	1	A	0.00						
3	20	1	B		0.00					
5	20	1	C			0.00				
7	30	2	A	2.88						
9			B		2.88					
11			C			1.72				
13	20	2	A	1.72						
15			B		1.72					
17	20	2	C			1.72				
19	20	2	A	1.72						
21			B		1.72					
23			C			1.72				
25	20	2	A	1.72						
27			B		2.81					
29	30	2	C			2.81				
31			A	6.67						
33	60	3	B		6.67					
35			C			6.67				
37			A	0.00						
39	20	1	B		0.00					
41			C			0.00				
SUBTOTAL				14.71	15.80	14.64				
2			A	3.62						
4	70	3	B		3.62					
6			C			3.62				
8			A	3.31						
10	35	3	B		3.31					
12			C			3.31				
14			A	4.36						
16	45	3	B		4.36					
18			C			4.36				
20			A	3.31						
22	35	3	B		3.31					
24			C			3.31				
26			A	4.36						
28	45	3	B		4.36					
30			C			4.36				
32			A	3.31						
34	35	3	B		3.31					
36			C			3.31				
38			A	4.36						
40	45	3	B		4.36					
42			C			4.36				
SUBTOTAL				26.63	26.63	26.63				

PANEL SCHEDULE ~ L32									
VOLTAGE: 208/120V			MLO: 225A			AIC: 22KA			
3-PHASE, 4-WIRE									
CIRCUIT BREAKER			CIRCUIT LOAD (KVA) CONNECTED			BRANCH CIRCUIT DESCRIPTION			
CKT NO	BRKR SIZE	NO OF POLES	PH	A	B	C			
1	20	1	A	1.26					
3	20	1	B		1.26				
5									