1. FIRE ALARM COMPONENTS SHALL BE CONNECTED TO THE EXISTING SILENT KNIGHT IFP-2000 SERIES ADDRESSABLE FIRE ALARM CONTROL PANEL IN EMERY HALL. SEE SHEET ES101M FOR CONDUITS TO EMERY HALL. PROVIDE ALL NECESSARY COMMON COMPONENTS, POWER SUPPLY, BATTERY CHARGERS, BATTERIES, PROGRAMMING, ETC. AS REQUIRED TO SUPPORT THE ADDITION OF COMPONENTS PROVIDED UNDER THIS SECTION FOR COMPLETION OF A TOTALLY OPERATIONAL FIRE ALARM SYSTEM IN ACCORDANCE WITH NFPA 72 AND LOCAL REQUIREMENT.
2. FIRE ALARM SYSTEM COMPONENTS SHALL BE COMPATIBLE AND LISTED FOR USE WITH THE EXISTING FIRE ALARM SYSTEM, AND SHALL MATCH EXISTING SIMILAR DEVICES OR BE THE SYSTEM MANUFACTURER'S CURRENT RECOMMENDED REPLACEMENT FOR EXISTING SIMILAR DEVICES.

- SMOKE DETECTOR, WIRED TO FACP
- HEAT DETECTOR, WIRED TO FACP
- MANUAL PULL STATION, MOUNT 48" AFF
- HORN/STROBE, WALL MOUNTED CANDELA AS NOTED ON PLANS, WIRED TO FACP
- HORN/STROBE, CEILING MOUNTED, CANDELA AS NOTED ON PLANS, WIRED TO FACP
- STROBE ONLY INDICATING APPLIANCE, WALL MOUNTED, CANDELA AS NOTED ON PLANS, WIRED TO FACP
- STROBE ONLY INDICATING APPLIANCE, CEILING MOUNTED, CANDELA AS NOTED ON PLANS, WIRED TO FACP

A1	FIRE ALARM PLAN	A7	FIRE ALARM NOTES	A9	FIRE ALARM SYSTEM
SCALE: 1"=10'-0"		NO SCALE		NO SCALE	

Reviewed for Code Compliance
Inspectors Division
Date: 06/20/17

scott simons architects
designed for human potential

75 York Street,
Portland, Maine 04101
simonsarchitects.com
207.772.4656

Allied Engineering
Structural Mechanical
Electrical Commissioning

160 Veranda Street
Portland, Maine 04103
T: 207.221.2260
F: 207.221.2266
Web: www.allied-eng.com

© COPYRIGHT 2015 ALLIED ENGINEERING, INC.

Allied Project No: 15051
Cad File: 15051E.dwg

PROJECT NAME:

WAYNFLETE
LOWER SCHOOL
ADDITION & RENOVATIONS

WAYNEFLETE SCHOOL
360 SPRING STREET
PORTLAND, MAINE 04102

SEAL:

STATE OF MAINE
CATHERINE A. FAUCHER
No. 7575
LICENSED
PROFESSIONAL ENGINEER

THIS DRAWING IS THE PROPERTY OF SCOTT SIMONS ARCHITECTS (SSA) AND IS NOT TO BE COPIED OR REPRODUCED IN PART OR WHOLE
2015 © SCOTT SIMONS ARCHITECTS, LLC

REVISION:

1	DATE
2	DATE
3	DATE
4	DATE
5	DATE
6	DATE

DATE OF ISSUE: -
PROJECT NUMBER: -
STATUS: -

MODULAR BUILDINGS
FIRE ALARM
PLAN

FA101M

ISSUED FOR PERMIT ~ NOT FOR CONSTRUCTION ~ APRIL 28, 2017

N:\Projects\2015\15051 ~ Wayfnlete School\00 Drawing Files\Temporary Modulars\15051E-TRAILERS.dwg Apr 28, 2017 - 10:48am