BUILDING CODE

1. ATTIC VENTILATION SHALL NOT BE LESS THAN 1/150th OF THE HORIZONTAL AREA TO BE VENTILATED.
2. THE BUILDING EXTERIOR AND ALL FACILITIES WITHIN THE BUILDING SHALL BE IDENTIFIED WITH THE INTERNATIONAL SYMBOL OF ACCESSIBILITY.
3. BUILDER/DEALER SHALL BE RESPONSIBLE FOR ON SITE BARRIER FREE PROVISIONS: STEPS, RAMPS, PARKING SIGNS, ETC. – BUILDING APPROACH (WALK OR RAMP) WITH A MINIMUM WIDTH OF 5' AND A GRADIENT OF NOT MORE THAN 1 FOOT IN 20 FEET.
4. ALL LOCKS TO BE UNLOCKABLE FROM THE INTERIOR WITHOUT THE USE OF A KEY OR SPECIAL KNOWLEDGE.
5. CORROSION RESISTANT FLASHING AT TOP AND SIDES OF DOORS, WINDOWS AND AT ROOF PENETRATIONS.
6. ALL GLAZING WITHIN 24" OF EXTERIOR PASSAGE DOORS AND IN PASSAGE DOORS, OR WITHIN 18" OF FLOOR TO BE "SAFTEY GLAZED" AND SO MARKED.

MANSARD DETAIL @ ENDWALL

STATE OF MAINE
Pin-Shi Peter Lee
12156
LICENSED
PROFESSIONAL ENGINEER
APR 28 2017

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/20/17

JOB NO:	2
DRAWING NO:	
DATE:	4/12/17
SCALE:	NTS

WILLIAMS SCOTSMAN, INC.
325 RODMAN ROAD, AUBURN, ME 04210

DRAWN BY:	R.M.
REV:	
TITLE:	CROSS SECTION
MODEL:	2464 O/A CLASSROOM