


951178

FILL IN AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,



61-6-5

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. 08 November 1995

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 320 Spring St Use of Building 2-fam No. Stories New Building Existing "
Name and address of owner of appliance Wilson/Browning
Installer's name and address Rudi the Plumber Telephone
1231 Forest Ave Ptld,f ME 04103 797-8311

To install Gas fired forced hot water heating system - Replacement

IF HEATER, OR POWER BOILER

Location of appliance Basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? Natural Gas
Minimum distance to burnable material, from top of appliance or casing top of furnace 18"
From top of smoke pipe 18" From front of appliance 18" From sides or back of appliance 18"
Size of chimney flue 7" Other connections to same flue no
If gas fired, how vented? chimney Rated maximum demand per hour 225,000
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion? yes

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories?
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?
Type of floor beneath burner Size of vent pipe
Location of oil storage Number and capacity of tanks
Low water shut-off Make No.
Will all tanks be more than five feet from any flame? How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustibile material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Master Oil Burner 1076

- 1. 1 1/2" FILL PIPE
2. 1 1/4" VENT PIPE
3. Kind of heat
4. Burner rigidity & support
5. Name & Label
6. Remote control
7. High limit control
8. Main cutoff switch
9. Low water cutoff
10. High limit control
11. Piping support & protection
12. Valves in supply line
13. Capacity of tanks
14. Tank rigidity & support
15. Oil gauge
16. Inspection card
17. Adequate venting
18. Sufficient fresh air
19. Sufficient fresh air
20. Thermal relief

Amount of fee enclosed?

APPROVED:

O.K. Hoffo

Will there be in charge of the work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Installer Rudi the Plumber
[3] Ms SIMPSON

CS 300

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY

no access for inspection