



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Jeff Levine, AICP, Director
Director of Planning and Urban Development

Tammy Munson
Director, Inspections Division

Electronic Signature and Fee Payment Confirmation

Notice: Your electronic signature is considered a legal signature per state law.

By digitally signing the attached document(s), you are signifying your understanding this is a legal document and your electronic signature is considered a **legal signature** per Maine state law. You are also signifying your intent on paying your fees by the opportunities below.

I, the undersigned, intend and acknowledge that no permit application can be reviewed until payment of appropriate permit fees are **paid in full** to the Inspections Office, City of Portland Maine by method noted below:

Within 24-48 hours, upon receipt of an e-mailed invoice from Building Inspections, which signifies that my electronic permit application and corresponding paperwork have been received, determined complete, entered by an administrative representative, and assigned a permit number, I then have the following four (4) payment options:

- to provide an on-line electronic check or credit/debit card (we now accept American Express, Discover, VISA, and MasterCard) payment (along with applicable fees beginning July 1, 2014),
- call the Inspections Office at (207) 874-8703 and speak to an administrative representative to provide a credit/debit card payment over the phone,
- hand-deliver a payment method to the Inspections Office, Room 315, Portland City Hall,
- or deliver a payment method through the U.S. Postal Service, at the following address:

City of Portland
Inspections Division
389 Congress Street, Room 315
Portland, Maine 04101

Once my payment has been received, this then starts the review process of my permit. **After all approvals have been met and completed, I will then be issued my permit via e-mail.** No work shall be started until I have received my permit.

Applicant Signature:  Date: 2-2-15

I have provided digital copies and sent them on: James Robinson Date: 2-2-15

NOTE: All electronic paperwork must be delivered to buildinginspections@portlandmaine.gov or by physical means ie; a thumb drive or CD to the office.

Room 315 - 389 Congress Street- Portland, Maine 04101 (207) 874-8703 - Fax: 874-8716 - TTY: 874-8936

FILL IN AND SIGN WITH INK



HVAC / Power Equipment Checklist

All of the following information is required and must be submitted. Checking off each item as you prepare your application package will ensure your package is complete and will help to expedite the permitting process.

A floor plan that includes structural details, size and dimensions of the floor the equipment is going to be installed.

Information on how the unit is being vented & hanging details if appropriate.

Details of the specific equipment being installed; ie; specifications and any heating technical specifications. Often this information can be obtained from the manufacturer's spec sheet or retail advertisements.

A plot plan showing the shape and dimension of the lot, with the distance from the actual property lines, and the principal structure.

Proof of ownership is required if it is inconsistent with the assessors records.

**All HVAC installations must be conducted in compliance with the
IRC 2009 Building Code**

Separate permits are required for plumbing and electrical installations, as required.

Separate permits are also required based on different properties (different Chart, Block and Lot.)

Permit Fee: \$25.00 for the first \$1000.00 construction cost, \$11.00 per additional \$1000.00 cost

This is not a Permit; you may not commence any work until the Permit is issued.



FILL IN AND SIGN WITH INK

Application for Heating, Ventilation, Air Condition (HVAC) Cooking or Power Equipment



To the Inspector of Buildings, Portland Maine:

The undersigned hereby applies for a permit to install the following HVAC, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Address/CBL: 10 Greyhurst Park Use of Building: SINGLE FAMILY Date: 2-2-15

Name and Address of Owner: DAN SKWIRE

Phone Number Owner: 207-874-2934 E-Mail: Owner: Dan.skwire@milliman.com

Name and Address of Installer: MAINELY PLG & HTG INC

Phone Number Installer: 207-854-4969 E-Mail: Installer: jim@mainelyplumbing.com

<p>Location of Appliance:</p> <p><input checked="" type="checkbox"/> Basement <input type="checkbox"/> Floor</p> <p><input type="checkbox"/> Attic <input type="checkbox"/> Roof</p> <p>Type of Fuel:</p> <p><input checked="" type="checkbox"/> Gas <input type="checkbox"/> Oil <input type="checkbox"/> Solid</p> <p>Appliance Name: <u>WEIL MCLAIN EG50</u></p> <p>UL Approved: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Will appliance be installed in accordance with the manufacturer's installation instructions? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Type of License of Installer: Master Plumber #: <u>MS2401</u></p> <p>Solid Fuel #: _____</p> <p>Oil #: _____</p> <p>Gas #: <u>PNT347</u></p> <p>Other: _____</p>	<p>Type of Venting: <i>(Plan required for submittal)</i></p> <p><input type="checkbox"/> Masonry Lined</p> <p><input type="checkbox"/> Factory Built: _____</p> <p><input type="checkbox"/> Metal</p> <p><input checked="" type="checkbox"/> Factory Built UL Listing: <u>SS LINER</u></p> <p><input type="checkbox"/> Direct Vent</p> <p>Type: _____ UL #: _____</p> <p># of Tanks: _____</p> <p>Type of Fuel Tank:</p> <p><input type="checkbox"/> Gas <input type="checkbox"/> Oil</p> <p>Size of Tank: <u>NATURAL GAS</u></p> <p>Distance from tank to center of flame: _____</p> <p>Cost of Work: \$ <u>9,000</u></p> <p>Permit Fee: \$ <u>113.00</u></p>
---	--

Signature of Installer:  E-Mail: jim@mainelyplumbing.com

•
•
•
•
•
•
•

MAINELY PLUMBING & HEATING, INC.
674 MAIN STREET
GORHAM, MAINE 04038
207-854-4969/ FAX 854-2232
www.mainelyplumbing.com
MEMBER PHCC OF MAINE
Plumbing, Heating & Cooling Contractors of Maine

DATE: 2-2-2015

TO: CITY OF PORTLAND INSPECTIONS DEPARTMENT

FROM: JIM ROBINSON

WANT TO INSTALL NEW WEIL MCLAIN EG-50 STEAM CHIMNEY VENTED
NATURAL GAS BOILER IN THE BASEMENT CONNECTED TO THE EXISTING
HEATING DISTRIBUTION SYSTEM AND VENTED THRU A NEW 6" SS CHIMNEY
LINER.
THIS WILL REPLACE AN OIL FIRED BOILER.
WE CALCULATED THE EXISTING STEAM LOAD BASED ON THE EXISTING
SYSTEM WHICH TOTALED 420 SQ FT OF STEAM AND THE NEW BOILER WILL
PRODUCE 454 SQ FT OF STEAM

• • • • •