City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

T			Di	
Location of Construction:	Owner:		Phone:	Permit No: 9 8 0 0 3 3
Owner Address:	Lessee/Buyer's Name:	Phone:	BusinessName:	PERMIT ISSUED
Contractor Name:	Address: 15 Cak St S. Portland 1	Phone: 76	7-2934	Permit Issued:
Past Use:	Proposed Use:	COST OF WORK	PERMIT FEE:	JAN 2 1998
1-fam dwelling	l-fam dwelling	FIRE DEPT. A	Use Group: R-3Type:	Zone: CBL:
Proposed Project Description:		Signature:	Signature: 7	Zanima Annuali
Interior Removations (per	plaus minus kitchen)	Action: A	pproved with Conditions: enied	Special Zone or Reviews:
		Signature:	Date:	☐ Flood Zone ☐ Subdivision
Permit Taken By: Sherry Finard	Date Applied For:		Date	☐ Site Plan maj ☐minor ☐mm ☐
		uary 16, 1998		Zoning Appeal
2. Building permits do not include plumbin	arted within six (6) months of the date of is			☐ Miscellaneous ☐ Conditional Use ☐ Interpretation ☐ Approved ☐ Denied
			PERMIT ISSUED WITH REQUIREMENTS	Historic Preservation □ Not in District or Landmark □ Does Not Require Review □ Requires Review Action:
I hereby certify that I am the owner of record of authorized by the owner to make this applicate if a permit for work described in the application areas covered by such permit at any reasonab	ion as his authorized agent and I agree to on is issued, I certify that the code official	conform to all applicable s authorized representative	laws of this jurisdiction. In addit e shall have the authority to ente	ion, Denied
SIGNATURE OF APPLICANT	ADDRESS:	DATE:	PHONE;	
Gary Shank		January 16, 1998		
RESPONSIBLE PERSON IN CHARGE OF W			PHONE:	CEO DISTRICT
White	Permit Desk Green-Assessor's Ca	nary-DPW Pink-Publ	lic File Ivory Card-Inspector	

LAND USE - ZONING REPORT

ADDRESS: 354 DANGEVIN DATE: 120/98
REASON FOR PERMIT: Interior Terrorigitions
BUILDING OWNER: Karen Santara C-B-L: 61-H-12
PERMIT APPLICANT: GNY Shand
APPROVED: With conditions DENIED:
CONDITION(S) OF APPROVAL
1. During its existence, all aspects of the Home Occupation criteria, Section 14-410, shall be maintained.
2. The footprint of the existing shall not be increased during maintenance reconstruction.
3. All the conditions placed on the original, previously approved, permit issued on
 4. Your present structure is legally nonconforming as to rear and side setbacks. If you were to demolish the building on your own volition, you will not be able to maintain these same setbacks. Instead you would need to meet the zoning setbacks set forth in today's ordinances. In order to preserve these legally non-conforming setbacks, you may only rebuild the garage in place and in phases. 5) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval. 6. Our records indicate that this property has a legal use of units. Any change in this approved use shall require a separate permit application for review and approval. 7. Separate permits shall be required for any signage. 8. Separate permits shall be required for future decks and/or garage. 9. Other requirements of condition The Soliton to the factor of the property of the factor.
persuing A Conditional Use Appeal with The Zoning Board to Allow in Additional unit, However prior to Any Board Affroad Three Addition of And Kotchen equipment or even preparatory plumbing indications. If and when the portant provide your appeals wing. If and when the portant provide your Appeals and when the portant Marge Schmuckal, Zoning Administrator, and Asst. Chief of Code Enforcement Amendment or Spanish permit Shall be Affriced for The Additional unit - Ministration Schmuckal Schmuckal Schmuckal for The Additional unit - Ministration Schmuckal Schmuckal Schmuckal Schmuckal

BUILDING PERMIT REPORT

DATE: 21 Jan, 1998 ADDRESS: 354 Dan for Th ST.
REASON FOR PERMIT: To MAKE INTERIOR VENOUATIONS
BUILDING OWNER: Karen Sanford
CONTRACTOR: Gark Shank
PERMIT APPLICANT: Gark Shank APPROVAL:
USE GROUP R-3 BOCA 1996 CONSTRUCTION TYPE 5B

CONDITION(S) OF APPROVAL

- 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
- Precaution must be taken to protect concrete from freezing.
- 4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
- Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
- 6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993).
- Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
- 8. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 34" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".)
- 9. Headroom in habitable space is a minimum of 7'6"
- 10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
- The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6' 8")
- Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
- Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units
- 14. All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self-closer's.
- The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms

80				Date 1/9 / 1/9 / 2/3/50
be done per plans.				Type Type O.K. O.K.
Insp appears to b	Membing - of	# 96 CC8C		Foundation: Framing: Plumbing: Final: Other:
1/3/48 - Did framing Insp c	Checked row	Keterto primit # 96		


- In each story within a dwelling unit, including basements
 In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)
- 17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
- 18. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 19. The Sprinkler System shall maintained to NFPA #13 Standard.
- 20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 21. No construction or demolition work shall begin until you have obtained permits for dumpsters or containers. A work Stop Order shall be issued if this requirement is not met.
- 22. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 23. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 24. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
- 25. Ventilation shall meet the requirements of Chapter 12 Sections 1210, of the City's Building Code.
- 26. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade.
- 27. All requirements must be met before a final Certificate of Occupancy is issued.
- 28. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).

29. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993).

	Mechanical Code/1993).
× 30.	This permit is being issued for interior renovations. Only NOT To
, 1	add any New USES.
×31.	Rease read and implement attached Land-USC-Zoning report
	requirements.
₹ 32.	your submitted plans Shows The removal of or wall. If This
•	hall is a bearing wall No work is To be done in This area until a new
30.	Plan has been submitted showing a detail of The header-This design
	Shall be done by a registered design professional.
34	

Samuel Hoffses, Code Enforcement

cc: Lt. McDougall, Pf4.



... . (

HT AOINA O

