

. . . Fire Protection by Computer Design

FREEDOM FIRE PROTECTION
209 QUAKER RIDGE ROAD
CASCO, MAINE 04015
(207) 627-4109

Job Name : 380 DANFORTH STREET
Drawing : 380 DANFORTH STREET
Location : PORTLAND, MAINE 04102
Remote Area : #1 AREA #1
Contract :
Data File : 380 DANFORTH STREET HC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 380 DANFORTH STREET Date - 12/15/16
Location - PORTLAND, MAINE 04102
Building - 380 DANFORTH STREET System No. - #1 AREA #1
Contractor - FREEDOM FIRE PROTECTION Contract No. -
Calculated By - MIKE NOBLIT Drawing No. - FP-2
Construction: (X) Combustible () Non-Combustible Ceiling Height 10'-0"
OCCUPANCY - HOUSE

S Type of Calculation: (X)NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 16 Gpm System Type
Listed Pres. at Start Point - 13.2 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16' x 16' () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - 0 Gpm Make TYCO Model LFII
I Elevation at Highest Outlet - 33 Feet Size 1/2" K-Factor 4.4
G Note: Temperature Rating 155
N

Calculation Gpm Required 32.437 Psi Required 55.247 At Test
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 2/1/2016 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 66 Elev.
R Residual (Psi) - 0 Other Well
Flow (Gpm) - 691 Proof Flow Gpm
S Elevation -

P Location:
P
L Source of Information: PORTLAND WATER DISTRICT
Y


Water Supply Curve C

FREEDOM FIRE PROTECTION
380 DANFORTH STREET

Page 2
Date 12/15/16

City Water Supply:
C1 - Static Pressure : 66
C2 - Residual Pressure: 0
C2 - Residual Flow : 691

Demand:
D1 - Elevation : 14.292
D2 - System Flow : 32.437
D2 - System Pressure : 55.247
Hose (Demand) : _____
D3 - System Demand : 32.437
Safety Margin : 10.523



Fittings Used Summary

FREEDOM FIRE PROTECTION
380 DANFORTH STREET

Page 3
Date 12/15/16

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION
380 DANFORTH STREET

Page 4
Date 12/15/16

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
101	33.0	4.4	13.2	na	15.99	0.05	0.001	13.2
12	33.0		13.65	na				
11	22.0		19.08	na				
10	22.0		19.73	na				
102	33.0	4.4	13.98	na	16.45	0.05	0.001	13.2
9	33.0		14.18	na				
8	22.0		19.65	na				
7	22.0		20.44	na				
6	22.0		23.5	na				
5	22.0		24.9	na				
4	10.33		33.52	na				
3	10.33		35.42	na				
2	0.0		48.08	na				
1	0.0		50.31	na				
0	0.0		52.57	na				
TEST	0.0		55.25	na				

The maximum velocity is 12.04 and it occurs in the pipe between nodes 3 and 2

Final Calculations - Hazen-Williams - 2007

FREEDOM FIRE PROTECTION
380 DANFORTH STREET

Page 5
Date 12/15/16

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv.	Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
101 to 12	33 33	4.40	15.99	1	T	9.563 0.0	0.500 9.562	150	13.200 0.0			
			15.99	1.101		0.0	10.062	0.0449	0.452	Vel =	5.39	
12 to 11	33 22		0.0	1	E	3.825 0.0	11.000 3.825	150	13.652 4.764			
			15.99	1.101		0.0	14.825	0.0450	0.667	Vel =	5.39	
11 to 10	22 22		0.0	1	T	9.563 0.0	4.830 9.562	150	19.083 0.0			
			15.99	1.101		0.0	14.392	0.0450	0.647	Vel =	5.39	
10 to 7	22 22		0.0	1	T	9.563 0.0	6.166 9.562	150	19.730 0.0			
			15.99	1.101		0.0	15.728	0.0450	0.707	Vel =	5.39	
7			0.0 15.99						20.437	K Factor =	3.54	
102 to 9	33 33	4.40	16.45	1	E	3.825 0.0	0.500 3.825	150	13.979 0.0			
			16.45	1.101		0.0	4.325	0.0474	0.205	Vel =	5.54	
9 to 8	33 22		0.0	1	E	3.825 0.0	11.000 3.825	150	14.184 4.764			
			16.45	1.101		0.0	14.825	0.0474	0.703	Vel =	5.54	
8 to 7	22 22		0.0	1		0.0 0.0	16.583 0.0	150	19.651 0.0			
			16.45	1.101		0.0	16.583	0.0474	0.786	Vel =	5.54	
7 to 6	22 22		15.99	1	T	9.563 0.0	8.830 9.562	150	20.437 0.0			
			32.44	1.101		0.0	18.392	0.1664	3.061	Vel =	10.93	
6 to 5	22 22		0.0	1	E	3.825 0.0	4.583 3.825	150	23.498 0.0			
			32.44	1.101		0.0	8.408	0.1665	1.400	Vel =	10.93	
5 to 4	22 10.330		0.0	1	E	2.531 0.0	11.660 2.531	120	24.898 5.054			
			32.44	1.101		0.0	14.191	0.2515	3.569	Vel =	10.93	
4 to 3	10.330 10.330		0.0	1	E	2.531 0.0	5.000 2.531	120	33.521 0.0			
			32.44	1.101		0.0	7.531	0.2515	1.894	Vel =	10.93	
3 to 2	10.330 0		0.0	1	E Zaa	2.0 0.0	10.330 2.000	120	35.415 8.741	** Fixed Loss =	4.267	
			32.44	1.049		0.0	12.330	0.3183	3.925	Vel =	12.04	
2 to 1	0 0		0.0	1	T	5.0 0.0	2.000 5.000	120	48.081 0.0			
			32.44	1.049		0.0	7.000	0.3184	2.229	Vel =	12.04	
1 to 0	0 0		0.0	1.5	3E	10.627 0.0	40.000 10.627	140	50.310 0.0			
			32.44	1.481		0.0	50.627	0.0446	2.259	Vel =	6.04	
0 to TEST	0 0		0.0	1.5		0.0 0.0	60.000 0.0	140	52.569 0.0			
			32.44	1.481		0.0	60.000	0.0446	2.678	Vel =	6.04	
			0.0									

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION
380 DANFORTH STREET

Page 6
Date 12/15/16

Node1	Elev1	K	Qa	Nom	Fitting		Pipe	CFact	Pt			
to					or		Ftng's		Pe	*****	Notes	*****
Node2	Elev2	Fact	Qt	Act	Eqv.	Ln.	Total	Pf/Ft	Pf			
TEST			32.44						55.247		K Factor =	4.36