



**LIGHTING KEY NOTES:**

- ① WAYSIDE/IN-WALL LIGHTING CONTROLS TO INCLUDE:
  - 1.) LS-B8 JUNCTION BOX
  - 2.) LCP-200 DIMMING CONTROLLER
  - 3.) LCP-200 SERIES WALL MOUNT OCCUPANCY SENSOR
  - 4.) DT-200 SERIES WALL MOUNT PHOTOCELL
  - 5.) LS-280C CEILING MOUNT PHOTOCELL
- ② ULTRASONIC OCCUPANCY SENSOR SET FOR JAWHAWK THEATRE FROM MANUFACTURER'S RECOMMENDATIONS. FIXTURES INCLUDE:
  - 6.) LS-4C WALL SWITCH AND INSTALL LS-B8 1'-0" BOX ABOVE CEILING AT ENTRANCE TO ROOM BEING SERVED. INSTALL LCP-200 AND DT-200 IN J-BOX AND MOUNT WITH DIM RAIL. SEE DETAIL SHEET E-2X FOR SPECIFIC MOUNTING AND OPERATIONAL INSTRUCTIONS.
- ③ MOUNT OCCUPANCY SENSORS 4" BELOW BOTTOM OF LIGHT FIXTURES.
- ④ FIXTURES WITH EMERGENCY BALLAST REQUIRE AN ADDITIONAL WIRE CONNECTED TO THE UNSWITCHED HOT FROM THE SAME BRANCH CIRCUIT AS THE 2X BALLAST.
- ⑤ LITRION NOVIA T WALLBY DIMMERS IN\*\* MOUNT DIMMERS IN INDIVIDUAL WALLBOXES AND ALLOW 1/2" OF SPACE BETWEEN EACH TIED DOWN WITH RIBBON. CHECK FROM P-24,25,26.

<p><b>DATE:</b> 09/07  <b>SCALE:</b> 1/8" = 1'-0"  <b>PROJECT NO.:</b> 2005-004-00  <b>DRAWN BY:</b> RABR  <b>DWG NO.:</b> E-1.5</p>	<p><b>STATUS:</b>          ISSUED FOR BIDDING</p>	<p><b>TITLE:</b>  <b>ELECTRICAL LIGHTING FIRST FLOOR PLAN</b></p>	<p><b>PROJECT:</b>  <b>WAYNFLETE ARTS CENTER PHASE TWO</b>  <input type="checkbox"/> ADDITION/RENOVATION  <b>390 SPRING STREET PORTLAND, ME</b></p>	<p><b>Scott Simon Architects</b>          73 York Street          Portland, Maine 04101          Tel: 603.763.8888          Fax: 603.763.8889</p>	<p><b>Will and Gunter</b>          OLD FLE 2588806</p>
--	---	---	---	---	--