

From: Benjamin Wallace
To: Terri MacDonald
Date: 10/26/2009 2:01:37 PM
Subject: Re: 7 Carroll St, Portland, plan of action

Good afternoon,

This is acceptable. I just want to make clear that the frames need to be rated also.

Captain Dyer- Would you please schedule a follow up inspection to clear the smoke alarm violation with the owner?

Thanks,

Benjamin A. Wallace Jr.
Fire Prevention Officer
Portland Fire Department
380 Congress Street
Portland, Maine 04101
(207)756-8096
wallaceb@portlandmaine.gov

>>> Terri MacDonald <tmacdonald88@hotmail.com> 10/26 1:21 PM >>>

Hi Ben.

Per our conversation last Thursday (hope you had a nice long weekend) here is the email you asked me to send to you.

I will have the apartment doors changed to 60 minute fire doors with two self closing hinges by Christmas time this year. Upon looking at the property, there are 7 doors that need to be changed. As I mentioned, I have already complied with the code that requires smoke/carbon dioxide detectors be hard wired in each apartment.

Here is my contact info:

Terri MacDonald
31 Kathy's Path
Scituate, MA 02066
781-424-6432
tmacdonald88@hotmail.com

Thank-you!

Terri MacDonald