

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT

This is to certify that

SCHNELL ARTHUR G & MICHELE E BEDNARZ

Located at

114 PINE ST

PERMIT ID: 2016-02284

ISSUE DATE: 09/21/2016

CBL: 062 C002001

has permission to **Renovation of rental unit kitchen, bath-sheetrocking and floor refinishing. (Unit #1 only)**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

| | |
|---|--|
| Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED. | A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy. |
|---|--|

/s/ Michael White

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Six dwelling units

Building Inspections

Use Group: R-2 **Type:** 5B

Apartment house - 6 units

UNIT #1

MUBEC/IBC 2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Final - Commercial

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

| | | | | |
|---|--------------------------------------|--|--|---|
| City of Portland, Maine - Building or Use Permit | | Permit No: 2016-02284 | Date Applied For: 08/25/2016 | CBL: 062 C002001 |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 | | | | |
| Proposed Use: Same: Multi Unit | | Proposed Project Description: Renovation of rental unit kitchen, bath-sheetrocking and floor refinishing. (Unit #1 only) | | |
| <hr/> | | | | |
| Dept: Historic | Status: Approved w/Conditions | Reviewer: Robert Wiener | Approval Date: 09/08/2016 | Ok to Issue: <input checked="" type="checkbox"/> |
| Note: | | | | |
| Conditions: | | | | |
| 1) With the exception of a replacement bathroom window (very limited visibility) and a small bathroom vent hood (to be painted the same color as the siding,) no exterior alterations are approved with this permit. | | | | |
| <hr/> | | | | |
| Dept: Zoning | Status: Approved w/Conditions | Reviewer: Christina Stacey | Approval Date: 09/06/2016 | Ok to Issue: <input checked="" type="checkbox"/> |
| Note: | | | | |
| Conditions: | | | | |
| 1) This property shall remain a six dwelling units. Any change of use shall require a separate permit application for review and approval. | | | | |
| 2) This permit is not approving any lot coverage or setback requirements for the existing structure. It is approving interior work only. | | | | |
| 3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. | | | | |
| <hr/> | | | | |
| Dept: Building Inspecti | Status: Approved w/Conditions | Reviewer: Laurie Leader | Approval Date: 09/21/2016 | Ok to Issue: <input checked="" type="checkbox"/> |
| Note: | | | | |
| Conditions: | | | | |
| 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. | | | | |
| 2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. | | | | |
| <hr/> | | | | |
| Dept: Engineering DPS | Status: Not Applicable | Reviewer: Rachel Smith | Approval Date: 08/26/2016 | Ok to Issue: <input checked="" type="checkbox"/> |
| Note: | | | | |
| Conditions: | | | | |
| 1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801. | | | | |
| <hr/> | | | | |
| Dept: Fire | Status: Approved w/Conditions | Reviewer: Michael White | Approval Date: 09/07/2016 | Ok to Issue: <input checked="" type="checkbox"/> |
| Note: | | | | |
| Conditions: | | | | |
| 1) If applicable, all outstanding code violations shall be corrected prior to final inspection. | | | | |
| 2) All means of egress to remain accessible at all times. | | | | |
| 3) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation. | | | | |
| 4) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4). | | | | |
| 5) All construction shall comply with City Code, Chapter 10. | | | | |