

**RETURN OF ADMINISTRATIVE INSPECTION WARRANT**

STATE OF MAINE  
CUMBERLAND, ss

DISTRICT COURT  
PORTLAND, MAINE


RE: 128 Emery Street, Portland

I, Captain John Brennan, am the Captain assigned to the City of Portland Fire Prevention Bureau. Pursuant to an Administrative Inspection Warrant issued by this Court on August 14, 2017, on August 25, 2017, my designee inspected the Premises at 128 Emery Street in Portland (the "Property").

The following violations of Chapter 10 of the City of Portland Code of Ordinances were found during that inspection:

1. Storage of a gas grill on outside decks;
2. Failure to label unit doors;
3. Missing smoke and Carbon Monoxide detectors in the basement;
4. Uncovered electrical outlets in the bathroom in Unit 2;
5. Unsealed vertical openings in the front entry way and second floor landing; and
6. Missing fire-rated, self-closing doors in the front and rear egress to each apartment and to the basement.

Dated:

  
\_\_\_\_\_  
Captain John Brennan  
City of Portland Fire Prevention Bureau