

DEAN & ALLYN, INC.

FIRE PROTECTION / SPECIAL HAZARD

116 Lewiston Road
Gray, ME 04039
P-207-657-5646 / F-207-657-5647

August 18, 2016

Attn: Rick Ackerman

Re: 114 Emery St
Portland, ME
Fire Sprinkler Installation Statement of Compliance

Dear Mr. Ackerman,

Thank you for choosing Dean & Allyn, Inc. for your fire protection needs for the referenced project. This letter serves to confirm that the work provided, as described below was performed in accordance with the requirements of NFPA 13D and state & local codes.

Description:

Work performed included the design and installation of a wet automatic fire sprinkler system for single family dwelling using an electric fire pump and dedicated stored water tank per NFPA 13D.

Very truly yours,

Dean & Allyn, Inc.



Derek Narvaez
Project Manager