114 Emery Street

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 03/02/16

Barn sits at SW property line as defined by 1950s era cyclone fence and approx. 58'6" from front of lot

Fire protection:

- There will be no openings in the walls at either side of the building bordered by the property lines.
- IS 5/8 type x firecode sheetrock
- O.S. strip existing clap-boards and replace with "Hardi-Plank" cement board clapboards