CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/02/16

CARRIAGE HOUSE RENOVATION
ACKERMAN RESIDENCE
114 EMERY ST

1ST FLOOR PLAN

¼" = 1'-0"

R Value Walls: R-19
R Value Ceiling: R-30

Floor + Roof Sheathing: 1" thick

Head room first floor: 8'

New header:
- 5 1/2" x 7 1/4" x 48"
- Solid built up (3) 2 x 8" + plywood gusset

John Muldoon - Carpenter
13 Columbus Avenue
South Portland, Maine 04106
(207) 767-2235
Insured