

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

MOIR BRUCE D & ELIZABETH W MOIR JTS

Located at

97 VAUGHAN ST

PERMIT ID: 2015-01987

ISSUE DATE: 09/30/2015

CBL: 062 D004001

has permission to **Construct a garden shed (8' x 10')**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
--	--

N/A

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

Two-family dwelling

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-01987	Date Applied For: 08/14/2015	CBL: 062 D004001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Two- (2-) Family Dwelling		Proposed Project Description: Construct a garden shed (8' x 10')		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 09/30/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Shed is to be painted or stained in the same recessive color scheme as the garage.				
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 09/25/2015
Note: R-4 zone		Ok to Issue: <input checked="" type="checkbox"/>		
Lot size 14,729 sf - meets 6,000 sf min				
Front yard - 25' min, house is 8' scaled off plan - legally nonconf.				
Rear yard - 25' min, house 55' scaled off plan - OK				
Rear yard detached acc str <144 sf - 5' min, proposed shed 8'4" - OK				
Side yard 14' min for 2-story structure, house on line - legally nonconf.				
Side yard 5' min for 1-story shed, proposed shed 17' - OK				
Max lot coverage 30% = 4,419 sf allowed, total existing & proposed = 2,788 sf				
Max height 18', total height of shed 8' - OK				
Conditions:				
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 09/25/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				