

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction:		Owner:		Phone:		Permit No. <b>960277</b>	
Owner Address:		Lessee/Buyer's Name:		Phone:		Business Name:	
Contractor Name:		Address:		Phone:		<div style="border: 2px solid black; padding: 5px; text-align: center;"> <b>PERMIT ISSUED</b>                  Permit Issued:  <b>APR 22 1996</b>  <b>CITY OF PORTLAND</b> </div>	
Past Use:		Proposed Use:		<b>COST OF WORK:</b> \$ _____ <b>PERMIT FEE:</b> \$ _____		<b>INSPECTION:</b> Use Group: <i>AR</i> Type <i>5B</i> Signature: <i>Hoffe</i>	
Proposed Project Description:		<b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied Signature: _____		<b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b> Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		Zone: _____ CBL: _____ Zoning Approval: _____ <b>Special Zone or Reviews:</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By:		Date Applied For:				<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	

- This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**PERMIT ISSUED WITH LETTER**

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT \_\_\_\_\_ ADDRESS: \_\_\_\_\_ DATE: \_\_\_\_\_ PHONE: \_\_\_\_\_


RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE \_\_\_\_\_ PHONE: \_\_\_\_\_

**Historic Preservation**  
 Not in District or Landmark  
 Does Not Require Review  
 Requires Review

Action:  
 Approved  
 Approved with Conditions  
 Denied

Date: \_\_\_\_\_

CEO DISTRICT



COMMENTS

Work complete w/out insp. - unable to  
gain access to prop. do inspect - no  
notification called in for inspections.

Inspection Record

Type

Foundation: \_\_\_\_\_

Framing: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Final: \_\_\_\_\_

Other: \_\_\_\_\_

Date

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Inspection Services  
P. Samuel Hoffses  
Chief



Planning and Urban Development  
Joseph E. Gray Jr.  
Director

**CITY OF PORTLAND**

April 22, 1996

Ken Leigh  
RD# 2, Box 234  
Alfred, Maine 04002

RE: 22 Carroll Street

Dear Sir,

Your application to make interior renovations by extending the floor 2'10" has been reviewed and a permit is herewith issued subject to the requirement listed below. This permit does not excuse the applicant from meeting applicable State and Federal laws.


This permit is being issued with the understanding that the proposed 6'8" headroom be replaced with the required 7'6" headroom.

If you have any questions regarding the requirements, please do not hesitate to contact this office.

Sincerely,



P. Samuel Hoffses  
Chief, Code Enforcement Division



DOOR OPENING

LOAD FROM UPPER FLOOR =  
 PROVIDES DOWN FORCE TO  
 HOLD BOX BEAM IN PLACE

CUT LINE

NEW 6x8

CORNER IN LOFT

BOX BEAM

3'-4"

3'-4"

BEARING WALL

10'-10"

7'-4"

DINING RM


BEDROOM

ELEVATION 1/2" + 1'-0"

EXISTING

Revised

# SECTION @ 1" = 1'-0"



81-3" WINDOW H.

81-4"

LAMINATE / 2 LAYERS 3/4" PLYWOOD  
SCREWS @ 6" O.C. / 5/4

EXIST. PLYWOOD  
SCREW TO BEAM

REMOVE BOX BEAM  
FROM DOOR TO WALL  
\* PROVIDE 6x8 FOR  
SAME OPENING  
10'-10" +/-

5/4 x 4 SCREW / EXIST W.  
GLUE / EXIST W.

61-8"

21-10"

EXISTING 2x6  
3/4" PLYWOOD  
6x8 DOUGLAS FIR.

EXIST. FLOOR+PLY