

Board of Deacons
Williston Church
Walter C. Bevel, — — — — —

December 18, 1944

part of the church building for which you are responsible, but these minor alterations bring to attention the means of egress from this part of the building. They are deficient from the balcony for the reason that while there are two stairways down to the main vestry floor level these stairways are both on one side of the balcony and not very far apart. Thus any emergency which involved quickly the area in the balcony around the top of the two stairways would leave the occupants of the balcony with no way whatever to get out in safety. Thus even though you introduced two widely separated doorways in the larger classroom, the occupants of the room would still have to go toward the balcony hall in order to leave the building.

Just what the situation is at the main vestry floor level I do not know, but I have the impression that there is only one stairway from that second floor level to be considered as an exit. If that is true then you have quite a serious situation as to safety from the standpoint of the people in the balcony classrooms and in the vestry itself.

I recommend and urge that you make plans as soon as possible to relieve this situation. It may be that I am misinterpreting the plans and there has been no time afforded to make an examination. Naturally if you have extensive plans for altering the building, the arrangement of means of egress from this part will be only one feature. I realize that it would be helpful if we of this department could make a thorough examination of the building and make suggestions. In view of the large number of places that need such service that is entirely out of the question. If you can make comprehensive plans of what you propose however, we will be glad to review them and help you to what we may consider a definite improvement for the situation as regards safety.

The three small classrooms next to the small chapel have very small capacities theoretically and there is no need of the doors swinging outward as far as the law is concerned. In fact, the doors swinging into the narrow balcony at that point might constitute an obstruction to others trying to reach the stairway.

Very truly yours,

FSCD/H
CC: Albert W. Knight
38 Byfield Road

Inspector of Buildings



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

PERMIT ISSUED
Permit No. 1-3

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, December 12, 1944
Completed 12/13/44

The undersigned hereby applies for a permit to erect alter, build the following building structure—equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 30 Thomas Street Within Fire Limits? yes Dist. No. 3
Owner's or Lessee's name and address Williston Church Telephone _____
Contractor's name and address A. W. Knight, 36 Byfield Road Telephone 3-3298
Architect _____ Plans filed yes No. of sheets 1
Proposed use of building Church No. families _____
Other buildings on same lot _____
Estimated cost \$ 200. Fee \$ 1.00

Description of Present Building to be Altered

Material brick No. stories 1 1/2 Heat _____ Style of roof _____ Roofing _____
Last use Church No. families _____

General Description of New Work

To close in openings in rear of balcony on both sides as shown on plan (curtain wall)
2x3 studs 16" OC - plasterboard both sides

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? _____
Is any electrical work involved in this work? _____ Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

ORIGINAL

Signature of owner By

Williston Church

A. W. Knight

Permit No. 44/1286

Location 30 Thoma St

Owner Wilbur Church

Date of permit 12/18/44

Notif. closing-in


Inspn. closing-in

Final Notif.

Final Inspn. 3/10/45. 5000

Cert. of Occupancy issued V. J. [Signature]

NOTES



PLAN OF BASEMENT OF WILLISTON CHURCH - PARISH HOUSE
 AT 32 CARROLL STREET
 DATE - 4/2/40 SCALE - 1"=20'

Rept. 6695C-I

April 9, 1940

Mr. Harry G. Eastman,
178 Pleasant Avenue,
Portland, Maine

Dear Mr. Eastman:

The Board of Fire Engineers are unable to approve the permit for the construction of the proposed game room in the basement of Williston Church or Parish House at 82 Carroll Street, because they feel that the means of egress are inadequate.

You are at liberty, of course, to take the matter up directly with Chief Sanborn, but I believe the trouble is that there is only one door leading from the game room and in order to reach the open air from this doorway it is necessary to pass directly by the heating plant in an event. Thus, although theoretically there are two means of leaving the building or reaching the open air, one through the church and one through the parish house, actually persons in the game room would have to be exposed to about the only hazard there is in the place in order to reach either of these exits to the open air.

In addition to the above the exit doors leading from the game room should swing outwards or toward the direction of exit travel, should be at least three feet wide and not less than six feet four inches high. The locksets on these doors should be of such a type that they could never be locked against persons on the inside getting out and all other locks or bolts eliminated.

Will you be kind enough to go over this matter with the people at the church and see what may be done to improve the proposition so that it will satisfy Building Code requirements and receive the approval of the Board of Fire Engineers?

Very truly yours,

WCD/H

Inspector of Buildings

Handwritten notes and signatures:
The undersigned, Harry G. Eastman, is the owner of the premises described above and hereby certifies that the same are in compliance with the provisions of the Building Code of the City of Portland, Maine, and that the same are in compliance with the provisions of the Fire Code of the City of Portland, Maine.
Harry G. Eastman
178 Pleasant Avenue
Portland, Maine



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED
0151
FEB 8 1935

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. Portland, Maine, February 8, 1935

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 32 Thomas Street Use of Building Parish House
Name and address of owner Williston Church, Ward 7
Contractor's name and address Portland Gas Light Co., 5 Temple St. Telephone 2-8321

General Description of Work

To install gas range

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in no If not, which story 1st Kind of Fuel gas
Material of supports of heater or equipment (concrete floor or what kind) wood - 6" above floor
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 8"
from top of smoke pipe over 4' from front of heater over 4' from sides or back of heater 3"
vented to wood which is vented to masonry chimney Other connections to same flue

IF OIL BURNER

Name and type of burner _____ Labeled and approved by Underwriters' Laboratories? _____
Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) _____
Location oil storage _____ No. and capacity of tanks _____
Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc.. 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor Portland Gas Light Co.
By Allen R. Andrews

Ward 7 Permit No 35/151
Loc on 32 Thomas St.
Owner Williston Church
Date of permit 2/8/35

Post Card sent

Notif. for insp.

Approval Tag issued 4/13/35 CAG

(An owner check date)

1. Kind of heat
2. Label
3. Anti-siphon
4. Oil storage
5. Tank distance
6. Vent pipe
7. Fill pipe
8. Gauge
9. Rigidity
10. Feed safety
11. Pipe sizes and material
12. Control valve
13. Ash pit vent
14. Temp. or pressure safety
15. Instruction card
- 16.

NOTES

2/12/35. Range not in
bed. with pipe
completed. etc.

4/13/35. Could not get it. etc.
4/13/35. This range is
not 2" from side
wood on one side.
Mr. Andrews of Gas
Co. said this range
is heavily insulated
and danger from
heat because of
closeness is eliminated
CAG.



APPLICATION FOR PERMIT TO REPAIR BUILDING

Second Class Building

Permit No. 0554
29 1921

To the INSPECTOR OF BUILDINGS, PORTLAND, ME. Portland, Maine, April 28, 1921
The undersigned hereby applies for a permit to repair the following described building in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location St. Thomas Street Ward 7 Within fire limits? yes Dist. No. 3
Owner's name and address St. Thomas Church
Contractor's name and address George A. Clark, 60 Portland St. Telephone 2641-F
Use of building Church and Parsonage
No. stories 1 Height 10 ft., Gross area 1000 sq. ft., Style of roof Gable
Type of present roof covering Shingles

General Description of New Work

To Repair after Fire to former condition. No alterations

If Roof Covering is to be Repaired or Renewed

When last repaired? 1918 Area then repaired 1000 sq. ft.
Are repairs or renewal due to damage by fire? yes If so, what area damaged? 1000 sq. ft.
Area of roof to be repaired now? 1000 sq. ft.
Type of roofing to be used Shingles No. plies 1
Trade name and grade of roof covering to be used Shingles
Estimated cost \$ 4500

INSPECTION COPY

Signature of owner St. Thomas Church
By George A. Clark

Fee \$ 2.75

By G. A. Clark

0554

Ward 7 Permit No. P 31/554
Location 32 Thomas St.
Owner Williston Church
Date of permit 4/22/31
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 6/30/31
Cert. of Occupancy issued None

NOTES

4/22/31 - In one place
they proposed to replace
the roofing with
tar & gravel and will
strengthen joists. They
are now deciding
whether to raise
one side of roof
& if a new chimney
is built. It was
to be removed
outside of there
no change.

4/30/31 - Taking up
section of old floor -
A.G.
Replacing burned
on of floor - A.G.

5/14/31 - Working on
roof A.G.
5/22/31 - Same A.G.
6/10/31 - Setting A.G.
6/19/31 - Plastering A.G.
6/30/31 - Painting A.G.

Tox Family House
#24 Thomas St.

12'0"

concrete walk

Line of 42°

Proposed
Porch

Parish House
of Wollaston Church
#33 Thomas St.

Garage
rear

Hayden Dingwell
1924 Broad Street
Portland Maine
See e, p. 100



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

Portland, Maine, September 14, 1928

Permit No. 1889
SEP 15 1928

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to alter in whole the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 50 Thomas Street Ward 7 Within Fire Limits? Yes Dist. No. 3

Owner's or lessee's name and address Williston Church, Telephone _____

Contractor's name and address Hayden & Wingwell, 192 Broadway St. Telephone 5149

Architect's name and address _____

Proposed use of building Church and Parish House No. families _____

Other buildings on same lot _____

Description of Present Building to be Altered

Material Brick No. stories 2 Heat _____ Style of roof _____ Roofing _____

Last use Church and Parish House No. families _____

General Description of New Work

Old story, frame
to build enclosed/entrance porch 5' x 5'4" 205 rear entrance door to Parish House

If this porch is to be used outdoors for leaning the bldg. or for exit suggest that porch door swing outwards

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation iron posts Thickness, top _____ bottom _____

Material of underpinning _____ Height _____ Thickness _____

Kind of roof shed (flat) Roof covering Asphalt shingles Class C Ord. Lab.

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Distance, heater to chimney _____

If oil burner, name and model _____

Capacity and location of oil tanks _____

Is gas fitting involved? _____ Size of service _____

Corner posts _____ Sills 2x3 Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor 2x6, 2nd _____, 3rd _____, roof 2x4

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Plans filed as part of this application? yes No. sheets 1

Estimated cost \$ 75. Fee \$ 5.

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto

be observed? Yes Williston Church

LECTION COPY

Signature of owner Edward F. Hayden

Ward 7 Permit No. 28/1889

Location 30 Lisman St.

Owner William Chuska

Date of permit Sept. 15/28

Notif. closing-in

Inspn. closing-in


Final Notif.

Final Inspn. 11/13/28 CLB

Cert. of Occupancy issued

NOTES

Not started 10/10/28



26-38
 Thomas St
 8/4/24

Building Department
 City of New York
 100 City Hall
 New York, N.Y.

PERMIT GRANTED

Permit filled out by192.....
 Permit number
 Location

FINAL REPORT

.....192.....
 Has the work been completed in accordance with
 this application and plans filed and approved?

.....
 Law been violated?Doc. No.of 192.....

Nature of violation?

.....
 Violation removed, when?192.....
 Estimated cost of alterations, etc. \$.....

Inspector of Buildings.
 PERMIT MUST BE OBTAINED BEFORE BEGINNING WORK

11 JARVIS ST. N.Y.C. 2196

When project finished or permit expires

912642

Permit # _____ City of Portland BUILDING PERMIT APPLICATION Fee \$10.00 Zone _____ Map # _____ Lot# _____
Please fill out any part which applies to job. Proper plans must accompany form.

Owner: Williston West Church Phone # 774-4060
Address: 32 Thomas St. Portland, Maine
LOCATION OF CONSTRUCTION 32 Thomas St.
Contractor: Les Wilson & Sons (res. permit)
Address: P.O. Box 1028 Westbrook 04098 Phone # 854-4583
Est. Construction Cost: _____ Proposed Use: _____
Past Use: _____
of Existing Res. Units _____ # of New Res. Units _____
Building Dimensions L _____ W _____ Total Sq. Ft. _____
Stories: _____ # Bedrooms _____ Lot Size: _____
Is Proposed Use: Seasonal _____ Condominium _____ Conversion _____
Explain Conversion to remove 1 5,000 gal underground tank

Foundation:

1. Type of Soil: _____
2. Set Backs - Front _____ Rear _____ Side(s) _____
3. Footings Size: _____
4. Foundation Size: _____
5. Other _____

Floor:

1. Sills Size: _____ Sills must be anchored.
2. Girder Size: _____
3. Lally Column Spacing: _____ Size: _____
4. Joists Size: _____ Spacing 16" O.C.
5. Bridging Type: _____ Size: _____
6. Floor Sheathing Type: _____ Size: _____
7. Other Material: _____

Exterior Walls:

1. Studding Size _____ Spacing _____
2. No. windows _____
3. No. Doors _____
4. Header Sizes _____ Span(s) _____
5. Bracing: Yes _____ No _____
6. Corner Posts Size _____
7. Insulation Type _____ Size _____
8. Sheathing Type _____ Size _____
9. Siding Type _____ Weather Exposure _____
10. Masonry Materials _____
11. Metal Materials _____

Interior Walls:

1. Studding Size _____ Spacing _____
2. Header Sizes _____ Span(s) _____
3. Wall Covering Type _____
4. Fire Wall if required _____
5. Other Materials _____

For Official Use Only		PERMIT ISSUED
Date <u>May 21, 1991</u>	Subdivision: _____	MAY 29 1991 CITY OF PORTLAND
Inside Fire Limits _____	Name _____	
Bldg Code _____	Ownership: ☒ Public	
Time Limit _____		
Estimated Cost _____		

Zoning:

Street Frontage Provided: _____
Provided Setbacks: Front _____ Back _____ Side _____ Side _____

Review Required:

Zoning Board Approval: Yes _____ No _____ Date: _____
Planning Board Approval: Yes _____ No _____ Date: _____
Conditions: 1 Use: _____ Variance _____ Site Plan _____ Subdivision _____
Shoreland Zoning Yes _____ No _____ Floodplain Yes _____ No _____
Special Exception _____
Other (Explain) CH 6-107-7-5-27-71

Ceiling:

1. Ceiling Joists Size: _____
2. Ceiling Strapping Size _____ Spacing _____ North District nor Landmark
3. Type Ceilings: _____ Does not require review
4. Insulation Type _____ Size _____ Requires Review
5. Ceiling Height: _____

Roof:

1. Trusses or Rafter Size _____ Span 39.0' Action: Approved
2. Sheathing Type _____ Size _____ Approved with Conditions
3. Roof Covering Type _____ Asph/Flt

Chimneys:

Type: _____ Number of Fire Places _____ Date: 5/21/91
Signature: [Signature]

Heating:

Type of Heat: _____

Electrical:

Service Entrance Size: _____ Smoke Detector Required Yes _____ No _____

Plumbing:

1. Approval of soil test if required has been done Yes _____ No _____
2. No. of Tubs or Showers _____
3. No. of Flushes _____
4. No. of Lavatories _____
5. No. of Other Fixtures _____

Swimming Pools:

1. Type: _____
2. Pool Size: _____ x _____ Square Footage _____
3. Must conform to National Electrical Code and State Law.

Permit Received By:

Latini agent for church Date 5/21/91

Signature of Applicant [Signature] Ron Wilson

Signature of CEO [Signature] Date 5/21/91

Inspection Dates _____

1991 .15 yam

White-Tax Assessor

Yellow GPCOG


White Tag - CEO

© Copyright GPCOG 1988

PLOT PLAN

Completed 10/11/91

N
▲



FEES (Breakdown From Front)

Base Fee \$ 10.00
 Subdivision Fee \$ _____
 Site Plan Review Fee \$ _____
 Other Fees \$ _____
 (Explain) _____
 Late Fee \$ _____

Inspection Record

Type

Date

_____	_____
_____	_____
_____	_____
_____	_____
_____	_____

COMMENTS

DEC form submitted

Signature of Applicant *R. M. Williams Agent for Owner*

Date May 21, 1991

BUILDING PERMIT REPORT

DATE: 5-28-91

ADDRESS: 32 Thomas St.

REASON FOR PERMIT: Underground Tank Removal ~~Installation~~

1- 5000 gal fuel

BUILDING OWNER: Williston West Church.

CONTRACTOR: Les Wilson + Son

PERMIT APPLICANT: Pon Wilson

APPROVED: KDD ~~DENIED~~

CONDITION OF APPROVAL OR DENIAL:

- ✓ (1) All underground tank removal and/or installation shall be done in accordance with Department of Environmental Protection Regulations Chapter 691
- ✓ (2) No cutting of tanks on site. Cutting of tanks to be done at an approved tank disposal site.
- ✓ (3) Fire Dispatcher must be notified 48 hours in advance of removal and/or transportation of tanks.

COPY

Maine Departmental of Environmental Protection
Bureau of Oil & Hazardous Materials Control
State House Station #17, Augusta, Maine 04333
Telephone: 207-289-2651
Attn: Tank Removal Notice

NOTICE OF INTENT
TO ABANDON (REMOVE) AN
UNDERGROUND OIL STORAGE FACILITY

Name of Facility Owner: WILSON WEST Church
Mailing Address: 32 Thomas St Telephone No: 774 4061
City: Portland State: ME Zip Code: 04102
Contact Person (name, address & telephone no.): Beth Davis

Name of Facility: SAMP Registration No.: 12172
Facility Location: SAMP

1. Identify the tanks at this location which are to be removed:

	Tank Number	Age of Tank (Years)	Tank Size (Gallons)	Type of Product Most Recently Stored
A.	1	30	5000	Fuel
B.				
C.				
D.				

2. Directions to Facility (be specific):

off Pine St - Portland, ME

3. Is tank(s) used for the storage of Class I liquids (e.g. gasoline, jet fuel)? Yes ☐ No ☒ (IF YES, REMOVAL OF THE TANK MUST BE UNDER THE DIRECTION OF A CERTIFIED TANK INSTALLER OR PROFESSIONAL FIREFIGHTER.)

4. Name and telephone number of contractor who will do the tank removal: LS Wilson Sons 854 4583

Certified Tank Installer Certification Number & Name (if applicable):

N/A

Professional Firefighter Yes ☐ No ☒ (Affiliation: _____)

5. Expected date of removal: JUNE 21, 1991

I hereby provide Notice that I intend to properly abandon the underground oil storage facility as described above.

Date: 5/20/91

Ronald Wilson Rep.
Signature of Tank Owner or Operator

Ronald Wilson Rep
Printed Name and Title

THIS FORM MUST BE FILED WITH THE DEPARTMENT AND LOCAL FIRE DEPARTMENT 30 DAYS PRIOR TO REMOVAL - RETURN POSTCARD WHEN TANK(S) HAS BEEN REMOVED.

Mail original and yellow copy to DEP; pink copy to fire dept.; retain gold copy

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

September 21, 1992


RE: 32 Thomas St.

Reverend Eric Kelly
35 Thomas Street
Portland, Maine 04102

Dear Reverend Kelly,

This office has received a complaint regarding the multiple uses of the property at 32 Thomas Street in Portland. It is necessary that I review the various uses at this address and determine whether they comply with the City's Land Use Code. Please call so we can schedule an appointment to discuss this matter. I can be reached at 874-8300 Ext. 8695.

Sincerely,


William D. Giroux
Zoning Administrator

/el

cc: Joseph E. Gray, Jr., Director of Planning and Urban Development
P. Samuel Hoffses, Chief of Inspection Services
Kathy Lowe, Code Enforcement Officer

PLUMBING APPLICATION

Department of Human Services
Division of Health Engineering
(207) 283-3826

PROPERTY ADDRESS

Town Or Plantation: Portland

Street Subdivision Lot #: 28 Thomas St.

PROPERTY OWNERS NAME

Last: McKee Sr. First: John

Applicant Name: Ronald E. Leonard

Mailing Address of Owner/Applicant (If Different): 86 Main St. Raymond, Me. 04071

PORTLAND

4746 TOWN COPY

Date Permit Issued: 12/31/93 \$ 4.47 FEE ☐ Double Fee Charged

Local Plumbing Inspector Signature: [Signature] L.P.I. # 01241

Chief Plumbing Inspector

Owner/Applicant Statement

I certify that the information submitted is correct to the best of my knowledge and understand that any falsification is reason for the Local Plumbing Inspector to deny a Permit.

Signature of Owner/Applicant: [Signature] Date: 3-31-93

Caution: Inspection Required

I have inspected the installation authorized above and found it to be in compliance with the Maine Plumbing Rules.

Local Plumbing Inspector Signature: Kathy Lowe Date Approved: 6-30-93

PERMIT INFORMATION

This Application is for:

1. ☒ NEW PLUMBING

2. ☒ RELOCATED PLUMBING

Type Of Structure To Be Served:

1. ☐ SINGLE FAMILY DWELLING

2. ☐ MODULAR OR MOBILE HOME

3. ☒ MULTIPLE FAMILY DWELLING

4. ☐ OTHER - SPECIFY _____

Plumbing To Be Installed By:

1. ☒ MASTER PLUMBER

2. ☐ OIL BURNERMAN

3. ☐ MFG'D. HOUSING DEALER/MECHANIC

4. ☐ PUBLIC UTILITY EMPLOYEE

5. ☐ PROPERTY OWNER

LICENSE # 106,456

Hook-Up & Piping Relocation Maximum of 1 Hook-Up	Number	Column 2 Type of Fixture	Number	Column 1 Type of Fixture
HOOK-UP: to public sewer in those cases where the connection is not regulated and inspected by the local Sanitary District.		Hosebib / Sillcock	<u>03</u>	Bathtub (and Shower)
		Floor Drain	<u>01</u>	Shower (Separate)
OR		Urinal	<u>02</u>	Sink
		Drinking Fountain	<u>05</u>	Wash Basin
HOOK-UP: to an existing subsurface wastewater disposal system.		Indirect Waste	<u>04</u>	Water Closet (Toilet)
		Water Treatment Softener, Filter, etc.		Clothes Washer
PIPING RELOCATION: of sanitary lines, drains, and piping without new fixtures.		Grease/Oil Separator	<u>02</u>	Dish Washer
		Dental Cuspidor		Garbage Disposal
Number of Hook-Ups & Relocations		Bidet		Laundry Tub
		Other: _____		Space Heater
Hook-Up & Relocation Fee		Fixtures (Subtotal) Column 2	<u>1.7</u>	Fixtures (Subtotal) Column 1
			<u>0.0</u>	Fixtures (Subtotal) Column 2
			<u>1.7</u>	Total Fixtures
			\$	Fixture Fee
			\$	Hook-Up & Relocation Fee
			\$ <u>44.00</u>	Permit Fee (Total)

SEE PERMIT FEE SCHEDULE FOR CALCULATING FEE

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

September 23, 1993


RE: Williston West Church

Reverend Eric Kelly
32 Thomas St.
Portland, Maine 04102

Dear Reverend Kelly,

This letter is in reference to the professional offices you operate at Williston West Church in Portland. It was my expectation that following the withdrawal of your Conditional Use application you would have eliminated the professional office uses. We recently received another complaint indicating those offices are still there. These offices have not received review and approval under the applicable codes and ordinances and may not be in compliance with the Land Use Code as well as health and safety codes. It is necessary that you apply for a permit within 15 days from date of this letter. Failure to do so will result in my referral of this matter to the City's Corporation Counsel for consideration of legal action.

Sincerely,


William D. Giroux
Zoning Administrator

/el

cc: Joseph E. Gray, Jr., Director of Planning and Urban Development
P. Samuel Hoffses, Chief of Inspection Services
Marge Schmuckal, Asst. Chief of Inspection Services
Kathy Lowe, Code Enforcement Officer
LT. Gaylen McDougall, Fire Prevention Bureau

City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 32 Thomas St		Owner: Willeston-West Church		Phone:		Permit No: 960741	
Owner Address: 32 Thomas St - Portland ME 04102		Leasee/Buyer's Name:		Phone:		Business Name:	
Contractor Name: Sewall Assoc Inc		Address: Box 6610- Portland ME 04101		Phone: 774-4755		PERMIT ISSUED JUL 29 1996 CITY OF PORTLAND	
Past Use: church		Proposed Use: church w intr renvtns		COST OF WORK: \$ 29,500		PERMIT FEES: \$ 170	
				FIRE DEPT. ☒ Approved ☐ Denied		INSPECTION: Use Group: #3 Type: 3B	
Proposed Project Description: interior renovations		Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>		Zone: R-4 CBL: 62-E-5	
Permit Taken By: L Chase		Date Applied For: 7/25/96		Signature: <i>[Signature]</i>		Date: 7/25/96	
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: ☐ Approved ☐ Approved with Conditions ☐ Denied		Zoning Approval: <i>use to remain the same - any changes of Special Zone or Reviews:</i> ☐ Shoreland use shall req ☐ Wetland A Sep. permit ☐ Flood Zone <i>OK</i> ☐ Subdivision <i>7/25/96</i> ☐ Site Plan <i>major</i> ☐ minor ☐ minor	

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

**PERMIT ISSUED
WITH LETTER**

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: *[Signature]* ADDRESS: **7/25/96** DATE: **774 4755** PHONE: **774 4755**

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: _____ PHONE: _____

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

Zoning Appeal

☐ Variance
☐ Miscellaneous
☐ Conditional Use
☐ Interpretation
☐ Approved
☐ Denied

Historic Preservation

☐ Not in District or Landmark
☐ Does Not Require Review
☐ Requires Review

Action: *alternately; no exterior*
☐ Approved *approved with this permit.*
☐ Approved with Conditions
☐ Denied

Date: **7/25/96**

CEO DISTRICT **3**
N. POWERS