

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : THOMAS STREET APARTMENTS
Building : WOOD STRUCTURE
Location : ATTIC #1
System : 2
Contract : C16021
Data File : THOMAS ST APT- ATTIC-C.WXF

Hydraulic Design Information Sheet

Name - 32 THOMAS STREET APARTMENTS Date - 8/23/16
 Location - ATTIC #1
 Building - WOOD STRUCTURE System No. - 2
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16021
 Calculated By - T. PRAY Drawing No. - 1 OF 2
 Construction: (X) Combustible () Non-Combustible Ceiling Height - VARIES
 Occupancy - UNUSED ATTIC SPACE

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E
 M Area of Sprinkler Operation - 1615 System Type Sprinkler/Nozzle
 Density - .1 () Wet Make VIKING
 D Area Per Sprinkler - 120 (X) Dry Model VK300
 E Elevation at Highest Outlet - 137.92 () Deluge Size 1/2"
 S Hose Allowance - Inside - () Preaction K-Factor 5.6
 I Rack Sprinkler Allowance - () Other Temp.Rat.200
 G Hose Allowance - Outside - 100

N Note

Calculation Flow Required - 509.24 Press Required - 48.16 AT TEST
 Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - 8/22/16 Cap. -
 T Time of Test - 11:30 AM Rated Cap.- Elev.-
 E Static Press - 51 @ Press -
 R Residual Press - 49 Elev. - Well
 Flow - 903 Proof Flow
 S Elevation - 100

U Location - HYDRANTS ARE LOCATED ON THOMAS STREET, SEE PLOT PLAN

P Source of Information - PORTLAND WATER DISTRICT

Y
 C Commodity Class Location
 O Storage Ht. Area Aisle W.
 M Storage Method: Solid Piled % Palletized % Rack
 M
 () Single Row () Conven. Pallet () Auto. Storage () Encap.
 S R () Double Row () Slave Pallet () Solid Shelf () Non
 T A () Mult. Row () Open Shelf
 O C

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:
 E

Water Supply Curve (C)

Residential Fire Protection
THOMAS STREET APARTMENTS


Page 2
Date 8/23/2016

City Water Supply:

C1 - Static Pressure : 51
C2 - Residual Pressure: 49
C2 - Residual Flow : 903

Demand:

D1 - Elevation : 20.464
D2 - System Flow : 409.257
D2 - System Pressure : 48.163
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 509.257
Safety Margin : 2.144



Fittings Used Summary

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 3
Date 8/23/2016

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
D	Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 4
Date 8/23/2016

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
SP01	146.71	5.6	7.0	na	14.82	0.1	120	7.0
SP02	146.71	5.6	7.0	na	14.82	0.1	120	7.0
1	137.92	5.6	11.18	na	18.72	0.1	120	7.0
19	137.92	5.6	11.21	na	18.75	0.1	120	7.0
22	137.92	5.6	10.81	na	18.41	0.1	120	7.0
21	137.92	5.6	10.86	na	18.45	0.1	120	7.0
20	137.92	5.6	10.98	na	18.56	0.1	120	7.0
20A	137.92		11.43	na				
50	135.92		13.3	na				
2	140.42		11.25	na				
3	140.42		11.25	na				
4	140.42	5.6	11.25	na	18.79	0.1	120	7.0
5	144.42		9.5	na				
6	144.42		9.5	na				
7	144.42	5.6	9.5	na	17.26	0.1	120	7.0
8	144.42	5.6	9.5	na	17.26	0.1	120	7.0
52	144.42		9.55	na				
53	146.71		8.62	na				
9	140.42		11.24	na				
10	140.42		11.24	na				
11	140.42	5.6	11.24	na	18.77	0.1	120	7.0
54	135.92		13.63	na				
55	135.92		13.68	na				
12	137.92	5.6	8.58	na	16.41	0.1	120	7.0
13	137.92	5.6	8.61	na	16.43	0.1	120	7.0
14	137.92	5.6	8.77	na	16.58	0.1	120	7.0
15	137.92	5.6	8.96	na	16.76	0.1	120	7.0
16	137.92	5.6	9.36	na	17.13	0.1	120	7.0
31	137.92	5.6	9.18	na	16.97	0.1	120	7.0
36	137.92	5.6	9.21	na	16.99	0.1	120	7.0
18	137.92	5.6	9.31	na	17.09	0.1	120	7.0
17	137.92	5.6	9.65	na	17.39	0.1	120	7.0
16A	137.92		10.31	na				
23	144.42		9.51	na				
24	144.42		9.51	na				
25	144.42		9.51	na				
26	144.42		9.51	na				
27	144.42		9.51	na				
28	144.42		9.51	na				
29	144.42	K = K @ EQ01	9.51	na	16.58			
30	144.42	K = K @ EQ02	9.51	na	16.57			
58	144.42		9.55	na				
59	135.92		13.48	na				
32	147.25	5.6	7.0	na	14.82	0.1	120	7.0
33	147.25	5.6	7.02	na	14.84	0.1	120	7.0
34	147.25	5.6	7.03	na	14.85	0.1	120	7.0
35	147.25	5.6	7.05	na	14.87	0.1	120	7.0
60	147.25		7.18	na				
61	135.92		13.54	na				
62	135.92		13.93	na				
63	136.5		14.47	na				
TOR1	101.88		36.4	na				
DPV	97.88		39.63	na				
HDR1	97.88		41.29	na				
HDR	97.88		41.38	na				
BFP	97.88		41.4	na				
6UG	97.88		48.52	na				
TEST	100.0		48.16	na	100.0			

The maximum velocity is 13.32 and it occurs in the pipe between nodes 16A and 55

Final Calculations - Hazen-Williams

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 5
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SP01 to EQ01	14.82	1.049 120 0.0748	1E 1T	2.0 5.0 0.0	1.000 7.000 8.000	7.000 0.0 0.598			K Factor = 5.60	
	0.0								Vel = 5.50	
	14.82					7.598			K Factor = 5.38	
SP02 to EQ02	14.82	1.049 120 0.0748	1E 1T	2.0 5.0 0.0	1.000 7.000 8.000	7.000 0.0 0.598			K Factor = 5.60	
	0.0								Vel = 5.50	
	14.82					7.598			K Factor = 5.38	
1 to 19	18.72	2.157 100		0.0 0.0	7.500 0.0	11.178 0.0			K Factor = 5.60	
	18.72	0.0048		0.0	7.500	0.036			Vel = 1.64	
19 to 20A	18.76	2.157 100	1T	8.783 0.0	3.750 8.783	11.214 0.0			K Factor = 5.60	
	37.48	0.0174		0.0	12.533	0.218			Vel = 3.29	
	0.0									
	37.48					11.432			K Factor = 11.09	
22 to 21	18.41	2.157 100	1E	4.392 0.0	6.210 4.391	10.807 0.0			K Factor = 5.60	
	18.41	0.0046		0.0	10.601	0.049			Vel = 1.62	
21 to 20	18.45	2.157 100		0.0 0.0	7.460 0.0	10.856 0.0			K Factor = 5.60	
	36.86	0.0169		0.0	7.460	0.126			Vel = 3.24	
20 to 20A	18.56	2.157 100	1T	8.783 0.0	3.750 8.783	10.982 0.0			K Factor = 5.60	
	55.42	0.0359		0.0	12.533	0.450			Vel = 4.87	
20A to 50	37.47	2.157 100	1T	8.783 0.0	2.000 8.783	11.432 0.866				
	92.89	0.0934		0.0	10.783	1.007			Vel = 8.16	
50 to 53	-119.22	4.26 100	1I	6.578 0.0	24.250 6.578	13.305 -4.673				
	-26.33	-0.0004		0.0	30.828	-0.011			Vel = 0.59	
	0.0									
	-26.33					8.621			K Factor = -8.97	
2 to 3	0.0	2.157 100		0.0 0.0	8.000 0.0	11.253 0.0				
	0.0	0.0		0.0	8.000	0.0			Vel = 0	
3 to 4	0.0	2.157 100		0.0 0.0	8.000 0.0	11.253 0.0				
	0.0	0.0		0.0	8.000	0.0			Vel = 0	
4 to 53	18.79	2.157 100	1E 1T	4.392 8.783	5.920 13.174	11.253 -2.724			K Factor = 5.60	
	18.79	0.0048		0.0	19.094	0.092			Vel = 1.65	
	0.0									
	18.79					8.621			K Factor = 6.40	
5 to 6	0.0	2.157 100		0.0 0.0	7.000 0.0	9.504 0.0				
	0.0	0.0		0.0	7.000	0.0			Vel = 0	

Final Calculations - Standard

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 6
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
6	0.0	2.157		0.0	7.000	9.504				
to		100		0.0	0.0	0.0				
7	0.0	0.0		0.0	7.000	0.0		Vel = 0		
7	17.26	2.157	1T	8.783	3.000	9.504		K Factor = 5.60		
to		100		0.0	8.783	0.0				
52	17.26	0.0042		0.0	11.783	0.049		Vel = 1.52		
	0.0									
	17.26					9.553		K Factor = 5.58		
8	17.26	2.157	1T	8.783	4.000	9.500		K Factor = 5.60		
to		100		0.0	8.783	0.0				
52	17.26	0.0041		0.0	12.783	0.053		Vel = 1.52		
52	17.26	2.157		0.0	4.000	9.553				
to		100		0.0	0.0	-0.992				
53	34.52	0.0150		0.0	4.000	0.060		Vel = 3.03		
53	11.23	2.157	1T	8.783	4.500	8.621				
to		100		0.0	8.783	4.673				
54	45.75	0.0252		0.0	13.283	0.335		Vel = 4.02		
	0.0									
	45.75					13.629		K Factor = 12.39		
9	0.0	2.157		0.0	8.000	11.238				
to		100		0.0	0.0	0.0				
10	0.0	0.0		0.0	8.000	0.0		Vel = 0		
10	0.0	2.157		0.0	8.000	11.238				
to		100		0.0	0.0	0.0				
11	0.0	0.0		0.0	8.000	0.0		Vel = 0		
11	18.77	2.157	1E	4.392	8.950	11.238		K Factor = 5.60		
to		100	1T	8.783	13.174	-2.724				
53	18.77	0.0048		0.0	22.124	0.107		Vel = 1.65		
	0.0									
	18.77					8.621		K Factor = 6.39		
54	45.75	4.26	1I	6.578	43.960	13.629				
to		100		0.0	6.578	0.0				
55	45.75	0.0009		0.0	50.538	0.046		Vel = 1.03		
55	151.76	4.26	1I	6.578	12.370	13.675				
to		100		0.0	6.578	0.0				
62	197.51	0.0137		0.0	18.948	0.260		Vel = 4.45		
	0.0									
	197.51					13.935		K Factor = 52.91		
12	16.41	2.157		0.0	8.000	8.583		K Factor = 5.60		
to		100		0.0	0.0	0.0				
13	16.41	0.0038		0.0	8.000	0.030		Vel = 1.44		
13	16.43	2.157	1E	4.392	7.080	8.613		K Factor = 5.60		
to		100		0.0	4.391	0.0				
14	32.84	0.0136		0.0	11.471	0.156		Vel = 2.88		
14	16.58	2.157		0.0	6.500	8.769		K Factor = 5.60		
to		100		0.0	0.0	0.0				
15	49.42	0.0291		0.0	6.500	0.189		Vel = 4.34		

Final Calculations - Standard

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 7
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
15 to 16	16.76 66.18	2.157 100 0.0499		0.0 0.0 0.0	8.000 0.0 8.000	8.958 0.0 0.399			K Factor = 5.60 Vel = 5.81	
16 to 16A	17.13 83.31	2.157 100 0.0764	1T	8.783 0.0 0.0	3.750 8.783 12.533	9.357 0.0 0.957			K Factor = 5.60 Vel = 7.31	
	0.0 83.31					10.314			K Factor = 25.94	
31 to 36	16.97 16.97	2.157 100 0.0040		0.0 0.0 0.0	7.170 0.0 7.170	9.180 0.0 0.029			K Factor = 5.60 Vel = 1.49	
36 to 18	16.99 33.96	2.157 100 0.0145		0.0 0.0 0.0	7.170 0.0 7.170	9.209 0.0 0.104			K Factor = 5.60 Vel = 2.98	
18 to 17	17.09 51.05	2.157 100 0.0309	1E	4.392 0.0 0.0	6.500 4.391 10.891	9.313 0.0 0.336			K Factor = 5.60 Vel = 4.48	
17 to 16A	17.39 68.44	2.157 100 0.0531	1T	8.783 0.0 0.0	3.750 8.783 12.533	9.649 0.0 0.665			K Factor = 5.60 Vel = 6.01	
16A to 55	83.32 151.76	2.157 100 0.2314	1T	8.783 0.0 0.0	2.000 8.783 10.783	10.314 0.866 2.495			Vel = 13.32	
	0.0 151.76					13.675			K Factor = 41.04	
50 to 59	119.23 119.23	4.26 100 0.0054	1I	6.578 0.0 0.0	25.210 6.578 31.788	13.305 0.0 0.171			Vel = 2.68	
	0.0 119.23					13.476			K Factor = 32.48	
23 to 24	0.0 0.0	2.157 100 0.0		0.0 0.0 0.0	7.210 0.0 7.210	9.509 0.0 0.0			Vel = 0	
24 to 25	0.0 0.0	2.157 100 0.0		0.0 0.0 0.0	7.000 0.0 7.000	9.509 0.0 0.0			Vel = 0	
25 to 26	0.0 0.0	2.157 100 0.0		0.0 0.0 0.0	5.500 0.0 5.500	9.509 0.0 0.0			Vel = 0	
26 to 27	0.0 0.0	2.157 100 0.0		0.0 0.0 0.0	8.000 0.0 8.000	9.509 0.0 0.0			Vel = 0	
27 to 28	0.0 0.0	2.157 100 0.0		0.0 0.0 0.0	7.000 0.0 7.000	9.509 0.0 0.0			Vel = 0	
28 to 29	0.0 0.0	2.157 100 0.0		0.0 0.0 0.0	6.000 0.0 6.000	9.509 0.0 0.0			Vel = 0	

Final Calculations - Standard

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 8
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
29 to 58	16.58	2.157 100	1T	8.783 0.0	3.040 8.783	9.509 0.0			K Factor @ node EQ01	
	16.58	0.0039		0.0	11.823	0.046			Vel = 1.46	
	0.0 16.58					9.555			K Factor = 5.36	
30 to 58	16.57	2.157 100	1T	8.783 0.0	3.580 8.783	9.507 0.0			K Factor @ node EQ02	
	16.57	0.0039		0.0	12.363	0.048			Vel = 1.45	
58 to 59	16.58	2.157 100	1T	8.783 0.0	8.500 8.783	9.555 3.681				
	33.15	0.0139		0.0	17.283	0.240			Vel = 2.91	
59 to 61	119.23	4.26 100		0.0 0.0	7.050 0.0	13.476 0.0				
	152.38	0.0085		0.0	7.050	0.060			Vel = 3.43	
	0.0 152.38					13.536			K Factor = 41.42	
32 to 33	14.82	2.157 100		0.0 0.0	7.170 0.0	7.000 0.0			K Factor = 5.60	
	14.82	0.0031		0.0	7.170	0.022			Vel = 1.30	
33 to 60	14.84	2.157 100	1T	8.783 0.0	4.790 8.783	7.022 0.0			K Factor = 5.60	
	29.66	0.0113		0.0	13.573	0.154			Vel = 2.60	
	0.0 29.66					7.176			K Factor = 11.07	
34 to 35	14.84	2.157 100		0.0 0.0	7.170 0.0	7.027 0.0			K Factor = 5.60	
	14.84	0.0032		0.0	7.170	0.023			Vel = 1.30	
35 to 60	14.87	2.157 100	1T	8.783 0.0	2.330 8.783	7.050 0.0			K Factor = 5.60	
	29.71	0.0113		0.0	11.113	0.126			Vel = 2.61	
60 to 61	29.66	2.157 100	1E 1T	4.392 8.783	22.460 13.174	7.176 4.907				
	59.37	0.0408		0.0	35.634	1.453			Vel = 5.21	
61 to 62	152.38	4.26 100	1J	15.036 0.0	10.580 15.035	13.536 0.0				
	211.75	0.0156		0.0	25.615	0.399			Vel = 4.77	
62 to 63	197.51	4.26 100	2I	13.156 0.0	1.830 13.157	13.935 -0.251				
	409.26	0.0527		0.0	14.987	0.790			Vel = 9.21	
63 to TOR1	0.0	4.26 100	8I 1J	52.625 15.036	63.870 67.660	14.474 14.994				
	409.26	0.0527		0.0	131.530	6.936			Vel = 9.21	
TOR1 to DPV	0.0	4.26 100	1D	26.313 0.0	2.000 26.313	36.404 1.732				
	409.26	0.0528		0.0	28.313	1.494			Vel = 9.21	
DPV to HDR1	0.0	4.26 120	1B 1T	15.8 26.334	2.000 42.134	39.630 0.0				
	409.26	0.0376		0.0	44.134	1.661			Vel = 9.21	

Final Calculations - Standard

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 9
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HDR1 to HDR	0.0 409.26	4.26 120 0.0376	0.0 0.0 0.0	2.500 0.0 2.500	41.291 0.0 0.094		Vel = 9.21		
HDR to BFP	0.0 409.26	4.26 120 0.0380	0.0 0.0 0.0	0.500 0.0 0.500	41.385 0.0 0.019		Vel = 9.21		
BFP to 6UG	0.0 409.26	4.26 120 0.0377	0.0 0.0 0.0	3.000 0.0 3.000	41.404 7.000 0.113		* Fixed loss = 7 Vel = 9.21		
6UG to TEST	0.0 409.26	6.16 140 0.0047	1L 12.911 1G 4.304 1T 43.037	60.000 60.252 120.252	48.517 -0.918 0.564		Vel = 4.41		
	100.00 509.26				48.163		Qa = 100.00 K Factor = 73.38		