

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : THOMAS STREET APARTMENTS
Building : WOOD STRUCTURE
Location : ATTIC #2
System : 2
Contract : C16021
Data File : THOMAS ST APT- ATTIC#2.WXF

Hydraulic Design Information Sheet

Name - 32 THOMAS STREET APARTMENTS Date - 8/23/16
 Location - ATTIC #2
 Building - WOOD STRUCTURE System No. - 2
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16021
 Calculated By - T. PRAY Drawing No. - 1 OF 2
 Construction: (X) Combustible () Non-Combustible Ceiling Height - VARIES
 Occupancy - UNUSED ATTIC SPACE

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation - 338	System Type	Sprinkler/Nozzle
	Density - .1	() Wet	Make VIKING
D	Area Per Sprinkler - 120	(X) Dry	Model VK300
E	Elevation at Highest Outlet - 137.92	() Deluge	Size 1/2"
S	Hose Allowance - Inside -	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance -	() Other	Temp.Rat.200
G	Hose Allowance - Outside - 100		

N Note

Calculation Flow Required - 223.29 Press Required - 46.24 AT TEST
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 8/22/16		Cap. -
T	Time of Test - 11:30 AM	Rated Cap.-	Elev.-
E	Static Press - 51	@ Press -	
R	Residual Press - 49	Elev. -	Well
S	Flow - 903		Proof Flow
U	Elevation - 100		

P Location - HYDRANTS ARE LOCATED ON THOMAS STREET, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
THOMAS STREET APARTMENTS


Page 2
Date 8/23/2016

City Water Supply:

C1 - Static Pressure : 51
C2 - Residual Pressure: 49
C2 - Residual Flow : 903

Demand:

D1 - Elevation : 16.315
D2 - System Flow : 123.294
D2 - System Pressure : 46.239
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 223.294
Safety Margin : 4.610



Fittings Used Summary

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 3
Date 8/23/2016

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
D	Generic Dry Pipe Valve	0	0	0	0	0	0	9.5	17	0	28	0	47	0	0	0	0	0	0	0	0
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 4
Date 8/23/2016

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
200	131.67	5.6	11.52	na	19.01	0.1	149	7.0
201	131.67	5.6	11.7	na	19.15	0.1	149	7.0
202	137.67	5.6	7.08	na	14.9	0.1	149	7.0
203	137.67	5.6	7.77	na	15.61	0.1	149	7.0
204	137.67	5.6	7.81	na	15.65	0.1	149	7.0
205	131.83	5.6	12.02	na	19.41	0.1	149	7.0
206	131.83	5.6	12.2	na	19.56	0.1	149	7.0
220	131.67		12.89	na				
221	137.67		8.58	na				
222	131.83		13.44	na				
230	128.04		15.88	na				
231	128.04		16.0	na				
232	128.04		16.5	na				
TOR1	101.88		38.0	na				
DPV	97.88		39.89	na				
HDR1	97.88		40.07	na				
HDR	97.88		40.08	na				
BFP	97.88		40.08	na				
6UG	97.88		47.1	na				
TEST	100.0		46.24	na	100.0			

The maximum velocity is 9.9 and it occurs in the pipe between nodes 221 and 231

Final Calculations - Hazen-Williams

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 5
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
200 to 220	19.01	1.049 100	1T	3.568 0.0	4.670 3.568	11.521 0.0			K Factor = 5.60	
	19.01	0.1659		0.0	8.238	1.367			Vel = 7.06	
	0.0 19.01						12.888		K Factor = 5.30	
201 to 220	19.15	1.049 100	1T	3.568 0.0	3.500 3.568	11.698 0.0			K Factor = 5.60	
	19.15	0.1684		0.0	7.068	1.190			Vel = 7.11	
	0.0 19.15						12.888		K Factor = 5.33	
202 to 203	14.90	1.049 100		0.0 0.0	6.500 0.0	7.079 0.0			K Factor = 5.60	
	14.9	0.1058		0.0	6.500	0.688			Vel = 5.53	
203 to 221	15.61	1.38 100	1T	4.282 0.0	3.460 4.282	7.767 0.0			K Factor = 5.60	
	30.51	0.1048		0.0	7.742	0.811			Vel = 6.54	
	0.0 30.51						8.578		K Factor = 10.42	
204 to 221	15.65	1.049 100	1T	3.568 0.0	3.040 3.568	7.812 0.0			K Factor = 5.60	
	15.65	0.1159		0.0	6.608	0.766			Vel = 5.81	
	0.0 15.65						8.578		K Factor = 5.34	
205 to 222	19.41	1.049 100	1T	3.568 0.0	4.670 3.568	12.017 0.0			K Factor = 5.60	
	19.41	0.1725		0.0	8.238	1.421			Vel = 7.21	
	0.0 19.41						13.438		K Factor = 5.29	
206 to 222	19.56	1.049 100	1T	3.568 0.0	3.500 3.568	12.201 0.0			K Factor = 5.60	
	19.56	0.1750		0.0	7.068	1.237			Vel = 7.26	
	0.0 19.56						13.438		K Factor = 5.34	
220 to 230	38.16	1.38 100	1T	4.282 0.0	4.670 4.282	12.888 1.572				
	38.16	0.1585		0.0	8.952	1.419			Vel = 8.19	
	0.0 38.16						15.879		K Factor = 9.58	
221 to 231	46.16	1.38 100	1T	4.282 0.0	10.170 4.282	8.578 4.171				
	46.16	0.2253		0.0	14.452	3.256			Vel = 9.90	
	0.0 46.16						16.005		K Factor = 11.54	
222 to 232	38.97	1.38 100	1T	4.282 0.0	4.330 4.282	13.438 1.641				
	38.97	0.1649		0.0	8.612	1.420			Vel = 8.36	
	0.0									

Final Calculations - Standard

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 6
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	38.97					16.499			K Factor = 9.59	
230 to 231	38.16	2.157 100		0.0	7.000	15.879				
231 to 232	38.16	0.0180		0.0	7.000	0.126			Vel = 3.35	
231 to 232	46.16	2.157 100		0.0	6.330	16.005				
232 to TOR1	84.32	0.0780		0.0	6.330	0.494			Vel = 7.40	
232 to TOR1	38.97	2.635 100	14I 1T	82.303 11.758	76.960 94.061	16.499 11.330				
TOR1 to DPV	123.29	0.0594		0.0	171.021	10.167			Vel = 7.25	
TOR1 to DPV	0.0	4.26 100	1D	26.313	2.000	37.996				
DPV to HDR1	123.29	0.0058		0.0	28.313	0.163			Vel = 2.78	
DPV to HDR1	0.0	4.26 120	1B 1T	15.8 26.334	2.000 42.134	39.891 0.0				
HDR1 to HDR	123.29	0.0041		0.0	44.134	0.181			Vel = 2.78	
HDR1 to HDR	0.0	4.26 120		0.0	2.500	40.072				
HDR to BFP	123.29	0.0040		0.0	2.500	0.010			Vel = 2.78	
HDR to BFP	0.0	4.26 120		0.0	0.500	40.082				
BFP to 6UG	123.29	0.0040		0.0	0.500	0.002			Vel = 2.78	
BFP to 6UG	0.0	4.26 120		0.0	3.000	40.084				
6UG to TEST	123.29	0.0040		0.0	3.000	0.012			* Fixed loss = 7 Vel = 2.78	
6UG to TEST	0.0	6.16 140	1L 1G	12.911 4.304	60.000 60.252	47.096 -0.918				
TEST	123.29	0.0005	1T	43.037	120.252	0.061			Vel = 1.33	
	100.00								Qa = 100.00	
	223.29					46.239			K Factor = 32.84	