



. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : THOMAS STREET APARTMENTS
Building : WOOD STRUCTURE
Location : 1ST FLOOR- E.C. SIDEWALLS
System : WET
Contract : C16021
Data File : THOMAS ST APT- 1ST FLR E.C. SIDEWALLS.WXF

Hydraulic Design Information Sheet

Name - 32 THOMAS STREET APARTMENTS Date - 8/23/16
 Location - 1ST FLOOR- E.C. SIDEWALLS
 Building - WOOD STRUCTURE System No. - WET
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16021
 Calculated By - T. PRAY Drawing No. - 1 OF 2
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 11'-10"
 Occupancy - OFFICE & CONFERENCE ROOMS

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 938 SF	System Type	Sprinkler/Nozzle
	Density	- .1	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 320	() Dry	Model VK606
E	Elevation at Highest Outlet	- 111.42	() Deluge	Size 3/4
S	Hose Allowance - Inside	-	() Preaction	K-Factor 8.0
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 232.71 Press Required - 48.34 AT TEST
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 8/22/16		Cap. -
T	Time of Test - 11:30PM	Rated Cap.-	Elev.-
E	Static Press - 51	@ Press -	
R	Residual Press - 49	Elev. -	Well
S	Flow - 903		Proof Flow
U	Elevation - 100		

P Location - HYDRANTS ARE LOCATED ON THOMAS STREET, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
THOMAS STREET APARTMENTS


Page 2
Date 8/23/2016

City Water Supply:

C1 - Static Pressure : 51
C2 - Residual Pressure: 49
C2 - Residual Flow : 903

Demand:

D1 - Elevation : 4.946
D2 - System Flow : 132.709
D2 - System Pressure : 48.338
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 232.709
Safety Margin : 2.499



Fittings Used Summary

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 3
Date 8/23/2016

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

Pressure / Flow Summary - STANDARD

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 4
Date 8/23/2016

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DO01	0.0	8	16.0	na	32.0	0.1	320	16.0
180	111.42	K = K @ EQ01	17.92	na	32.0			
181	111.42	8	17.94	na	33.88	0.1	320	16.0
182	111.42	K = K @ EQ01	18.24	na	32.29			
183	111.42	8	18.64	na	34.54	0.1	320	16.0
163	110.67		24.97	na				
164	110.67		25.82	na				
155	110.67		29.12	na				
TOR	97.88		41.12	na				
HDR	97.88		44.17	na				
BFP	97.88		44.17	na				
6UG	97.88		49.19	na				
TEST	100.0		48.34	na	100.0			

The maximum velocity is 11.88 and it occurs in the pipe between nodes DO01 and EQ01

Final Calculations - Hazen-Williams

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 5
Date 8/23/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DO01 to EQ01	32.00 32.0	1.049 120 0.3105	1T	5.0 0.0 0.0	1.170 5.000 6.170	16.000 0.0 1.916			K Factor = 8.00 Vel = 11.88	
	0.0 32.00					17.916			K Factor = 7.56	
180 to 181	32.00 32.0	2.157 120 0.0090		0.0 0.0 0.0	2.330 0.0 2.330	17.916 0.0 0.021			K Factor @ node EQ01 Vel = 2.81	
181 to 182	33.88 65.88	2.157 120 0.0353		0.0 0.0 0.0	8.670 0.0 8.670	17.937 0.0 0.306			K Factor = 8.00 Vel = 5.78	
182 to 183	32.29 98.17	2.157 120 0.0737		0.0 0.0 0.0	5.330 0.0 5.330	18.243 0.0 0.393			K Factor @ node EQ01 Vel = 8.62	
183 to 163	34.54 132.71	2.157 120 0.1289	2I 1T	8.615 12.307 0.0	25.670 20.922 46.592	18.636 0.325 6.005			K Factor = 8.00 Vel = 11.65	
163 to 164	0.0 132.71	2.157 120 0.1288	1I	4.307 0.0 0.0	2.330 4.307 6.637	24.966 0.0 0.855			Vel = 11.65	
164 to 155	0.0 132.71	2.157 120 0.1289	2I 1J	8.615 10.461 0.0	6.500 19.076 25.576	25.821 0.0 3.296			Vel = 11.65	
155 to TOR	0.0 132.71	2.157 120 0.1289	5I	21.537 0.0 0.0	28.590 21.537 50.127	29.117 5.539 6.460			Vel = 11.65	
TOR to HDR	0.0 132.71	2.157 120 0.1289	1G 1Z 1T	1.231 6.153 12.307	4.000 19.691 23.691	41.116 0.0 3.054			Vel = 11.65	
HDR to BFP	0.0 132.71	4.26 120 0.0040		0.0 0.0 0.0	0.500 0.0 0.500	44.170 0.0 0.002			Vel = 2.99	
BFP to 6UG	0.0 132.71	4.26 120 0.0047		0.0 0.0 0.0	3.000 0.0 3.000	44.172 5.000 0.014			* Fixed loss = 5 Vel = 2.99	
6UG to TEST	0.0 132.71	6.16 140 0.0006	1L 1G 1T	12.911 4.304 43.037	60.000 60.252 120.252	49.186 -0.918 0.070			Vel = 1.43	
	100.00 232.71					48.338			Qa = 100.00 K Factor = 33.47	