

**. . . Fire Protection by Computer Design**

Residential Fire Protection  
64 Daggett Hill Rd.  
Greene, ME 04236  
(207)946-343

Job Name : THOMAS STREET APARTMENTS  
Building : WOOD STRUCTURE  
Location : 1ST FLOOR- OFFICE SPACE  
System : 1  
Contract : C16021  
Data File : THOMAS ST APT- 1ST FLR SS SIDEWALLS.WXF

Hydraulic Design Information Sheet

Name - 32 THOMAS STREET APARTMENTS Date - 8/23/16  
 Location - 1ST FLOOR- OFFICE SPACE  
 Building - WOOD STRUCTURE System No. - 1  
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16021  
 Calculated By - T. PRAY Drawing No. - 1 OF 2  
 Construction: (X) Combustible ( ) Non-Combustible Ceiling Height - 12'-0"  
 Occupancy - OFFICE SPACE

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. ( ) 1 ( ) 2 ( ) 3 ( ) Ex.Haz.  
 Y ( ) NFPA 231 ( ) NFPA 231C ( ) Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 960 SF	System Type	Sprinkler/Nozzle
	Density	- .1	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 149	( ) Dry	Model VK305
E	Elevation at Highest Outlet	- 111.96	( ) Deluge	Size 1/2"
S	Hose Allowance - Inside	-	( ) Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	( ) Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 261.91 Press Required - 44.59 AT TEST  
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 8/22/16		Cap. -
T	Time of Test - 11:30 AM	Rated Cap.-	Elev.-
E	Static Press - 51	@ Press -	
R	Residual Press - 49	Elev. -	Well
S	Flow - 903		Proof Flow
U	Elevation - 100		

P Location - HYDRANTS ARE LOCATED ON THOMAS STREET, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	( ) Single Row	( ) Conven. Pallet	( ) Auto. Storage ( ) Encap.
S	( ) Double Row	( ) Slave Pallet	( ) Solid Shelf ( ) Non
T	( ) Mult. Row		( ) Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling  
 A Longitudinal Transverse

E Horizontal Barriers Provided:

# Water Supply Curve (C)

Residential Fire Protection  
THOMAS STREET APARTMENTS


Page 2  
Date 8/23/2016

### City Water Supply:

C1 - Static Pressure : 51  
C2 - Residual Pressure: 49  
C2 - Residual Flow : 903

### Demand:

D1 - Elevation : 5.180  
D2 - System Flow : 161.908  
D2 - System Pressure : 44.594  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : 100  
D3 - System Demand : 261.908  
Safety Margin : 6.203



# Fittings Used Summary

Residential Fire Protection  
THOMAS STREET APARTMENTS

Page 3  
Date 8/23/2016

## Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61

# Pressure / Flow Summary - STANDARD

Residential Fire Protection  
THOMAS STREET APARTMENTS

Page 4  
Date 8/23/2016

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
120	111.96	5.6	7.08	na	14.9	0.1	149	7.0
121	111.96	5.6	7.99	na	15.82	0.1	149	7.0
122	110.67	5.6	10.06	na	17.77	0.1	149	7.0
123	111.96	5.6	7.83	na	15.67	0.1	149	7.0
124	111.96	5.6	8.83	na	16.64	0.1	149	7.0
159	110.67		11.06	na				
125	110.67	5.6	11.98	na	19.38	0.1	149	7.0
126	111.96	5.6	12.25	na	19.6	0.1	149	7.0
127	111.96	5.6	12.31	na	19.64	0.1	149	7.0
162	110.67		13.33	na				
163	110.67		16.4	na				
28	111.96	5.6	16.11	na	22.48	0.1	149	7.0
164	110.67		17.34	na				
155	110.67		22.1	na				
TOR	97.88		36.98	na				
HDR	97.88		41.39	na				
BFP	97.88		41.39	na				
6UG	97.88		45.41	na				
TEST	100.0		44.59	na	100.0			

The maximum velocity is 15.79 and it occurs in the pipe between nodes 125 and 162

# Final Calculations - Hazen-Williams

Residential Fire Protection  
THOMAS STREET APARTMENTS

Page 5  
Date 8/23/2016

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
120 to 121	14.90 14.9	1.049 120 0.0755		0.0 0.0 0.0	12.000 0.0 12.000	7.079 0.0 0.906			K Factor = 5.60 Vel = 5.53	
121 to 122	15.82 30.72	1.38 120 0.0757	3E	9.0 0.0 0.0	11.080 9.000 20.080	7.985 0.559 1.521			K Factor = 5.60 Vel = 6.59	
122 to 159	17.77 48.49	1.38 120 0.1762		0.0 0.0 0.0	5.670 0.0 5.670	10.065 0.0 0.999			K Factor = 5.60 Vel = 10.40	
	0.0 48.49						11.064		K Factor = 14.58	
123 to 124	15.67 15.67	1.049 120 0.0829		0.0 0.0 0.0	12.000 0.0 12.000	7.833 0.0 0.995			K Factor = 5.60 Vel = 5.82	
124 to 159	16.64 32.31	1.38 120 0.0831	2E 1T	6.0 6.0 0.0	8.170 12.000 20.170	8.828 0.559 1.677			K Factor = 5.60 Vel = 6.93	
159 to 125	48.49 80.8	1.61 120 0.2138		0.0 0.0 0.0	4.290 0.0 4.290	11.064 0.0 0.917			Vel = 12.73	
125 to 162	19.39 100.19	1.61 120 0.3184		0.0 0.0 0.0	4.250 0.0 4.250	11.981 0.0 1.353			K Factor = 5.60 Vel = 15.79	
	0.0 100.19						13.334		K Factor = 27.44	
126 to 127	19.60 19.6	2.067 120 0.0046		0.0 0.0 0.0	12.000 0.0 12.000	12.251 0.0 0.055			K Factor = 5.60 Vel = 1.87	
127 to 162	19.65 39.25	2.067 120 0.0166	2E 1T	10.0 10.0 0.0	8.170 20.000 28.170	12.306 0.559 0.469			K Factor = 5.60 Vel = 3.75	
162 to 163	100.18 139.43	2.067 120 0.1738	1T	10.0 0.0 0.0	7.670 10.000 17.670	13.334 0.0 3.071			Vel = 13.33	
163 to 164	0.0 139.43	2.157 120 0.1412	1I	4.307 0.0 0.0	2.330 4.307 6.637	16.405 0.0 0.937			Vel = 12.24	
	0.0 139.43						17.342		K Factor = 33.48	
28 to 164	22.48 22.48	1.38 120 0.0425	1E 1T	3.0 6.0 0.0	6.875 9.000 15.875	16.109 0.559 0.674			K Factor = 5.60 Vel = 4.82	
164 to 155	139.43 161.91	2.157 120 0.1862	2I 1J	8.615 10.461 0.0	6.500 19.076 25.576	17.342 0.0 4.762			Vel = 14.22	
155 to TOR	0.0 161.91	2.157 120 0.1862	5I	21.537 0.0 0.0	28.590 21.537 50.127	22.104 5.539 9.333			Vel = 14.22	

# Final Calculations - Standard

Residential Fire Protection  
THOMAS STREET APARTMENTS

Page 6  
Date 8/23/2016

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TOR	0.0	2.157	1G	1.231	4.000	36.976				
to		120	1Z	6.153	19.691	0.0				
HDR	161.91	0.1862	1T	12.307	23.691	4.411		Vel = 14.22		
HDR	0.0	4.26		0.0	0.500	41.387				
to		120		0.0	0.0	0.0				
BFP	161.91	0.0080		0.0	0.500	0.004		Vel = 3.64		
BFP	0.0	4.26		0.0	3.000	41.391				
to		120		0.0	0.0	4.000		* Fixed loss = 4		
6UG	161.91	0.0067		0.0	3.000	0.020		Vel = 3.64		
6UG	0.0	6.16	1L	12.911	60.000	45.411				
to		140	1G	4.304	60.252	-0.918				
TEST	161.91	0.0008	1T	43.037	120.252	0.101		Vel = 1.74		
	100.00							Qa = 100.00		
	261.91					44.594		K Factor = 39.22		