

. . . Fire Protection by Computer Design

Residential Fire Protection
64 Daggett Hill Rd.
Greene, ME 04236
(207)946-343

Job Name : THOMAS STREET APARTMENTS
Building : WOOD STRUCTURE
Location : 3RD FLOOR- RESIDENTIAL UPRIGHTS
System : WET
Contract : C16021
Data File : THOMAS ST APT- 3RD FLR RES UPRIGHT.WXF

Hydraulic Design Information Sheet

Name - 32 THOMAS STREET APARTMENTS Date - 8/23/16
 Location - 3RD FLOOR- RESIDENTIAL UPRIGHTS
 Building - WOOD STRUCTURE System No. - WET
 Contractor - RESIDENTIAL FIRE PROTECTION Contract No. - C16021
 Calculated By - T. PRAY Drawing No. - 1 OF 2
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 23.67'
 Occupancy - APARTMENT

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other RESIDENTIAL DESIGN

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 4 HEADS	System Type	Sprinkler/Nozzle
	Density	- .0508	(X) Wet	Make VIKING
D	Area Per Sprinkler	- 256	() Dry	Model VK467
E	Elevation at Highest Outlet	- 136.55	() Deluge	Size 7/16
S	Hose Allowance - Inside	-	() Preaction	K-Factor
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.155
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 156.72 Press Required - 47.44 AT TEST
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 8/22/16		Cap. -
T	Time of Test - 11:30PM	Rated Cap.-	Elev.-
E	Static Press - 51	@ Press -	
R	Residual Press - 49	Elev. -	Well
S	Flow - 903		Proof Flow
U	Elevation - 100		

P Location - HYDRANTS ARE LOCATED ON THOMAS STREET, SEE PLOT PLAN

L Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method:	%	Palletized % Rack
	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

E Horizontal Barriers Provided:

Water Supply Curve (C)

Residential Fire Protection
THOMAS STREET APARTMENTS


Page 2
Date 8/2/2016

City Water Supply:

C1 - Static Pressure : 51
C2 - Residual Pressure: 49
C2 - Residual Flow : 903

Demand:

D1 - Elevation : 15.830
D2 - System Flow : 56.722
D2 - System Pressure : 47.443
Hose (Adj City) : _____
Hose (Demand) : 100
D3 - System Demand : 156.722
Safety Margin : 3.479



Fittings Used Summary

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 3
Date 8/2/2016

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	Generic Butterfly Valve	0	0	0	0	0	0	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
F	45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
L	Long Turn Elbow	1	1	2	2	2	3	4	5	5	6	8	9	13	16	18	24	27	30	34	40
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121

Pressure / Flow Summary - STANDARD

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 4
Date 8/2/2016

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
100	136.55	4.9	7.04	na	13.0	0.0508	256	7.0
101	136.55	4.9	7.61	na	13.51	0.0508	256	7.0
102	136.55	4.9	8.07	na	13.92	0.0508	256	7.0
103	136.55	4.9	11.05	na	16.29	0.0508	256	7.0
150	136.55		11.28	na				
151	136.55		11.43	na				
152	136.55		13.77	na				
153	122.21		24.23	na				
154	122.21		27.62	na				
155	110.67		34.75	na				
TOR	97.88		41.0	na				
HDR	97.88		41.34	na				
BFP	97.88		41.34	na				
6UG	97.88		48.35	na				
TEST	100.0		47.44	na	100.0			

The maximum velocity is 8.94 and it occurs in the pipe between nodes 151 and 152

Final Calculations - Hazen-Williams

Residential Fire Protection
THOMAS STREET APARTMENTS

Page 5
Date 8/2/2016

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
100 to 101	13.00 13.0	1.049 120 0.0587		0.0 0.0 0.0	9.580 0.0 9.580	7.044 0.0 0.562			K Factor = 4.90 Vel = 4.83	
101 to 102	13.52 26.52	1.38 120 0.0577		0.0 0.0 0.0	7.960 0.0 7.960	7.606 0.0 0.459			K Factor = 4.90 Vel = 5.69	
102 to 151	13.91 40.43	1.38 120 0.1259	1E 1T	3.0 6.0 0.0	17.710 9.000 26.710	8.065 0.0 3.362			K Factor = 4.90 Vel = 8.67	
	0.0 40.43					11.427			K Factor = 11.96	
103 to 150	16.29 16.29	1.38 120 0.0234	1T	6.0 0.0 0.0	4.040 6.000 10.040	11.050 0.0 0.235			K Factor = 4.90 Vel = 3.49	
150 to 151	0.0 16.29	1.61 120 0.0110	1T	8.0 0.0 0.0	4.920 8.000 12.920	11.285 0.0 0.142			Vel = 2.57	
151 to 152	40.43 56.72	1.61 120 0.1112	1T 1E	8.0 4.0 0.0	9.040 12.000 21.040	11.427 0.0 2.339			Vel = 8.94	
152 to 153	0.0 56.72	1.61 120 0.1111	2E 2F 1T	8.0 4.0 8.0	18.250 20.000 38.250	13.766 6.211 4.250			Vel = 8.94	
153 to 154	0.0 56.72	1.61 120 0.1111	1T	8.0 0.0 0.0	22.540 8.000 30.540	24.227 0.0 3.394			Vel = 8.94	
154 to 155	0.0 56.72	1.61 120 0.1111	2E	8.0 0.0 0.0	11.210 8.000 19.210	27.621 4.998 2.135			Vel = 8.94	
155 to TOR	0.0 56.72	2.635 120 0.0101	5I	41.186 0.0 0.0	28.590 41.186 69.776	34.754 5.539 0.705			Vel = 3.34	
TOR to HDR	0.0 56.72	2.635 120 0.0101	1F 1B 1T	4.119 9.61 16.474	4.000 30.203 34.203	40.998 0.0 0.345			Vel = 3.34	
HDR to BFP	0.0 56.72	4.26 120 0.0		0.0 0.0 0.0	0.500 0.0 0.500	41.343 0.0 0.0			Vel = 1.28	
BFP to 6UG	0.0 56.72	4.26 120 0.0010		0.0 0.0 0.0	3.000 0.0 3.000	41.343 7.000 0.003			* Fixed loss = 7 Vel = 1.28	
6UG to TEST	0.0 56.72	6.16 140 0.0001	1L 1G 1T	12.911 4.304 43.037	60.000 60.252 120.252	48.346 -0.918 0.015			Vel = 0.61	
	100.00 156.72					47.443			Qa = 100.00 K Factor = 22.75	