

**. . . Fire Protection by Computer Design**

Maine Fire Protection Systems  
6 Dowd Road  
Bangor, Maine 04401  
(207) 942-8809


Job Name : 780 calc file  
Building :  
Location :  
System :  
Contract :  
Data File : 780 calc file AREA 1.wxf

# Water Supply Curve C

Maine Fire Protection Systems  
780 calc file

Page 1  
Date

|   |  |  |
|---|--|--|
| <b>City Water Supply:</b><br>C1 - Static Pressure : 49<br>C2 - Residual Pressure: 45<br>C2 - Residual Flow : 1342<br><br><b>City Water Adjusted to Pump Inlet for Pf - Elev - Hose Flow</b><br>A1 - Adjusted Static: 49.797<br>A2 - Adj Resid : 4.79 @ 50<br>A3 - Adj Resid : 0 @ 54.44 | <b>Pump Data:</b><br>P1 - Pump Churn Pressure : 55<br>P2 - Pump Rated Pressure : 50<br>P2 - Pump Rated Flow : 50<br>P3 - Pump Pressure @ Max Flow : 32.5<br>P3 - Pump Max Flow : 54.44<br>City Residual Flow @ 0 = 5199.17<br>City Residual Flow @ 20 = 3915.62<br>City Water @ 150% of Pump = 48.99<br>Pump flow terminated at adjusted curve 0 psi | <b>Demand:</b><br>D1 - Elevation : 12.560<br>D2 - System Flow : 34.651<br>D2 - System Pressure : 55.404<br>Hose ( Demand ) : _____<br>D3 - System Demand : 34.651<br>Hose ( Adj City ) : 150<br>Safety Margin : 24.947 |
|---|--|--|



# Fittings Used Summary

Maine Fire Protection Systems  
780 calc file

Page 2  
Date

## Fitting Legend

| Abbrev. | Name                       | 1/2  | 3/4 | 1 | 1 1/4 | 1 1/2 | 2  | 2 1/2 | 3  | 3 1/2 | 4  | 5  | 6  | 8  | 10 | 12 | 14 | 16 | 18 | 20  | 24  |
|---------|----------------------------|--|-----|---|-------|-------|----|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|
| E       | NFPA 13 90' Standard Elbow | 1  | 2   | 2 | 3     | 4     | 5  | 6     | 7  | 8     | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50  | 61  |
| Fsp     | Flow Switch Potter VSR     | Fitting generates a Fixed Loss Based on Flow |     |   |       |       |    |       |    |       |    |    |    |    |    |    |    |    |    |     |     |
| T       | NFPA 13 90' Flow thru Tee  | 3  | 4   | 5 | 6     | 8     | 10 | 12    | 15 | 17    | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Zik     | Wilkins 950XL              | Fitting generates a Fixed Loss Based on Flow |     |   |       |       |    |       |    |       |    |    |    |    |    |    |    |    |    |     |     |

## Units Summary

Diameter Units           Inches  
 Length Units            Feet  
 Flow Units               US Gallons per Minute  
 Pressure Units          Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

# Pressure / Flow Summary - STANDARD

Maine Fire Protection Systems  
780 calc file

Page 3  
Date

| Node No. | Elevation | K-Fact | Pt Actual | Pn | Flow Actual | Density | Area | Press Req. |
|----------|-----------|--------|-----------|----|-------------|---------|------|------------|
| 1        | 31.0      | 4.9    | 12.5      | na | 17.33       | 0.1     | 96   | 12.5       |
| 2        | 31.0      |        | 13.33     | na |             |         |      |            |
| 3        | 31.0      |        | 17.06     | na |             |         |      |            |
| 3F       | 31.0      |        | 17.64     | na |             |         |      |            |
| 2F       | 14.0      |        | 26.71     | na |             |         |      |            |
| GF       | 14.0      |        | 30.97     | na |             |         |      |            |
| BSMT     | 8.0       |        | 34.98     | na |             |         |      |            |
| TOR      | 8.0       |        | 44.71     | na |             |         |      |            |
| PO       | 0.0       |        | 55.4      | na |             |         |      |            |
| PI       | 0.0       |        | 26.95     | na |             |         |      |            |
| 4        | 1.0       |        | 27.44     | na |             |         |      |            |
| 5        | 1.0       |        | 49.31     | na |             |         |      |            |
| 6        | 1.0       |        | 49.31     | na |             |         |      |            |
| TEST     | 2.0       |        | 48.9      | na | 150.0       |         |      |            |
| 7        | 31.0      | 4.9    | 12.5      | na | 17.32       | 0.1     | 96   | 12.5       |

The maximum velocity is 22.97 and it occurs in the pipe between nodes 4 and 5

# Final Calculations - Hazen-Williams - 2007

Maine Fire Protection Systems  
780 calc file

Page 4  
Date

| Hyd. Ref. Point          | Qa<br>Qt | Dia. "C"<br>Pf/Ft | Fitting or Eqv. | Ln.    | Pipe Ftg's Total | Pt Pe<br>Pf | Pt Pv<br>Pn | ***** | Notes                 | ***** |
|--------------------------|----------|-------------------|-----------------|--------|------------------|-------------|-------------|-------|-----------------------|-------|
| 1                        | 17.33    | 1.049             | 2E              | 4.0    | 4.270            | 12.505      |             |       | K Factor = 4.90       |       |
| to                       |          | 120.0             |                 | 0.0    | 4.000            | 0.0         |             |       |                       |       |
| 2                        | 17.33    | 0.0998            |                 | 0.0    | 8.270            | 0.825       |             |       | Vel = 6.43            |       |
| 2                        | 17.32    | 1.049             | 1E              | 2.0    | 8.380            | 13.330      |             |       |                       |       |
| to                       |          | 120.0             |                 | 0.0    | 2.000            | 0.0         |             |       |                       |       |
| 3                        | 34.65    | 0.3597            |                 | 0.0    | 10.380           | 3.734       |             |       | Vel = 12.86           |       |
| 3                        | 0.0      | 1.097             |                 | 0.0    | 2.000            | 17.064      |             |       |                       |       |
| to                       |          | 120.0             |                 | 0.0    | 0.0              | 0.0         |             |       |                       |       |
| 3F                       | 34.65    | 0.2890            |                 | 0.0    | 2.000            | 0.578       |             |       | Vel = 11.76           |       |
| 3F                       | 0.0      | 1.38              | 2E              | 6.0    | 12.000           | 17.642      |             |       |                       |       |
| to                       |          | 120.0             |                 | 0.0    | 6.000            | 7.363       |             |       |                       |       |
| 2F                       | 34.65    | 0.0946            |                 | 0.0    | 18.000           | 1.703       |             |       | Vel = 7.43            |       |
| 2F                       | 0.0      | 1.38              | 3E              | 9.0    | 12.000           | 26.708      |             |       |                       |       |
| to                       |          | 120.0             | 4T              | 24.0   | 33.000           | 0.0         |             |       |                       |       |
| GF                       | 34.65    | 0.0946            |                 | 0.0    | 45.000           | 4.258       |             |       | Vel = 7.43            |       |
| GF                       | 0.0      | 1.38              | 1E              | 3.0    | 12.000           | 30.966      |             |       |                       |       |
| to                       |          | 120.0             |                 | 0.0    | 3.000            | 2.599       |             |       |                       |       |
| BSMT                     | 34.65    | 0.0945            |                 | 0.0    | 15.000           | 1.418       |             |       | Vel = 7.43            |       |
| BSMT                     | 0.0      | 1.38              | 5E              | 15.0   | 44.080           | 34.983      |             |       |                       |       |
| to                       |          | 120.0             | 2T              | 12.0   | 27.000           | 3.000       |             |       | ** Fixed Loss = 3     |       |
| TOR                      | 34.65    | 0.0946            | 1Fsp            | 0.0    | 71.080           | 6.725       |             |       | Vel = 7.43            |       |
| TOR                      | 0.0      | 1.61              | 2E              | 8.0    | 8.000            | 44.708      |             |       |                       |       |
| to                       |          | 120.0             | 1Zik            | 0.0    | 8.000            | 9.982       |             |       | ** Fixed Loss = 6.517 |       |
| PO                       | 34.65    | 0.0446            |                 | 0.0    | 16.000           | 0.714       |             |       | Vel = 5.46            |       |
|                          | 0.0      |                   |                 |        |                  |             |             |       |                       |       |
|                          | 34.65    |                   |                 |        |                  | 55.404      |             |       | K Factor = 4.66       |       |
| System Demand Pressure   |          |                   |                 |        |                  | 55.404      |             |       |                       |       |
| Safety Margin            |          |                   |                 |        |                  | 24.947      |             |       |                       |       |
| Continuation Pressure    |          |                   |                 |        |                  | 80.351      |             |       |                       |       |
| Pressure @ Pump Outlet   |          |                   |                 |        |                  | 80.351      |             |       |                       |       |
| Pressure From Pump Curve |          |                   |                 |        |                  | -53.401     |             |       |                       |       |
| Pressure @ Pump Inlet    |          |                   |                 |        |                  | 26.950      |             |       |                       |       |
| PI                       | 0.0      | 1.598             |                 | 0.0    | 30.120           | 26.950      |             |       |                       |       |
| to                       |          | 150.0             |                 | 0.0    | 0.0              | -0.433      |             |       |                       |       |
| 4                        | 34.65    | 0.0306            |                 | 0.0    | 30.120           | 0.923       |             |       | Vel = 5.54            |       |
| 4                        | 0.0      | 0.785             | 1E              | 2.387  | 20.000           | 27.440      |             |       |                       |       |
| to                       |          | 150.0             |                 | 0.0    | 2.386            | 0.0         |             |       |                       |       |
| 5                        | 34.65    | 0.9769            |                 | 0.0    | 22.386           | 21.869      |             |       | Vel = 22.97           |       |
| 5                        | 0.0      | 12.34             |                 | 0.0    | 750.000          | 49.309      |             |       |                       |       |
| to                       |          | 120.0             |                 | 0.0    | 0.0              | 0.0         |             |       |                       |       |
| 6                        | 34.65    | 0.0               |                 | 0.0    | 750.000          | 0.001       |             |       | Vel = 0.09            |       |
| 6                        | 0.0      | 6.16              | 1E              | 15.101 | 300.000          | 49.310      |             |       |                       |       |
| to                       |          | 120.0             |                 | 0.0    | 15.101           | -0.433      |             |       |                       |       |
| TEST                     | 34.65    | 0.0001            |                 | 0.0    | 315.101          | 0.021       |             |       | Vel = 0.37            |       |
|                          | 150.00   |                   |                 |        |                  |             |             |       | Qa = 150.00           |       |
|                          | 184.65   |                   |                 |        |                  | 48.898      |             |       | K Factor = 26.41      |       |
| 7                        | 17.32    | 1.049             | 1T              | 5.0    | 3.320            | 12.500      |             |       | K Factor = 4.90       |       |
| to                       |          | 120.0             |                 | 0.0    | 5.000            | 0.0         |             |       |                       |       |
| 2                        | 17.32    | 0.0998            |                 | 0.0    | 8.320            | 0.830       |             |       | Vel = 6.43            |       |

# Final Calculations - Hazen-Williams

Maine Fire Protection Systems  
780 calc file

Page 5  
Date

| Hyd.<br>Ref.<br>Point | Qa<br><br>Qt | Dia.<br>"C"<br>Pf/Ft | Fitting<br>or<br>Eqv. Ln. | Pipe<br>Ftng's<br>Total | Pt<br>Pe<br>Pf | Pt<br>Pv<br>Pn | ***** | Notes           | ***** |
|-----------------------|--------------|----------------------|---------------------------|-------------------------|----------------|----------------|-------|-----------------|-------|
|                       | 0.0<br>17.32 |                      |                           |                         | 13.330         |                |       | K Factor = 4.74 |       |