


MPC- DACT - Digital Alarm Communication Transmitter

Features



UL Listed for Central Station/Remote Station Monitoring (NFPA 72 Chapter 4)

- Four separate monitoring accounts available
- Two phone lines available
- Can send serial information to monitoring station
- Reports in 8 standard communication formats
- Automatic 24 hour test available
- Mounts within the MPC-6000 or 7000 enclosure directly on the main processor board
- All programming is done as part of the CIS-4 configuration



Description

The Model MPC-DACT Digital Alarm Communication Transmitter is used to provide communication between the MPC-6000 or 7000 and a central or remote monitoring station. The MPC-DACT supports two lines and four accounts, and can transmit serial information (including the address of the event) to the monitoring station. Any of the accounts can send alarm, supervisory, trouble, reset, or trouble restore information (or any combination) as required. Communication protocols available include SIA DCS 8, SIA DCS 20, Ademco Contact ID, 3/1 1400 Hz, 3/1 2300 Hz, 4/2 1400 Hz and 4/2 2300 Hz. The FS-DACT can perform the automatic 24 hour test required by NFPA.

The MPC-DACT mounts within the MPC-6000 or 7000 enclosure on an 8-pin connection point on the main board. No external enclosure is required, and no wires are required between the panel and the dialer. Programming of account and dialing information is done as part of the system configuration. No external programmer for the dialer is required, and dialer information can be downloaded as part of the system configuration.

Ordering Information

Model	Description	Part No.
MPC-DACT	Digital dialer for the MPC-6000 or 7000	500-649330FA



Siemens Building Technologies, Inc. 8 Fernwood Road • Florham Park, NJ 07932 Tel: (973) 593-2600 • Fax: (973) 593-6670 Web: www.faradayllc.com WARNING - The information contained in this document is intended only as a summary and is subject to change without notice. The devices described in this document have specific instruction sheets which cover various technical, limitation and liability information. Copies of these instruction sheets and the General Product Warning and Limitations Document, which also contains important information, are provided with the product and are available from the Manufacturer. Information contained in these documents should be consulted before specifying or using the product. For further information or assistance concerning particular problems contact the Manufacturer.

12/03 2M SBT/IG December 2003 - New Issue