

From: "Kevin Lessard" <mklessard1@maine.rr.com>
To: <BlaFlamme@portlandmaine.gov>
Date: 7/15/2010 3:57 PM
Subject: R&E Associates Vaughn St Unit 213

Lessard & Son's Electric

173 Temple Avenue

Old Orchard Beach, ME 04064

(207) 934-7204 or (207) 467-0642

?

July 15, 2010

?

R&E Associates

Vaughn St Unit 213

To whom it may concern,

Due to fire damage, the wires that were replaced went to five receptacles. As a result of intense heat, three light boxes were replaced. Two smoke detectors, one for each bedroom were placed. Any outlets and switch boxes that had melted were replaced as well. There were two in the kitchen and one in the hallway. IN the bathroom I added boxes for the vanity light (there were none before). All wires were straightened and fastened in accordance to code.

The following locations did not receive work performed by Lessard and Son's electric:

- 1) Wiring to the bedrooms
- 2) Wiring to the hallway
- 3) Wiring to the bathroom
- 4) Wiring to the kitchen
- 5) The addition to the living

?

If you should have any questions or concerns please contact me at the above listed number.

Sincerely,

?

?

Kevin Lessard, Owner

Lessard & Son's Electric

PLEASE SCAN INTO FILE
CB2 063 C009003
213 VAUGHAN ST. # 3
7/16/2010 BKL