Per e-mail from applicant, the steps will be removed completely replaced/relocated. The porch will be completely enclosed by r (no steps off it) and the interior stairway will be used for egress story tenants.

CITY OF PORTLAND, MAINE RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/23/16

Steps – (5)
Depth 11 1/4"
Rise 7"
Open space 2 1/2"

EAST ELEVATION

REGISTERED ARCHITECT
ROGER P BUTEAU
No. 1353
STATE OF MAINE

NTUM NS	SCALE: DATE: PROJECT No:	VAUGHAN STREET AND EAST ELEVATIONS	OF SHEET No: A3

EXISTING FIRST FLOOR PLAN

AN CONDOMINIUM WN & SONS	SCALE: DATE: PROJECT No:	EXISTING FLOOR PLANS	OF SHEET No: A6

~~These steps to be moved here.~~ Resulting hole in floor to be filled with matched planks.