DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager			Inspector		Inspection Date	
D'amboise Kevin J			Jodine Adams		10/12/2004	
Locatation		CBL	Status		Inspectio	n Type
67 WEST ST		063 C030001	Re-Inspect 30 Days		Complaint-Inspection	
Code	Int/Ext		Floor	Unit No.	Area	Compliance Date

	Code	Int/Ext	Floor	Unit No.	Area	Compliance Date		
1)	6-116.5	Interior	1		Hall			
	Violation:	Fire Protection						
	Notes:	smoke detector missing						
2)	6-113.5							
		Maintenance of lighting fixtures						
		light fixture missing globe						
3)								
	Violation:	Maintenance of lighting fixtures						
	Notes:	low voltage wires must be protected or removed						
4)	6-108.2	Interior	2-3		Hall			
	Violation:	Interior floors, walls, ceilings and doors						
	Notes:	plaster falling						
5)	6-113.5							
	Violation:	Maintenance of lighting fixtures						
	Notes:	exposed wiring must be protected or removed						

Comments:

I have also included a building permit application for the work that was done in the basement. This must also be applied for within this 30 day period