

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

264 BRACKETT STREET LLC

**Located at**

264 BRACKETT ST

**PERMIT ID:** 2015-01604

**ISSUE DATE:** 08/20/2015

**CBL:** 063 D003001

has permission to **Renovations which include the removal of plaster and adding of drywall in the 2nd floor bathroom.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ David Petruccelli*

**Fire Official**

*/s/ Laurie Leader*

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

**PERMIT ID:** 2015-01604

**Located at:** 264 BRACKETT ST

**CBL:** 063 D003001

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing

Electrical Close-in

Final Inspection

Final - Electric

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|   |  |   |  |                                  |
|---|--|---|--|----------------------------------|
| <b>City of Portland, Maine - Building or Use Permit</b>             |  | <b>Permit No:</b><br>2015-01604   | <b>Date Applied For:</b><br>07/02/2015 | <b>CBL:</b><br>063 D003001       |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 |  |   |  |                                  |
| <b>Proposed Use:</b><br>Same: Four (4) Family                       |  | <b>Proposed Project Description:</b><br>Renovations which include the removal of plaster and adding of drywall in the 2nd floor bathroom.   |  |                                  |
| <b>Dept:</b> Historic   |  | <b>Status:</b> Approved w/Conditions  | <b>Reviewer:</b> Robert Wiener         | <b>Approval Date:</b> 08/12/2015 |
| <b>Note:</b>  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/>   |  |                                  |
| <b>Conditions:</b>  |  | 1) No exterior alterations are approved with this permit. If any exterior work is planned, including but not limited to windows, siding, venting, etc., it must be reviewed and approved prior to construction.   |  |                                  |
| <b>Dept:</b> Zoning   |  | <b>Status:</b> Approved w/Conditions  | <b>Reviewer:</b> Tammy Munson          | <b>Approval Date:</b> 08/03/2015 |
| <b>Note:</b>  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/>   |  |                                  |
| <b>Conditions:</b>  |  | 1) This permit does not certify the legal use of the building.<br>2) This permit approves interior work only.   |  |                                  |
| <b>Dept:</b> Building Inspecti                                      |  | <b>Status:</b> Approved w/Conditions  | <b>Reviewer:</b> Laurie Leader         | <b>Approval Date:</b> 08/20/2015 |
| <b>Note:</b>  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/>   |  |                                  |
| <b>Conditions:</b>  |  | 1) Hardwired photoelectric interconnected battery backup smoke detectors shall be installed in all sleeping rooms, protecting outside these rooms, and on every level.<br><br>The same is required for existing buildings, where permanent wiring is feasible; or at the very least battery operated smoke detectors are required. Verification of this will be upon inspection.<br>2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.<br>3) Carbon Monoxide (CO) alarms shall be installed in each area within or giving access to sleeping rooms. That detection must be powered by the electrical service (plug-in or hardwired) in the building and battery.<br>4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work. |  |                                  |
| <b>Dept:</b> Fire   |  | <b>Status:</b> Approved w/Conditions  | <b>Reviewer:</b> David Petrucci        | <b>Approval Date:</b> 08/07/2015 |
| <b>Note:</b>  |  | <b>Ok to Issue:</b> <input checked="" type="checkbox"/>   |  |                                  |
| <b>Conditions:</b>  |  | 1) All construction shall comply with City Code Chapter 10.<br><a href="http://www.portlandmaine.gov/citycode/chapter010.pdf">http://www.portlandmaine.gov/citycode/chapter010.pdf</a><br>2) Shall comply with 2009 NFPA 1 Chapter 16 Safeguards During Building Construction, Alteration, and Demolition Operations. Any cutting and welding done will require a Hot Work Permit from Fire Department.<br>3) Single-station Carbon Monoxide (CO) alarms powered by the building's electrical service with battery backup are required within the dwelling units. CO alarms shall be installed in the following locations:<br>(1) Outside each separate dwelling unit sleeping area in the immediate vicinity of the bedrooms<br>(2) On every occupiable level of the dwelling unit, including basements, excluding attics and crawl spaces<br>New CO alarms shall be hardwired.  |  |                                  |

- 4) Hardwired single-station smoke alarms are required within the dwelling units. Smoke alarms shall be installed in the following locations:
- (1) All sleeping rooms
  - (2) Outside each separate sleeping area, in the immediate vicinity of the sleeping rooms
  - (3) On each level of the dwelling unit, including basements.
- New smoke alarms shall be photoelectric powered by the building's electrical service with battery backup.
- 5) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer.
- 6) All outstanding code violations shall be corrected prior to final inspection.
- 7) Through-penetrations and membrane penetrations in fire walls, fire barrier walls, and fire resistance rated horizontal assemblies shall be protected by firestop systems or devices in conformance with NFPA 101:8.3.5 (ASTM E 814 or ANSI/UL 1479). Providing firestop labels at each firestop system or device and an onsite manual containing the detail for each firestop system or device used for the project will streamline final inspection approvals.
- 8) Shall meet the requirements of 2009 NFPA 1 Fire Code.