

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

223 WESTERN PROM LLC /Advanced Fire Protection Services

Located at

223 WESTERN PROMENADE

PERMIT ID: 2014-00045

ISSUE DATE: 01/22/2014

CBL: 063 E005001

has permission to **installation of a 13R sprinkler system**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

permit #2013-01639 established three residential condos

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-00045	Date Applied For: 01/09/2014	CBL: 063 E005001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: 3 Residential Condominiums		Proposed Project Description: installation of a 13R sprinkler system		
Dept: Historic Status: Approved w/Conditions Reviewer: Robert Wiener Approval Date: 01/15/2014 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Any masonry repair required in the course of installation must be performed with historically appropriate materials and methods. 2) Bronze plate to be used on building.				
Dept: Zoning Status: Approved Reviewer: Marge Schmuckal Approval Date: 01/15/2014 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions:				
Dept: Fire Status: Approved w/Conditions Reviewer: Craig Messinger Approval Date: 01/20/2014 Note: Ok to Issue: <input checked="" type="checkbox"/> Conditions: 1) Must comply with previous conditions from Permit No: 2013-01639 2) Any outstanding code violations shall be corrected prior to FD approval. 3) Must comply with NFPA 13R systems.				