

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

LEE JANE ELIZABETH

Located at

92 WEST ST

PERMIT ID: 2016-02750

ISSUE DATE: 11/08/2016

CBL: 063 F002001

has permission to **After the Fact permit for removal of stairway from 1st floor entry to 2nd floor entry (formerly served 3rd floor apt.) & removal of kitchen appliances**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

N/A

/s/ Greg Gilbert

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
single family

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases 6 months.**
- **If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

REQUIRED INSPECTIONS:

Final - Commercial

Framing Only

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2016-02750	Date Applied For: 10/20/2016	CBL: 063 F002001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same - Single family		Proposed Project Description: After the Fact permit for removal of stairway from 1st floor entry to 2nd floor entry (formerly served 3rd floor apt.) & removal of kitchen appliances		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 11/02/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) No exterior work is approved with this permit.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Ann Machado	Approval Date: 10/31/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) .All conditions from previous permits for this project are still in effect with the issuance of this permit.		
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Greg Gilbert	Approval Date: 11/08/2016
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) Permit approved based upon information provided by the applicant, This is an After the Fact permit for work that was performed prior to approvals. Inspections are required to confirm Life Safety, electrical and structural compliance, and may require exposure of any hidden elements. Additional work and design approvals may be required.		